

HEIDELBERG, FEBRUARY 2021

ABB EQmatic Energy Analyzer QA/S x.yy.1

KNX, M-Bus and Modbus

Jürgen Schilder Competence Center Europe – Smart Buildings

Agenda

Introduction

Basic

- Planning
- Installing
- Commissioning
 - Connecting to the device and commissioning wizard
 - Main menu “Management”
 - Main menu “System”
 - Main menu “Dashboard”
 - Main menu “Analytics”
 - Main menu “Load control”
 - ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Advanced

- Provide measured values (Modbus TCP and REST API)
- Data sharing via Modbus TCP to KNX (Building Automation Controller BAC/S and Visualisation software)



Introduction

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Why measuring energy consumption?

- Inspection of consumers behavior
- Consumption becomes transparent
- Fair splitting of costs
- Implement energy management systems
- Internal billing
- Detection of “Energy Thieves”
- Creation of incentives for cost saving
- Change of consumers behavior
- Approach for automation
- Load management
- Monitoring of the installation
- ...




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

What is ABB EQmatic?

ABB EQmatic

- is a compact and web-based solution offering for applications in the segment of energy management/-efficiency
- enables customers to record, visualize and process sub-metering data
- is a simple, **ready-to-use solution** for recording, visualizing and analyzing energy and consumption data
- **closes the gap** between field devices (meters) and high-level software applications
- is designed for **Energy-/Facility Manager** or any other operator in **small and mid size commercial buildings**




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

ABB EQmatic – ABB offers various solutions




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

KNX Energy Actuator SE/S 3.16.1

The ABB i-bus® KNX Energy Actuator SE/S 3.16.1 is a Switch Actuator that records the energy consumption of the connected electrical loads in the building

The Energy Actuator determines the active energy consumption per switching output

Furthermore, it provides the total consumption of all three outputs

All meter values can be sent cyclically, on request or when a start or stop event has occurred such as a time, operating period or when a defined consumption threshold is reached

Additionally, when a stop event occurs, the assigned output can be switched off




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

KNX Energy Actuator SE/S 3.16.1

For each channel, the active power, current and voltage as well as further electrical variables (apparent power, crest factor, power factor and frequency) can be measured

The measured values are made available via KNX

They can be monitored with threshold values

Should an overshoot or undershoot of a defined threshold occur, a warning can be sent or a channel switched

The ETS application also enables a simple load management functionality, where up to ten Energy Actuators can be interconnected

The electrical loads connected to the three floating switch outputs can be switched via the KNX or switched manually directly on the device



ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

KNX Meter Interface Module ZS/S 1.1

Electronic energy meters make the current energy values available on the KNX bus system in conjunction with a KNX interface (remote meter reading via KNX)

Consumption and measured values of electrical energy meters are collected via the Meter Interface Module ZS/S 1.1 and transferred via the ABB i-bus KNX

The device features an infrared interface which is used to read the data from ABB energy meters

The measured data can be intermediately stored, evaluated and visualized from here

The information and data which is read can be used for example for billing purposes, energy optimisation, visualisation or monitoring of installations




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Energy measurement

The recording of energy variables and values, as well as their processing, is continually gaining in significance

This is not just due to the rising energy costs but also due to the frequently demanded evaluation and reading possibilities via a decentralized reading station

The features of the ABB EQmatic series help to meet these requirements and can provide operators and users with convenient, cost-effective solutions for modern energy management

ABB offers a wide range of devices and solutions specially designed for these applications




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

ABB EQmatic

ABB EQmatic series devices are compact modular installation devices designed to monitor and display consumption and measured values

They log and store consumption data for electricity, gas, water or heat meters

This means that they can help those operating purpose-built premises or commercial buildings (offices, hotels, schools, public buildings) to implement energy management systems such as ISO 50001 or to put in place low-voltage installations compliant with VDE 0100-801

As a result, they make building energy flows and costs transparent




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device technology

ABB EQmatic Energy Analyzer QA/S collects data from

- ABB i-bus® KNX meters and sensors
- M-Bus meters
- Modbus RTU meters

The collected data can be

- Saved locally in the device database
- Sent as reports via E-Mail
- Uploaded via FTP
- Shared with other systems via Modbus TCP (IP) e.g. Building Automation Controller BAC/S (PLC Controller AC500 with integrated KNX interface), ABB Cylon®, ...

Note: Some functions in QA/S require the latest software version




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device technology

ABB EQmatic Energy Analyzer are compact, web-based standalone devices for energy management applications

They log, store, display and analyze consumption data for up to 16 or 64 electricity, gas, water or heat meters

Device access is via web browser (integrated web server)

They automatically detect ABB A and B Series Energy Meters and M2M Modbus Network Analyzer during commissioning

Other meters (water, gas,...) or pulse adapters must be manually configured and added to the system




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device technology




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device technology – Data sharing via Modbus TCP and REST API




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device technology – Data sharing via Modbus TCP to KNX




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

A, B and C Series ABB Energy Meters

The ABB EQ Energy Meters are designed as intermediate meters and offer a wide range of functions for countless applications

The meters are available in various variants:

Meters for single- or three-phase measurement, as well as meters for direct connection or transformer rated

The energy meters are optionally available with integral serial interfaces for M-Bus or Modbus RTU (RS485)

The ABB A and B Series Energy Meters and M2M Modbus Network Analyzer are automatically detected and configured during commissioning

Third-party meters (energy, water, heat or gas) are to be parameterized during commissioning




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Connection of a meter to the M-Bus

- Meter with built-in M-Bus interface
 - ABB EQ Energy Meters (A and B Series) are optionally available with integral serial interfaces for M-Bus or Modbus RTU (RS485) and detected and configured automatically
 - Third-party meters are to be parameterized during commissioning
- Meter with pulse output
 - Pulse adapter for M-Bus
- Meter for connecting a pulse output module
 - Pulse adapter for M-Bus
- Meter for connecting a bus module
 - M-Bus module




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

M-Bus module for a meter

- The M-Bus module is used for adaptation of meters to the M-Bus system, e.g. water meter
- When connected to the M-Bus network the module is energized
- A built-in battery ensures that metering despite sustained failure of the M-Bus network; the resulting is stored in non-volatile Flash info of the processor
- Manufacturer: NZR (Germany)
<https://www.nzr.de/en/home.html>



M-Bus



ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

M-Bus module for a meter




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Pulse module for a meter and pulse adapter for M-Bus

Pulse output module

- The pulse output module generates pulses (e.g. 1 pulse per 10 liter) similar to those generated by reed relays (dry contact)

- Manufacturer: Itron

<https://www.itron.com/emea/solutions/product-catalog/cyble-sensor>

M-Bus pulse adapter

- The pulse adapter allows the use of a meter or module with pulse output as a M-Bus slave
- So for example, data from a simple gas, water or energy meter can central be read out by M-Bus

- Manufacturer: Relay

<https://www.relay.de/en/>



pulses ↓ 






ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Pulse output module for a meter




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Pulse adapter for M-Bus




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview


Device technology – software

- Display and evaluation of historical consumption and measured data via configurable charts
- Cost and consumption analysis for media such as electricity, water, heat and gas
- Display of CO₂ emission and Energy Performance Indicator (EnPI)
- Storage of metering data from up to 16/64 meters for at least 3 years
- Data export (file, e-Mail, FTP, Modbus TCP)
- User addition and administration functions (simultaneous access for up to 10 users)
- Notifications when connected meters fail
- Alarms
- Load control (only for KNX)
- Environmental sensor data (only for KNX)



QA/S 1.16.1




QA/S 3.xx.1




QA/S 4.xx.1


ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview


Device technology – hardware

- Energy Analyzer QA/S 1.16.1 KNX
 - QA/S 1.16.1 max. 16 meters
- Energy Analyzer QA/S 3.xx.1 M-Bus
 - M-Bus master to DIN EN 13757-2
 - QA/S 3.16.1 max. 16 meters
 - QA/S 3.64.1 max. 64 meters
- Energy Analyzer QA/S 4.xx.1 Modbus
 - Modbus RTU master
 - QA/S 4.16.1 max. 16 meters
 - QA/S 4.64.1 max. 64 meters
- Modular installation device (MDRC)
- Mounting width: 4 space units
- Display elements (LEDs)
- LAN connection
- Supply voltage 100...240 V AC



QA/S 1.16.1




QA/S 3.xx.1




QA/S 4.xx.1


ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

User interface: Main menu

The device has a user interface for commissioning and operating purposes

To access the user interface there must be an IP connection to the device

The user interface offers

- A configurable dashboard
- Graphical analysis functions (historical data, benchmark - time interval, instantaneous values, ...)
- Management
- System settings
- Load control (only for KNX)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Dashboard

The dashboard provides a rapid overview of costs and consumers in the building

In the dashboard you can configure user-defined views using widgets (graphical display elements) and alarms (e.g. measured value is exceeded)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Historical Data

For analysis and display of historical measured data




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Usage

For analysis and display of

- Cost
 - Consumption
 - Generation
 - Income
 - ...
- per medium or consumer group
- Lighting
 - Cooling
 - Ventilation
 - ...




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Instantaneous Values

This function displays the instantaneous value of a single data point in real time

The desired metering point or meter must first be selected in the metering structure

Depending on the meter's scope of functions, various data points are available for display




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Benchmark Period

To compare a consumer or node referred to two time intervals (e.g. current month and previous month)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Benchmark Consumer

To compare up to five consumers or nodes referred to a time interval




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Reports

This function automatically sends analyzes and evaluations to different recipients

The data can either be sent by email or to an FTP server

Example: Send saved consumption figures or costs for a meter once a month to a recipient by email in the file format .xlsx for further evaluation and archiving

Reports configured are displayed and managed in an overview table

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System'. The date is '2018-09-05 12:21'. The 'Reports' menu item is highlighted with a red box. Below the navigation bar, there are tabs for 'Historical Data', 'Usage Split', 'Instantaneous Values', 'Benchmark - Period', 'Benchmark - Consumer', and 'Reports'. The 'Reports' tab is active, showing a 'Configuration' section with a 'Report recipients' sub-section. A search bar and a '+ Add' button are visible. Below this is a table with the following data:

RECIPIENTS	TYPE	STATUS	NEXT REPORT ON	PERIOD	RESOLUTION	MEDIUM	FORMAT	ACTION
Daily load profile: Main building								
192.168.1.12	FTP	OK	2018-09-06	a day	5 minutes	Electricity	XLSX	X
juergen.schilder@de.abb.com	EMAIL	OK	2018-09-06	a day	5 minutes	Electricity	XLSX	X

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Analytics – Alarms

Alarm ranges can be configured for any data point via the analysis function or dashboard

If a configurable value is exceeded, notification is sent to e-mail recipients and event is written to the alarm log

The screenshot displays the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Load control', 'Management', and 'System'. The 'Alarms' tab is highlighted in the secondary navigation bar. The main content area shows the 'Alarms' section with a search bar and a table of active alarms.

<input type="checkbox"/>	NAME	VALUE TYPE	NODE	STATE	UI NOTIFICATIONS	E-MAIL NOTIFICATIONS	ACTION
<input type="checkbox"/>	Power Blower room 3-001	Active Imported Power Total	Energy Actuator 1: SE/S	Active	Disabled	Disabled	
<input type="checkbox"/>	Voltage low	Voltage L1	Meter Interface 1: B21-113-100	Active	Enabled	Disabled	

An inset window shows a gauge for 'Active Imported Power' with a value of 105.622 W, ranging from 42W to 83W. Below the gauge is a detailed alarm log for the 'Voltage low' event:

- Category: Error
- Severity: High
- Name: Voltage low
- Value: 233.20 [V]
- Node: Meter Interface 1: B21-113-100
- Data point: Voltage L1
- Date: 14/01/2020 17:11:46

Below this, another alarm event is listed:

- Category: Note
- Severity: High
- Name: Power Blower room 3-001
- Value: 38.86 [W]
- Node: Energy Actuator 1: SE/S
- Data point: Active Imported Power Total
- Date: 14/01/2020 17:11:45

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Load control (only for QA/S 1.16.1 KNX)

With the Load Control Management function, load shedding sequences can be prioritized based on the electrical power values received from electricity meters

The load control parameter must be activated in the ETS so that the load control can be displayed and operated via the user interface




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: Management

The *Management* menu can be used to make settings (Administrator rights are required)

- Meter Management
- Metering Structure
- User Management
- Tariff and Units
- Consumer Groups
- Data Sharing




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Main menu: System Settings

Basic settings are made in the *System* menu
(Administrator rights are required)

- General
- Date and Time
- Network
- Update
- SMTP Configuration
- SSL Certificate
- SSH Access
- Erase data
- System Log
- System diagnostics




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

ABB i-bus® KNX

KNX is an open standard (see EN 50090, ISO/IEC 14543) for commercial and domestic building automation administered by the KNX Association cvba, a non-profit organisation

KNX devices can manage lighting, blinds and shutters, HVAC, security systems, energy management, audio video, white goods, displays, remote control, etc.

KNX can use an use several physical communication media: twisted pair, powerline, RF (KNX-RF) and IP (KNXnet/IP)

On this network, the devices form distributed applications and tight interaction is possible

The KNX Association had 478 registered hardware and software vendor members from 44 nations

Source: WIKIPEDIA




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

M-Bus

M-Bus (Meter-Bus) is a technical standard (EN 13757-2), applying its rules, e.g. in electricity meters, allows the electricity consumption to be transmitted as measured data

The gas, heat or water consumption can also be measured and transmitted by meters with M-Bus

The special feature here is remote reading, which involves additional connected devices transmitting their collected data over the Internet or the mobile telecommunications network. This can eliminate the need for humans to read the meters

Source: WIKIPEDIA




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Modbus RTU (RS485)

Modbus is a serial communications protocol originally published by Modicon in 1979 for use with its programmable logic controllers (PLCs)

Modbus has become a de facto standard communication protocol and is now a commonly available means of connecting industrial electronic devices

The main reasons for the use of Modbus in the industrial environment are:

- Developed with industrial applications in mind
- Openly published and royalty-free
- Easy to deploy and maintain

Source: WIKIPEDIA




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Device overview

	QA/S 1.16.1	QA/S 3.16.1	QA/S 3.64.1	QA/S 4.16.1	QA/S 4.64.1
Protocol	KNX	M-Bus		Modbus RTU	
Max. devices	16	16	64	16	64
Design	Modular installation device (MDRC)				
Order code	2CDG 110 224 R0011	2CDG 110 226 R0011	2CDG 110 227 R0011	2CDG 110 228 R0011	2CDG 110 229 R0011
List price	559.- €	599.- €	959.- €	599.- €	959.- €

All devices have the same settings and menus (dashboard, historical data, ...)
→ Only the commissioning step for scanning the connected meters (KNX, M-Bus or Modbus) is different
→ The KNX Energy Analyzer QA/S 1.16.1 offers additional features via KNX (e.g. load control)

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Technical documents

www.abb.com/KNX

→ Products and Downloads

→ Energy Management

→ QA/S x.yy.1 Energy Analyzer

- Product Manual
- Technical datasheet
- Installation and operating instructions
- Specification text
- Product information
- Presentation slides
- CE declaration of conformity
- ...

Detailed information for: QA/S3.16.1


This page contains technical data sheet, documents library and links to offering related to this product. If you require any other information, please contact us using form located at the bottom of the page. [Print...](#) [Print to Pdf...](#)

[Data Sheet](#) [Documentation](#)

QA/S3.16.1

General Information

Extended Product Type:	QA/S3.16.1
Product ID:	2CDG110226R0011
EAN:	4016779997751
Catalog Description:	QA/S3.16.1 Energy Analyzer, M-Bus
Long Description:	Energy management solution for capturing and analyzing consumption data of up to 16 electricity, gas, water or heat meters via M-Bus. Web-based user interface with graphical analysis functions such as historical data, dashboard, and more.



Downloads

You now see 10 files

- Show all (10) >
- Advertisement (1)
- CAD outline drawing (2)
- Certificate (1)
- Connection diagram (1)
- Course literature (1)




	Product Manual (.pdf) [EN] QA/S 3.xx.1 Summary: No summary available Manual - English - 2017-08-30 - 2,71 MB	↓ PDF
	Specification Text (.pdf) [EN] QA/S 3.16.1 Summary: No summary available Tender specification - English - 2017-08-28 - 0,11 MB	↓ PDF
	Technical Data (.pdf) [EN] QA/S 3.xx.1 Summary: No summary available Data sheet - English - 2017-08-28 - 0,15 MB	↓ PDF

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Training

Webinar recordings and slides

- “ABB EQmatic Energy Analyzer QA/S KNX” (January 2020)
[Link→PDF](#) and [Link→MP4](#)
- “ABB EQmatic Energy Analyzer QA/S M-Bus and Modbus” (September 2018) [Link→PDF](#) and [Link→MP4](#)
- Webinar “ABB EQmatic Energy Analyzer QA/S 3.x.1” (October 2017)
[Link→PDF](#) and [Link→MP4](#)

More documents are available on the Training & Qualification Database for ABB Home and Building Automation

<https://go.abb/ba-training>

ABB EQmatic Energy Analyzer QA/S x.yy.1
KNX, M-Bus and Modbus
Jürgen Schilder Competence Center Europe – Smart Buildings

ABB i-bus® KNX Switch Actuators – Energy Functions in Detail
Energy Analyzer QA/S 1.16.1 KNX and KNX Meters

Example: Energy Analyzer QA/S 1.16.1 KNX and Energy Actuator SE/S 3.16.1 – Assignment of Group Addresses

Meter x: SE/S – A: Meter reading	System – In operation
Meter x: SE/S – B: Meter reading	General – Request status values
Meter x: SE/S – Request status values	General – Request meter readings
Meter x: SE/S – Measurement circuit active	Diagnostics – Measurement circuit active
Meter x: SE/S – Meter reading	Meter total – Meter reading
Meter x: SE/S – Active power	Active power total – Active power
Meter x: SE/S – Frequency	Frequency – Frequency
Meter x: SE/S – A: Meter reading	A: Meter – Meter reading
Meter x: SE/S – A: Active power	A: Active power – Active power
Meter x: SE/S – A: Current	A: Current – Current value
Meter x: SE/S – A: Voltage	A: Voltage – Voltage
Meter x: SE/S – A: Apparent power	A: Apparent power – Apparent power
Meter x: SE/S – A: Power factor	A: Power factor – Power factor
Meter x: SE/S – B: Meter reading	B: Meter – Meter reading
Meter x: SE/S – B: Active power	B: Active power – Active power
Meter x: SE/S – B: Current	B: Current – Current value
Meter x: SE/S – B: Voltage	B: Voltage – Voltage
Meter x: SE/S – B: Apparent power	B: Apparent power – Apparent power
Meter x: SE/S – ...	B: ...

ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Training

Webinar recordings and slides

- “ABB EQmatic Energy Analyzer QA/S – Commissioning of third-party meters” (February 2021)
[Link→PDF](#) and [Link→MP4](#)
- “ABB EQmatic Energy Analyzer QA/S 1.16.1 KNX – Commissioning of ABB KNX meters” (February 2021)
[Link→PDF](#) and [Link→MP4](#)
- KNX Switch Actuators – Energy Functions in Detail (Nov. 2020)
[Link→PDF](#) and [Link→MP4](#)
- KNX Switch Actuators – Energy Functions (Nov. 2020)
[Link→PDF](#) and [Link→MP4](#)
- ...





ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Training “Energy Analyzer QA/S”

- Virtual Classroom Training
 - The dates will be announced later
 - ABB internal training
 - Worldwide access to the training equipment via ABB IP network
- Initial commissioning of an Energy Analyzer QA/S
- Provide measured values for Modbus TCP
- Various practical exercises on the training boards (access via ABB IP network)
 - Commissioning of an Energy Analyzer QA/S
 - Create the metering structure of a building
 - Configure the dashboard
 - ...




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Training

Training boards

- Board with Energy Analyzer M-Bus and two Energy Meters
- Manufacturer Lucas-Nuelle/Kerpen
- LN-Code: CO3210-ABB08
- Available boards:
 - 9x RCC Europe (Heidelberg)
 - 5x RCC IMA (Dubai)
 - 6x RCC Asia (Singapore)
- RCC Europe: Remote access via the ABB network possible
- Boards are also available on request with Modbus or KNX Energy Analyzer QA/S and country specific socket outlets (e.g. Switzerland)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Overview

Training

Training boards

- Board with Energy Analyzer QA/S KNX, Energy Actuator SE/S, Switch Actuator with Energy Functions SA/S and Meter Interface ZS/S with Energy Meter B21
- Manufacturer Lucas-Nuelle/Kerpen
- LN-Code: CO3210-ABB25




ABB EQmatic Energy Analyzer QA/S x.yy.1

Conclusion

Compact energy monitoring solution

This allows the customer to assign and monitor sub-metering data via web-based devices to improve energy efficiency and to lower costs



Energy and cost allocation



Reduce costs



Compliance with local provisions (e.g. ISO 50001, RT 2012)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

The Energy Analyzer QA/S 1.xx.1 records meter data via

A Modbus

B M-Bus

C KNX

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

The Energy Analyzer QA/S 1.xx.1 records meter data via

A Modbus

B M-Bus

C KNX

ABB EQmatic collects data from KNX meters and saves them locally in the device database

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

The Energy Analyzer QA/S 3.xx.1 records meter data via

- A Modbus
- B M-Bus
- C S0 pulse outputs

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

The Energy Analyzer QA/S 3.xx.1 records meter data via

- A Modbus
- B M-Bus
- C S0 pulse outputs

ABB EQmatic collects data from M-Bus meters and saves them locally in the device database

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

The Energy Analyzer QA/S 4.xx.1 records meter data via

A Modbus

B M-Bus

C KNX

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

The Energy Analyzer QA/S 4.xx.1 records meter data via

A Modbus

B M-Bus

C KNX

ABB EQmatic collects data from Modbus meters and saves them locally in the device database

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

Which types of consumption data can be recorded?

- A** Any media such as electricity, gas, water or heat
- B** Only Gas and water
- C** Only electricity

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

Which types of consumption data can be recorded?

- A** Any media such as electricity, gas, water or heat
- B** Only Gas and water
- C** Only electricity

Consumption data of electricity, gas, water or heat

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer(s) is correct?

Question 5

The consumption data are ...

- A** ... recorded and forwarded to a higher management level (via Modbus TCP)
- B** ... saved, evaluated and displayed with a web browser
- C** ... recorded and sent on the KNX bus via an integrated interface

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer(s) is correct?

Question 5

The consumption data are ...

- A** ... recorded and forwarded to a higher management level (via Modbus TCP)
- B** ... saved, evaluated and displayed with a web browser
- C** ... recorded and sent on the KNX bus via an integrated interface

Storing, analyzing and displaying data and sharing with other systems via Modbus TCP



Planning

ABB EQmatic Energy Analyzer QA/S x.yy.1

Planning

The appropriate standards, directives, regulations and specifications of the appropriate country should be observed when planning and setting up electrical installations

Operate the device only within the specified technical data

The Energy Analyzer is designed for use in 10/100 BaseT networks compliant to IEEE 802.3. The device features an AutoSensing function and sets the baud rate (10 or 100 Mbit) automatically.

Bus-specific requirements (e.g. max. cable length, etc.) must be observed

- Further information and documentation about M-Bus: www.m-bus.com
 - Standard EN 13757-1, “Communication systems for meters – Part 1: Data exchange”
 - Standard EN 13757-2, “Communication systems for meters – Part 2: Wired M-Bus communication”
 - Standard EN 13757-3, “Communication systems for meters – Part 3: Application protocols”
- Further information and documentation about Modbus: www.modbus.org
- Further information and documentation about KNX: www.abb.com/knx and www.knx.org

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is M-Bus?

M-Bus (Meter-Bus) is a European standard for remotely reading gas, water, heat or electricity meters

- The M-Bus interface is designed for communication over two-wire lines
- This bus satisfies the special requirements for remotely powered or battery-operated meters
- The M-Bus is based on the master-slave principle
- The meters send the collected measured values and data to a common master for further processing on request
- A unique address must be set in each meter
- Master = Level converter, e.g. QA/S 3.xx.1 Energy Analyzer
- Slave = M-Bus device/meter (e.g. ABB electricity meter from the A and B series, water meter, heat meter, gas meter, etc., with M-Bus interface)
- An M-Bus installation can consist of up to 250 addresses (meters)

The QA/S 3.xx.1 Energy Analyzer supports up to 16 or 64 meters, depending on the device type

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is M-Bus?

The M-Bus is designed for baud rates from 300 to 9,600 baud

ABB meters from the A and B series can communicate at baud rates of 2,400 to 9,600 baud

The baud rate must be set in the meter

The M-Bus interface is protected against polarity reversal, i.e. the wires of the cable used can be interchanged

The M-Bus supports different bus topologies

- The cables should be kept as short as possible
- A combination star, tree and linear structure is typically used; a ring structure is impermissible

ABB EQmatic Energy Analyzer QA/S x.yy.1


M-Bus pulse adapter

A pulse adapter is used to adapt consumption measuring devices, e.g. electricity, gas or water meters, to the M-Bus/Modbus system

The measuring devices must feature a floating pulse output or a mounted pulse module for sensing

Pulse adapters with different numbers of channels are available as rail-mounted devices and in surface mounted enclosures, etc.

Configuration (primary address, medium, unit, ...) is performed using a programming adapter and software



Meter with pulse output or pulse module for scanning

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer M-Bus QA/S 3.xx.1: Technical data [M-Bus](#)

Energy Analyzer, M-Bus master to DIN EN 13757-2

Max. number of M-Bus slaves on QA/S 3.16.1: 16

Max. number of M-Bus slaves on QA/S 3.64.1: 64

M-Bus baud rate: 300; 600; 1,200; 2,400; 4,800; 9,600

Operating voltage: Us 100...240 V AC, 50/60 Hz

Power consumption at 230 V AC < 10 W

Device leakage loss at 230 V AC < 3 W at 230 V AC

Simultaneous access to web browser for up to 10 users

Retrieval/storage of meter data every 5 minutes

IP security: HTTPS, SSL

Data export: JPG, PNG, CSV, XLSX, PDF

Data transfer: Modbus TCP

Report: FTP and e-mail

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer M-Bus QA/S 3.xx.1: Technical data [M-Bus](#)

Storage capacity with up to 64 M-Bus slaves: min. 3 years

IP network connection: Ethernet 10 / 100 Mb to IEEE 802.3

Temperature range in operation: -5 °C ... +45 °C

Environmental conditions: humidity max. 93%; dew formation must be ruled out

Design: modular installation device (MDRC) in Pro M design

Dimensions: 90 x 70 x 64 mm (H x W x D)

Mounting: On 35 mm mounting rail to DIN EN 60 715

Mounting position: Any

Display elements: LEDs to indicate operational readiness, network connection and M-Bus operational readiness

Operating element: Reset button

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is Modbus RTU?

Modbus is a serial communication protocol that was developed and published for use with programmable logic controllers (PLC)

Modbus RTU (remote terminal unit) is the most common implementation available for Modbus

It is a communication method for the transmission of information via serial cables between electronic devices

The device that requests the information is termed the Modbus master

The devices that send the information are Modbus slaves

In a standard Modbus network there is one master and up to 247 slaves each with a unique slave address from 1 to 247

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is Modbus RTU?

Bus principle RS485

- The Modbus standard uses the RS485 standard
- This standard defines the physical layer of the Modbus interface
- The data are transmitted in serial form via a 2-wire bus (RS485)
- The RS485 standard is based on the master – slave method and defines the bus cable as a cable with a start and an end that are each terminated using an EOL resistor RT (T=Termination)
- Master = level converter (e.g. QA/S 4.xx.1 Energy Analyzer)
- Slave = Modbus device/meter (e.g. ABB electricity meter from the A and B series, water meter, heat meter, gas meter, etc., with Modbus RTU interface)

Transmission speed: 300; 600; 1,200; 2,400; 4,800; 9,600; 19,200; 38,400; 57,600; 115,200 baud

Polarity: Attention must be paid to the correct polarity of the core pairs during installation because incorrect poling will invert the data signal

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is Modbus RTU?

Topology

- The optimal cable topology for the Modbus RTU is a purely linear structure
- Droplines to individual devices with a maximum length of 1 m are allowed
- These droplines are not terminated

Cable types

- A twisted pair, screened cable is recommended as the bus cable
- The cable type J-Y(St)Y n x 2 x 0.8mm is suitable, for instance
- The screen is to be connected to PE at one end
- The bus cable must be terminated with resistors (120 Ω , 0.25 W) at both ends so that only minimal reflections are produced
- The serial communication on the RS485 interface operates most efficiently if the source and load impedance are matched at 120 Ohm
- The EOL resistors are connected in parallel with terminals A and B and are included in the scope of delivery

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is Modbus RTU?




ABB EQmatic Energy Analyzer QA/S x.yy.1

What is Modbus RTU?

Cable length

- The RS485 specification limits the cable length to 1,200 m, the number of devices in the bus to 32 and stipulates a linear topology (daisy chain)

Number of devices

- The number of Modbus devices depends on the unit load (UL) of the RS485 transceivers
- In the worst case a transceiver has 1 UL
- An RS485 segment is specified for 32 UL
- If more devices are to be connected, a repeater must be used
- Modern RS485 transceivers have 1/4 or 1/8 UL

If only such devices are used, 128 or 256 users are possible without repeaters

Note

- The ABB A and B Series Energy Meters have a unit load of 1/8 UL
- Therefore 64 ABB meters can be connected to the QA/S 4.64.1 Energy Analyzer without repeaters

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer Modbus RTU QA/S 4.xx.1: Technical data

Energy Analyzer, Modbus-Bus master

Max. number of Modbus RTU slaves on QA/S 4.16.1: 16

Max. number of Modbus RTU slaves on QA/S 4.64.1: 64

Modbus baud rate: 1,200; 2,400; 4,800; 9,600; 19,200; 38,400; 57,600; 115,200

Operating voltage: Us 100...240 V AC, 50/60 Hz

Power consumption at 230 V AC < 10 W

Device leakage loss at 230 V AC < 3 W at 230 V AC

Simultaneous access to web browser for up to 10 users

Retrieval/storage of meter data every 5 minutes

IP security: HTTPS, SSL

Data export: JPG, PNG, CSV, XLSX, PDF

Data transfer: Modbus TCP

Report: FTP and e-mail

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer Modbus RTU QA/S 4.xx.1: Technical data

Storage capacity with up to 64 Modbus RTU slaves: min. 3 years

IP network connection: Ethernet 10 / 100 Mb to IEEE 802.3

Temperature range in operation: -5 °C ... +45 °C

Environmental conditions: humidity max. 93%; dew formation must be ruled out

Design: modular installation device (MDRC) in Pro M design

Dimensions: 90 x 70 x 64 mm (H x W x D)

Mounting: On 35 mm mounting rail to DIN EN 60 715

Mounting position: Any

Display elements: LEDs to indicate operational readiness, network connection and Modbus RTU operational readiness

Operating element: Reset button

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is KNX?

KNX is the synonym for smart home and intelligent building control

In this innovative system, all devices communicate with one another via a single bus cable which is installed alongside the normal power lines

This means that all electrical functions are connected with one another via the bus system, both in residential and commercial buildings

With the KNX system, the buildings we occupy are easier to manage and control, resulting in increased flexibility, security, economic efficiency and convenience

The operational flexibility of an KNX electrical installation allows the everyday working or living environment to be easily adapted to the individual's needs - now and in the future

Utilizing KNX means cost advantages throughout the entire lifetime: From planning and implementation, through the building phase, sale or rental, right up to operation and administration

This ensures that the building will be up-to-date and profitable in the long-term thus ensuring a short amortization period

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is KNX?

Main Advantages

- International Standard, therefore future proof (EN13321-1/2, ISO/IEC14543-3, in US ANSI/ASHRAE standard 135, SAC GB/T 20965,...)
- By product certification, KNX guarantees Interoperability & Interworking of products
- KNX stands for high product quality (ISO 9001)
- A unique manufacturer independent Engineering Tool Software ETS®
- KNX can be used for all applications in home and building control
- KNX is fit for use in different kind of buildings: New or existing buildings, one family houses or large size buildings
- KNX supports several communication media (TP, PL, RF and IP)
- KNX can be coupled to other systems (BACnet, DALI, DMX, RS485, M-BUS, ...)
- KNX is independent from any hard- or software technology

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is KNX?

Application Areas

- Lighting control and regulation
- Heating, ventilation, cooling
- Blinds and shutter control
- Security and monitoring
- Energy and load management
- Visualisation and operation
- Central automatic
- Remote control / maintenance
- Interface to other control systems
- ...

ABB EQmatic Energy Analyzer QA/S x.yy.1

What is KNX?

The KNX structure created is very flexible in its design due to the possible connection of the devices: linear, tree and star wiring configurations are allowed

The topological configuration includes lines and areas

A line is the smallest unit

- Up to 64 devices can be connected to a line
- At most 15 lines can be combined via line couplers to one area
- A bus system can be extended up to 15 areas (app. 15,000 devices and max. 57,000)

Transmission speed: 9,600 bit/s

Bus access method: CSMA/CA

“Programming” by the Engineering Tool Software ETS

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer KNX QA/S 1.16.1: Technical data

KNX device certified according to EN 50491

Max. number of KNX meters: 16

Maximum number of group objects: 1,630

Maximum number of group addresses: 2,000

KNX Bus voltage 21...32 V DC

KNX current consumption, bus < 12 mA

Operating voltage: Us 100...240 V AC, 50/60 Hz

Power consumption at 230 V AC < 10 W

Device leakage loss at 230 V AC < 3 W at 230 V AC

Simultaneous access to web browser for up to 10 users

Retrieval/storage of meter data every 5 minutes

IP security: HTTPS, SSL

ABB EQmatic Energy Analyzer QA/S x.yy.1

Energy Analyzer KNX QA/S 1.16.1: Technical data

Data export: JPG, PNG, CSV, XLSX, PDF

Data transfer: Modbus TCP

Report: FTP and e-mail

Storage capacity with up to 16 KNX devices: min. 3 years

IP network connection: Ethernet 10 / 100 Mb to IEEE 802.3

Temperature range in operation: -5 °C ... +45 °C

Environmental conditions: humidity max. 93%; dew formation must be ruled out

Design: modular installation device (MDRC) in Pro M design

Dimensions: 90 x 70 x 64 mm (H x W x D)

Mounting: On 35 mm mounting rail to DIN EN 60 715

Mounting position: Any

Display elements: LEDs to indicate operational readiness, network connection and KNX bus operational readiness

Operating element: Reset button

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

What supply voltage does a Energy Analyzer QA/S require?

A 12...240 V AC/DC

B 12...24 V DC

C 100...240 V AC

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

What supply voltage does a Energy Analyzer QA/S require?

A 12...240 V AC/DC

B 12...24 V DC

C 100...240 V AC

Operating voltage: U_s 100...240 V AC

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

What are the connections on the Energy Analyzer QA/S 1.16.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

What are the connections on the Energy Analyzer QA/S 1.16.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

Supply voltage – KNX – IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

What are the connections on the Energy Analyzer QA/S 3.xx.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

What are the connections on the Energy Analyzer QA/S 3.xx.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

Supply voltage – M-Bus – IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

What are the connections on the Energy Analyzer QA/S 4.xx.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

What are the connections on the Energy Analyzer QA/S 4.xx.1?

- A** Supply voltage, Modbus RTU and IP network
- B** Supply voltage, M-Bus and IP network
- C** KNX bus connection, supply voltage and IP network

Supply voltage – Modbus RTU – IP network

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 5

What functions do all Energy Analyzer QA/S offer?

- A**
 - Cost/consumption analysis for media such as electricity and water
 - Networking several Energy Analyzer QA/S devices via IP network
 - CO₂ emissions display
- B**
 - Data export to xls, csv, pdf, etc.
 - Addition of Favorites
 - Load management by avoiding load peaks
- C**
 - Storage of metering data from up to 64 meters for at least 3 years
 - Display and evaluation of historical consumption/measured data
 - Customizable dashboard with predefined widgets

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 5

What functions do all Energy Analyzer QA/S offer?

- A**
 - Cost/consumption analysis for media such as electricity and water
 - Networking several Energy Analyzer QA/S devices via IP network
 - CO₂ emissions display
- B**
 - Data export to xls, csv, pdf, etc.
 - Addition of Favorites
 - Load management by avoiding load peaks
- C**
 - Storage of metering data from up to 64 meters for at least 3 years
 - Display and evaluation of historical consumption/measured data
 - Customizable dashboard with predefined widgets

Storing metering data – historical consumption/measured data – configurable dashboard



Installing

ABB EQmatic Energy Analyzer QA/S x.yy.1

Installation

Attention! Hazardous voltage! Mounting and commissioning may be carried out only by electrical specialists

The appropriate standards, directives, regulations and specifications of the appropriate country should be observed when setting up electrical installations

Operate the device only within the specified technical data

The device must be operated only in an enclosed housing (distribution board)

Refer to the product manual or the installation and operating instructions for a detailed description of installation and commissioning





ABB EQmatic Energy Analyzer QA/S x.yy.1

Mounting and installation

The device is a modular installation device for quick installation in distribution boards on 35 mm mounting rails to DIN EN 60 715


The installation position can be selected as required

Electrical connection and M-Bus/Modbus connection are performed via screw terminals

The connection to the ABB i-bus® KNX is established via the supplied bus connection terminal (QA/S 1.16.1 KNX)

The device is ready for operation once the operating voltage is on and the initialization process has finished (green LED lights up continuously)

The device must be accessible for operation, testing, visual inspection, maintenance and repair in compliance with DIN VDE 0100-520



QA/S 3.xx.1



QA/S 4.xx.1



QA/S 1.16.1



ABB EQmatic Energy Analyzer QA/S x.yy.1

Scope of delivery

Energy Analyzer QA/S x.yy.1 with label carrier

Installation and operating instructions

Lettering inlay for label carrier

IP address assignment is set to automatic addressing (DHCP/AutoIP)

Language: Dependent on the language setting in the browser used

Currency: EUR

QA/S 4.xx.1 Modbus

– Two EOL resistors 120 Ohm

QA/S 1.16.1 KNX

– KNX physical address 15.15.255

– Bus connection terminal (red/black)

– KNX connection cover cap



Montage- und Betriebsanleitung
Installation and Operating Instructions
Mode d'emploi
Instrucciones de montaje de servicio
Istruzioni per l'uso
Montage- en bedieningshandleiding
Instrukcja montażu i eksploatacji
Руководство по монтажу и эксплуатации
安裝和操作手冊

QA/S 3.16.1

QA/S 3.64.1

- DE** Energie Analyzer, M-Bus
- EN** Energy Analyzer, M-Bus
- FR** Energy Analyzer, M-Bus
- ES** Medidor de Energía, M-Bus
- IT** Energy Analyzer, M-Bus
- NL** Energy Analyzer, M-Bus
- PL** Analizator Energii, M-Bus
- RU** Интерфейс, M-Bus
- CN** 能源信息管理器, M-Bus

2CDG941193P0001

ABB



ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 1.16.1 KNX: Connection diagram

1	Label carrier
2	KNX programming LED (red)
3	KNX programming button
4	KNX connection
5	Cover cap
6	Us supply voltage connection
7	Ethernet/LAN connection
8	ON LED (green)
9	LAN/LINK LED (yellow)
10	KNX telegram LED (yellow)
11	Reset button (behind label carrier)




ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Connection diagram

1	Power supply connection U_s
2	M-Bus slave/meter connection
3	Ethernet/LAN connection
4	ON LED (green)
5	LAN/LINK LED (yellow)
6	M-Bus LED (yellow)
7	Reset button (behind label carrier)
8	Label carrier




ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 4.xx.1 Modbus: Connection diagram

1	Power supply connection U_s
2	Modbus slaves/meter connection (RS485)
3	Ethernet/LAN connection
4	ON LED (green)
5	LAN/LINK LED (yellow)
6	Modbus RTU LED (yellow)
7	Reset button (behind label carrier)
8	Label carrier

- The bus cable must be terminated with resistors (120Ω , 0.25 W) at both ends
- A third conductor must interconnect all the devices of the bus (terminal "C" – common)







ABB EQmatic Energy Analyzer QA/S x.yy.1

Display elements

LED	Function	Description
 ON	ON	Operating system initialization process complete. Supply voltage on. The device is ready for operation.
	OFF	No supply voltage during operating system initialization process.
	Flashing (1 Hz)	During initialization.
	FLASHING (3 Hz)	Resetting network settings and restarting the device
 LAN/Link	OFF	No supply voltage. No network connection.
	FLASHING	Network connection OK. Telegram traffic.
 M-Bus/Modbus	ON	Supply voltage OK, device ready for operation and M-Bus/Modbus/KNX connected.
	OFF	No supply voltage. M-Bus/Modbus/KNX not connected.
	FLASHING (1 Hz)	Scanning process for slaves/devices.
	FLASHING (3 Hz)	Resetting network settings and restarting the device.
	FLASHING (10 Hz)	Resetting to factory settings.




ABB EQmatic Energy Analyzer QA/S x.yy.1

Installation steps

No tools needed!

Fastening on a mounting rail

- Place the DIN rail holder on the upper edge of the DIN rail and push down.
- Push the lower part of the device toward the DIN rail until the DIN rail holder engages.
- The device is now mounted on the DIN rail.

Removing from the mounting rail

- Press on the top of the device
- Release the bottom of the device from the DIN rail
- Lift the device up and off the DIN rail




ABB EQmatic Energy Analyzer QA/S x.yy.1

Installation steps

In order to avoid dangerous touch voltages, which originate through feedback from differing phase conductors, all-pole disconnection must be observed when extending or modifying the electrical connections

- Fastening device on mounting rail
- Connecting the lines for
 - Supply voltage
 - M-Bus, Modbus or KNX (meters/slaves)
 - Ethernet/LAN



QA/S 3.xx.1



QA/S 4.xx.1



QA/S 1.16.1



ABB EQmatic Energy Analyzer QA/S x.yy.1

Installation steps

Connecting the supply voltage

The operating system starts, and the yellow M-Bus/Modbus/KNX LED lights up

When the operating system has finished loading, the yellow M-Bus/Modbus/KNX LED goes off and the green ON LED starts to flash while the application is loading

When the application has finished loading, the green ON LED stops flashing and lights up continuously with the yellow M-Bus/Modbus/KNX LED

The initialization process is complete

The device is ready for operation and can be put into operation with a web browser




ABB EQmatic Energy Analyzer QA/S x.yy.1

Resetting the device

There are several ways to reset the device:

- Restarting (device reset only)
- Restarting and resetting the network settings
- Resetting to factory settings (deleting configuration and all data)

To reset the device, use the Reset button, which is behind the label carrier

- Open the label carrier cover
- Press the “Reset” button to perform a reset

Press for	Action	LED
< 2 sec.	No reaction	ON LED (green): ON M-Bus/Modbus/KNX LED (yellow): ON
> 2 s and < 10 sec.	1. Restart Pressing and releasing the Reset button restarts the device	ON LED (green): Flashing (3 Hz) M-Bus/Modbus/KNX LED (yellow): ON
> 10 < 20 sec.	2. Restart and reset the network settings Pressing and releasing the Reset button resets the IP address to automatic address assignment (DHCP) and restarts the device	ON LED (green): Flashing (3 Hz) M-Bus/Modbus/KNX LED (yellow): Flashing (3 Hz)
> 20 sec.	3. Restart and reset to factory settings. Pressing and releasing the Reset button deletes all user-defined settings, network settings and database entries	ON LED (green): Flashing (10 Hz) M-Bus/Modbus/KNX LED (yellow): Flashing (10 Hz)

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

The Energy Analyzer QA/S is suitable for installation

- A** on a 35 mm mounting rail in any installation position in distribution boards or small housings
- B** outdoors and indoors
- C** only in horizontal position in distribution boards or small housings

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

The Energy Analyzer QA/S is suitable for installation

- A** on a 35 mm mounting rail in any installation position in distribution boards or small housings
- B** outdoors and indoors
- C** only in horizontal position in distribution boards or small housings

Installation in distribution boards in any installation position

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

How can operational readiness be checked?

- A** Press the “Manual operation” button for longer than 2 seconds. The green ON LED flashes green (1 Hz).
- B** The yellow M-Bus/Modbus/KNX LED flashes yellow (3 Hz) and waits for metering data.
- C** The green ON LED lights up permanently after the initialization process.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

How can operational readiness be checked?

- A** Press the “Manual operation” button for longer than 2 seconds. The green ON LED flashes green (1 Hz).
- B** The yellow M-Bus/Modbus/KNX LED flashes yellow (3 Hz) and waits for metering data.
- C** The green ON LED lights up permanently after the initialization process.

The green ON LED lights up permanently

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

How is the Energy Analyzer QA/S 1.16.1 connected with the KNX meters?

- A** All KNX meters are connected with the Energy Analyzer QA/S 1.16.1 only in a line structure and the bus cable must be terminated with EOL resistors (120 Ω) at both ends.
- B** The Energy Analyzer QA/S 1.16.1 permits wireless connection in accordance with the wireless KNX RF standards.
- C** All KNX meters are connected with the Energy Analyzer QA/S 1.16.1 in any structure (star, tree, line, ...) according to KNX standards

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

How is the Energy Analyzer QA/S 1.16.1 connected with the KNX meters?

- A** All KNX meters are connected with the Energy Analyzer QA/S 1.16.1 only in a line structure and the bus cable must be terminated with EOL resistors (120 Ω) at both ends.
- B** The Energy Analyzer QA/S 1.16.1 permits wireless connection in accordance with the wireless KNX RF standards.
- C** All KNX meters are connected with the Energy Analyzer QA/S 1.16.1 in any structure (star, tree, line, ...) according to KNX standards

Two-wire TP line in star, tree or line topology

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

How is the Energy Analyzer QA/S 3.xx.1 connected with the M-Bus meters (slaves)?

- A** All M-Bus meters (slaves) are connected with the Energy Analyzer QA/S 3.xx.1 via a two-wire line.
- B** The KNX interface integrated into the Energy Interface supports the connection of M-Bus meters as well.
- C** The Energy Analyzer QA/S 3.xx.1 permits wireless connection in accordance with the wireless M-Bus standard (EN 13757-4).

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 4

How is the Energy Analyzer QA/S 3.xx.1 connected with the M-Bus meters (slaves)?

- A** All M-Bus meters (slaves) are connected with the Energy Analyzer QA/S 3.xx.1 via a two-wire line.
- B** The KNX interface integrated into the Energy Interface supports the connection of M-Bus meters as well.
- C** The Energy Analyzer QA/S 3.xx.1 permits wireless connection in accordance with the wireless M-Bus standard (EN 13757-4).

Two-wire line in star, tree or line topology

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 5

How is the Energy Analyzer QA/S 4.xx.1 connected with the Modbus RTU meters?

- A** The Energy Analyzer QA/S 4.xx.1 permits wireless connection in accordance with the wireless Modbus standard.
- B** All Modbus meters are connected with the Energy Analyzer QA/S 4.xx.1 in a line structure and the bus cable must be terminated with EOL resistors (120 Ω) at both ends.
- C** All Modbus meters are connected with the Energy Analyzer QA/S 4.xx.1 in any structure (star, tree, line, ...).

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 5

How is the Energy Analyzer QA/S 4.xx.1 connected with the Modbus RTU meters?

- A** The Energy Analyzer QA/S 4.xx.1 permits wireless connection in accordance with the wireless Modbus standard.
- B** All Modbus meters are connected with the Energy Analyzer QA/S 4.xx.1 in a line structure and the bus cable must be terminated with EOL resistors (120 Ω) at both ends.
- C** All Modbus meters are connected with the Energy Analyzer QA/S 4.xx.1 in any structure (star, tree, line, ...).

Line structure with EOL resistors

Commissioning

Connecting to the device and commissioning wizard

ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning requirements

PC/laptop with web browser for commissioning and operating
The QA/S is ready for operation and a LAN connection is established

The PC/laptop and the QA/S are in the same IP network

Meters are operating and connected to M-Bus/Modbus/KNX on the QA/S

The M-Bus/Modbus/KNX devices comply with the current standard

The M-Bus and Modbus devices are connected and configured according to manufacturer's instructions (e.g. speed, primary address, transformer ratios, etc.)

ETS (Engineering Tool Software) is used to parametrize the QA/S 1.16.1 KNX








ABB EQmatic Energy Analyzer QA/S x.yy.1

Example: Set the wired M-Bus interface

1. Select “SET” in the main menu and press 
2. Select “M-Bus” and press 
3. Press  once to get to the next menu “Baud”
 - The display will show the baud rate
 - Set baud rate (e.g. 9600)
4. Press  once to get to the next menu “Address”
 - The display will show the address
 - Set address (e.g. 001)





ABB EQmatic Energy Analyzer QA/S x.yy.1

Configuration of M-Bus devices

- M-Bus devices (slaves) are often delivered with an unknown primary address or primary address "0"
- Settings can be made with an interface and configuration software
 - Primary address
 - ID (secondary address)
 - Initial meter reading (counter)
 - Current date and time
 - Medium (water, energy,...)




M-Bus master with USB-Interface

Source: www.relay.de/en/


ABB EQmatic Energy Analyzer QA/S x.yy.1

Configuration of M-Bus devices




Speed (baud rate)

Primary address 0...250 or 254 for broadcast



Gas meter (pulse adapter)



Water meter

ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning steps: The steps are identical except for scanning the connected meters




ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning Energy Analyzer QA/S 1.16.1 KNX

To display and process the QA/S values of KNX meters, both the QA/S and the KNX meters must first be configured and parametrized in ETS

- Add the QA/S and KNX meters to the project
- Set the parameters of the QA/S and KNX meters, e.g.
 - Date and time source (KNX, User Interface or time server)
 - Meter settings: Meter Interface Module ZS/S, Energy Actuator SE/S, Energy Module EM/S, Electricity (generic), Gas (generic), Water (generic), Heat (generic)
 - Load control
- Assign group addresses
- Download individual address and application programs




ABB EQmatic Energy Analyzer QA/S x.yy.1

Access via the ABB i-bus® Tool

The ABB i-bus® Tool is free software that provides help with commissioning

The device can be accessed with the ABB i-bus® Tool during initial commissioning

IP address assignment in the QA/S is set to automatic addressing (DHCP/autoIP) at the factory, and the IP address can be read with the ABB i-bus® Tool

Download the ABB i-bus® Tool and install it on the Windows PC/laptop

Download link: www.abb.com/knx




ABB EQmatic Energy Analyzer QA/S x.yy.1

Access via the ABB i-bus® Tool

Start the ABB i-bus® Tool

Click:

- “Connect”
- “IP devices”
- “Discovery”

The ABB i-bus® Tool automatically searches for known IP devices in the local network

Select the desired Energy Analyzer QA/S from the table (click)

Click the “Open Website” button

The default web browser opens, and the start screen of the Energy Analyzer appears




ABB EQmatic Energy Analyzer QA/S x.yy.1

User interface

The connection to the device's web server is established

Enter the user name and the password

Default user name and password on delivery

- Username: admin
- Password: admin

Follow the instructions in the commissioning wizard to proceed with commissioning




ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning wizard (1)

Once a connection to the device is established, the commissioning wizard starts for the first time

The steps are identical except for scanning the connected meters (M-Bus or Modbus)

It guides the user through the steps and basic settings required for initial commissioning

- Read and confirm the terms and conditions of use
- Change the default password
 - This is important for device and data security
 - The password is expected to be at least 9 characters long and contain capital letters, small letters and non-letter (numeric or special) symbols

Introduction Completed: 0%

Welcome

In order to use the device, an initial configuration is required. Please follow the steps of the wizard to configure the device.

[Start configuration](#)

Password reset Completed: 25%

* New password ?

Confirm new password

[Next step](#)

ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning wizard (2)

- Change the network settings if necessary
- QA/S 1.16.1 KNX: All network configuration, except from proxy configuration, is only possible via ETS

Network Completed: 38%

Automatic network configuration

Proxy URL ⓘ
type proxy server address if any...

IP Address
192.168.0.111

* Subnet
24

* Default Gateway
192.168.0.1

DNS Server ⓘ
192.168.0.1

skip Save

ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning wizard (3)

- Configure the date and time
- QA/S 1.16.1 KNX: Date and time can also be received via KNX (3 byte and 8 byte)

Date and time Completed: 43%

Automatic date and time

* Timezone [Detect timezone](#)

Europe/Berlin (UTC+2:00)

* Time synchronization server (NTP) [Change the server](#)

pool.ntp.org

Skip **Next step**

ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning wizard (4)

- Configure the currency, costs and CO₂ factor per consumption unit

Default system settings Completed: 57%

[Edit](#)

Currency

Euro (EUR)

Medium	Unit	Cost per consumption unit [EUR]	CO ₂ per consumption unit [kg]
Electricity	kWh	0.25	0
Water	m ³	3.5	0
Gas	m ³	2.5	0
Heat	kWh	0	0

[Skip](#) [Next step](#)

ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Commissioning wizard (5):

- This step is absolutely essential during commissioning to be able to add, configure and manage M-Bus devices
- Scan the bus for connected M-Bus devices
- This scanning process uses either
 - Primary addressing
 - Secondary addressing
- Limit the scan range as much as possible to reduce the scanning process time
- Scanning can take several minutes depending on the scan settings and the number of M-Bus devices

Scanning Completed: 71%

Primary Secondary

* Speed range (baude rate)

300 9600

* Address range

1 250

Skip Scan

Speed range (baud rate): 2400 - 9600 Address range: 1 - 10

Current address: 6 of 10 for baud rate 2400

Estimated scanning time: 2 minutes

Scanning... 20%

Stop Pause

ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Commissioning wizard (5):

Scanning via the primary address

- The search for devices connected is based on their primary address
 - Each M-Bus device must be assigned to a unique primary address
 - Duplicate addresses cause address conflicts!
- The primary addresses must be set beforehand on the relevant M-Bus devices
- Address range: 1...250
 - Set the limits for the primary address range
- Speed range (baud rate): 300, 600, 1200, 2400, 4800, 9600
 - Set the speed range used for scanning for M-Bus devices connected





ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Commissioning wizard (5):

Scanning via the primary address

- The search for devices connected is based on their primary address
 - Each M-Bus device must be assigned to a unique primary address
 - Duplicate addresses cause address conflicts!
- The primary addresses must be set beforehand on the relevant M-Bus devices
- Address range: 1...250
 - Set the limits for the primary address range
- Speed range (baud rate): 300, 600, 1200, 2400, 4800, 9600
 - Set the speed range used for scanning for M-Bus devices connected



The screenshot shows the ABB EQmatic web interface. The 'Management' menu is highlighted in red. Below it, the 'Meter Management' menu is also highlighted in red. A table titled 'Configuration' is displayed, showing detected meters. A red arrow points to the 'PRIMARY ADDRESS' column header. The table has columns for PRIMARY ADDRESS, STATUS, SPEED, MANUFACTURER, MEDIUM, VERSION, PLACE OF INSTALLATION, METER NAME, SERIAL NUMBER, BUILDING NODE, and ACTION. The data rows are as follows:

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	9600	ABB	Electricity	32		B21 113-100	00752346	NOT ASSIGNED	✎ ✕
11	NOT CONFIGURED	2400	NZR	Water	3			20133660	NOT ASSIGNED	✎ ✕
21	NOT CONFIGURED	2400	REL	Heat	66			00387801	NOT ASSIGNED	✎ ✕
22	NOT CONFIGURED	2400	REL	Gas	66			00387802	NOT ASSIGNED	✎ ✕
101	OK	2400	NZR	Electricity	3			05358833	NOT ASSIGNED	✎ ✕


Detected meters will be listed in the *Meter Management* menu

ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Commissioning wizard (5):

Scanning via the secondary address

- If you select this option, M-Bus devices are scanned based exclusively on their secondary address
- In this case, there is no unique addressing (primary address) in the related M-Bus device
→ The primary address is unknown or is “0” in the delivery state and cannot be changed
- The device serial number is generally used as the secondary address
- The serial number of ABB meters is on the nameplate on the front of the device, e.g. 00486571
- Speed range (baud rate): 300, 600, 1200, 2400, 4800, 9600
 - Set the speed range used for scanning for M-Bus devices connected



Scanning

Primary **Secondary**

* Speed range (baud rate)

300 9600

Cancel Scan




ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 3.xx.1 M-Bus: Commissioning wizard (5):

Scanning via the secondary address

- If you select this option, M-Bus devices are scanned based exclusively on their secondary address
- In this case, there is no unique addressing (primary address) in the related M-Bus device
 - The primary address is unknown or is “0” in the delivery state and cannot be changed
- The device serial number is generally used as the secondary address
- The serial number of ABB meters is on the nameplate on the front of the device, e.g. 00486571
- Speed range (baud rate): 300, 600, 1200, 2400, 4800, 9600
 - Set the speed range used for scanning for M-Bus devices connected



The screenshot shows the ABB EQmatic web interface. The 'Management' menu is highlighted in the top navigation bar. Below it, the 'Meter Management' menu is selected. The main content area displays a 'Configuration' section with a table of detected meters. The table has columns for PRIMARY ADDRESS, STATUS, SPEED, MANUFACTURER, MEDIUM, VERSION, PLACE OF INSTALLATION, METER NAME, SERIAL NUMBER, BUILDING NODE, and ACTION. The SERIAL NUMBER column is highlighted with a red box, and a red arrow points to the first row's serial number, 00752346.

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
--	OK	9600	ABB	Electricity	32		B21 113-100	00752346	NOT ASSIGNED	✎ ✕
-	NOT CONFIGURED	2400	NZR	Water	3			20133660	NOT ASSIGNED	✎ ✕
-	NOT CONFIGURED	2400	REL	Heat	66			00387801	NOT ASSIGNED	✎ ✕
-	NOT CONFIGURED	2400	REL	Gas	66			00387802	NOT ASSIGNED	✎ ✕
-	OK	2400	NZR	Electricity	3			05358833	NOT ASSIGNED	✎ ✕

Detected meters will be listed in the *Meter Management* menu

ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 4.xx.1 Modbus: Commissioning wizard (5):

- Scan the bus for connected Modbus devices and create the automatic metering structure
 - 1,200 ... 115,200 baud
 - Address range 1 ... 247
- Limit the scan range as much as possible to reduce the scanning process time, e.g. ABB EQmeters (default): Baud rate “19200”, Parity “Even”, Byte size “8” and stop bits “1”
- Detected meters will be listed in the *Meter Management* menu
- Clicking on “Skip” allows the user to search for connected Modbus devices or slaves in the *Management* menu later on and to select creation of a manual or automatic metering structure

Scanning Completed: 71%

* Speed range (baud rate)
1200 115200

* Address range
1 247

Parity: None Odd Even
Byte size: 7 8 9
Stop bits: 1 2

Skip Scan

Scanning Completed: 71%

Skip Next step

root
ABB B23 112-100 (#00608121)
ABB B21 112-100 (#00408943)

ABB EQmatic Energy Analyzer QA/S x.yy.1

QA/S 1.16.1 KNX: Commissioning wizard (5):

- The Energy Analyzer QA/S1.16.1 KNX and the KNX meters must first be configured and parametrized in ETS
- The manual or automatic metering structure will be created later in the menu "Management" → "Metering Structure"





ABB EQmatic Energy Analyzer QA/S x.yy.1

Commissioning wizard (6)

Configuration has been completed successfully

The device is ready for operation

The *main* menu with the individually configurable dashboard is displayed



Commissioning


Main menu

ABB EQmatic Energy Analyzer QA/S x.yy.1

Main menu

Main menu structure

Users can navigate around the system using the main menu at the top of the user interface screen. Depending on the selection, a sub-menu may be displayed.



1	Dashboard	Customizable dashboard for displaying the most important data and measured values.
2	Analytics	Detailed analysis of costs, consumption, instantaneous values, benchmarks and comparison functions by consumer. Further processing and export of data and analyses. Automatic report function via email or FTP.
3	Load control	Power dependent load control for switching loads and consumers on and off (only for QA/S 1.16.1 KNX)
4	Management	Used to commission and manage the devices/meters, metering structures, users, tariffs/units and data transfer.
5	System	Basic device and system settings, e.g. date, time etc. as well as diagnostics.
6	Date and time	Displays the current system date and time. Clicking this field displays the date and time setting options.
7	Notifications	Displays notifications such as: <ul style="list-style-type: none">• Available system updates• Errors from connected meters: timeouts/conflicts, short circuits, etc.• Alarm notification: threshold exceeded• Time synchronization: no connection to NTP server
8	Favorites	Quick access to previously configured analyses.
9	User profile	Displays user settings and information such as name, password and access rights. The user language as well as the log-out options can be set.
10	System information	Displays device information such as type, name, current firmware version, serial number, and terms and conditions of use.
11	Logout	Used to log out and end a session.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Main menu

System Notifications

Displays notifications, e.g. system updates etc.

Click to open for more information

- M-Bus/Modbus RTU device error:
Timeout or collision
- M-Bus/Modbus RTU error:
Short circuit or open circuit
- Update available
- Time synchronization:
No connection to NTP server




ABB EQmatic Energy Analyzer QA/S x.yy.1

Main menu

Favorites

Quick link to jump to previously configured favorites analysis diagrams

The favorites can be created in the Analytics menu:

- Historical Data
- Usage Split
- Benchmark - Period
- Benchmark - Consumer

NAME	CREATED ON	ACTION
Weekly CO2 Light Building no 11	2018/09/05 21:29	
Daily load profile: Office floor no.3 (light)	2018/09/05 21:24	

ABB EQmatic Energy Analyzer QA/S x.yy.1


Main menu

User Profile

Displays user settings and information

- Name
- Password
- Email address
- Role and access rights
- The user language as well as the log-out options can be set

Users can be added, configured and deleted in the *Management* menu



Logged in user with administrator rights

ABB EQmatic Energy Analyzer QA/S x.yy.1

Main menu

System Information

Displays device information

- Type
- Order code
- Current firmware version
- Device name
- Meter communication interface (M-Bus or Modbus)
- Device serial number





ABB EQmatic Energy Analyzer QA/S x.yy.1

Main menu

Logout

Used to log out and end a session



Commissioning

Main menu “Management”

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Management

The Management menu is used to make the following setting:

- Meter Management
Note: Different in the device M-Bus, Modbus and KNX device configuration
- Metering Structure
- User Management (administration)
- Tariffs and Unit
- Consumer Groups
- Data Sharing
(transfer to higher-level systems)

Note:
Access only with “administrator” authorization




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 1.16.1 KNX

KNX meters are displayed in the meter management overview table once they are configured in ETS , assigned group addresses and downloaded

No settings can be made in the UI

The changing of parameters has to be done in the ETS and then reloaded into the KNX devices

The changes (e.g. nodes in the metering structure) must be updated in the UI

The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary navigation bar shows 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Overview' and contains a table with the following data:

METER NUMBER	STATUS	PRODUCT TYPE	MEDIUM	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	ACTION
1	OK	ZS/S	Electricity	Training Board (1)	Meter Interface 1: B23-112-100	85674123	
2	OK	ZS/S	Electricity	Training Board (2)	Meter Interface 1: B21-113-100	54129489	
3	OK	SE/S	Electricity	Training Board (3)	Energy Actuator 1: S E/S	1978563	
4	OK	EM/S	Electricity	Training Board (4)	Energy Module 1: EM/S	2581467	
5	OK	Electricity	Electricity	Training Board (5)	Energy Meter: Generic	4419782	
6	OK	Gas	Gas	Training Board (6)	Gas Meter: Generic	10978314	
7	OK	Water	Water	Training Board (7)	Water Meter: Generic	90294256	
8	OK	Heat	Heat	Training Board (8)	Heat Meter: Generic	1178965	
9	OK	Sensor	Sensor	Training Board (9)	Sensor: Measurement		

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 1.16.1 KNX

All KNX devices are shown along with their information in the overview table below

METER NUMBER	STATUS	PRODUCT TYPE	MEDIUM	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	ACTION
1	OK	ZS/S	Electricity	Training Board (1)	Meter Interface 1: B23 -112-100	85674123	
2	OK	ZS/S	Electricity	Training Board (2)	Meter Interface 1: B21 -113-100	54129489	
3	OK	SE/S	Electricity	Training Board (3)	Energy Actuator 1: S E/S	1978563	

Meter Number	Indicates the meter number as configured in ETS
Status	OK: Meter configured and connected. Reading enabled. ERROR, possible causes: <ul style="list-style-type: none">• Installation error (L and N transposed)• IR communication error (only with ZS/S)• Hardware fault• Reading disabled (only with SE/S and EM/S)
Product Type	DISCONNECTED: Device not connected to bus or has no power supply.
Medium	Displays the product in use (e.g. ZS/S) depending on the selection made in ETS
Place of installation	Displays the medium to be measured on the device The installation location must be entered in ETS. This is recommended so that the device is easier to identify and assign when configuring the metering structure. Duplicate names are allowed.
Meter Name	The meter name must be entered in ETS. This is recommended so that the device is easier to identify and assign when configuring the metering structure. Duplicate names are allowed.
Serial Number	The serial number must be entered in ETS. This is recommended so that the device is easier to identify and assign when configuring the metering structure.
Action	A view of the available data points for the meter. Opens the information and table view for the available data points. All of the meter's data points are listed in the table even if the meter is not linked with a group address via ETS, in which case the data point is shown as "0" in the table.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 1.16.1 KNX

Click the “Edit” icon in the overview table to see more information (e.g. instantaneous value) about the KNX meter

Available data points, which depend on the meter type, are listed in the data points list

METER NUMBER	STATUS	PRODUCT TYPE	MEDIUM	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	ACTION
1	OK	Z5/S	Electricity	Training Board (1)	Meter Interface 1: B23-112-100	85674123	
2	OK	Z5/S	Electricity	Training Board (2)	Meter Interface 1: B21-113-100	54129489	
3	OK	SE/S	Electricity	Training Board (3)	Energy Actuator 1: S-E/S	1978563	

Information		Data points			
RECORD NUMBER	VALUE	UNIT	OBJECT FUNCTION		
11	690	Wh	Active Imported Energy Total		
31	29.709999084472656	W	Active Imported Power Total		
32	29.709999084472656	W	Active Imported Power L1		
33	0	W	Active Imported Power L2		
34	0	W	Active Imported Power L3		
47	1	-	Power Factor Total		
48	No data available	-	Power Factor L1		
49	No data available	-	Power Factor L2		
50	No data available	-	Power Factor L3		
51	0.1290000081062317	A	Current L1		
52	0	A	Current L2		
53	0	A	Current L3		
54	No data available	A	Current Neutral		
55	230.90000915527344	V	Voltage L1		
56	18.899999618530273	V	Voltage L2		
57	19.100000381469727	V	Voltage L3		
61	50.08999588012695	Hz	Frequency		
68	No data available	-	Current Quadrant Total		
69	No data available	-	Current Quadrant L1		
70	No data available	-	Current Quadrant L2		
71	No data available	-	Current Quadrant L3		

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

The *Meter Management* menu is used to make all the settings for the detection of M-Bus devices connected

This scan or scanned by commissioning wizard is absolutely essential during commissioning to be able to add, configure and manage devices

After the scan, all M-Bus devices detected are listed in a table

It is the basis for assigning devices to the metering structure later on

Scanning can take several minutes depending on the scan settings and the number of M-Bus devices

Limit the scan range as much as possible to reduce the scanning process time




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

This scanning process uses either primary or secondary addressing

Primary:

- The primary addresses must be set before-hand on the relevant device (M-Bus slave)
- The primary address is pre-set to “0” on ABB meters in the factory
- Each M-Bus device must be assigned a unique primary address (1 ... 250)
- Duplicate addresses cause address conflicts!

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below the navigation bar, a secondary menu shows 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area shows a 'Scanning' dialog box with 'Primary' addressing selected (highlighted with a red box). The dialog includes fields for 'Speed range (baud rate)' (300 and 9600) and 'Address range' (1 and 250). Below the dialog, a 'Configuration' table is visible, with the 'PRIMARY ADDRESS' column highlighted by a red box. The table contains the following data:

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	9600	ABB	Electricity	32		B21 113-100	00486571	NOT ASSIGNED	✕
2	OK	9600	ABB	Electricity	32		B21 113-100	00486574	NOT ASSIGNED	✕
11	OK	2400	ACW	Gas	20			10010545	NOT ASSIGNED	✕

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

Secondary:

- Scan based exclusively on secondary address
- There is no unique (primary) addressing in the related M-Bus device
- The devices respond with speed, manufacturer, medium, version and serial number
- The device serial number is generally used as the secondary address
- It is an 8-digit number printed to the device
- The serial number of ABB meters is on the nameplate on the front of the device, e.g. 00486571

The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted), and 'System'. Below the navigation bar, the 'Meter Management' menu item is highlighted. The main content area displays a 'Scanning' dialog box with 'Secondary' selected as the scan mode. The 'Speed range (baud rate)' is set to 300 and 9600. Below the dialog, the 'Configuration' table is shown with the following data:





PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
-	OK	9600	ABB	Electricity	32		B21 113-100	00486571	NOT ASSIGNED	✕
-	OK	9600	ABB	Electricity	32		B21 113-100	00486574	NOT ASSIGNED	✕
-	OK	2400	ACW	Gas	20			10010545	NOT ASSIGNED	✕

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

After a successful scan, all detected M-Bus devices are shown along with their information in the overview table below

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	9600	ABB	Electricity	32	DB - 3rd floor	Lighting (B21 313-100)	00406880	Lighting 3rd floor	 
5	OK	9600	ABB	Electricity	32	DB - 3rd floor	Air conditioning (B23 313-100)	00433874	Air conditioning 3rd floor	 

Primary address	Shows the primary address set in the M-Bus device.
Status	OK: Meter detected, configured and connected Collision: Address conflict. Devices with same primary address or identical serial number Not configured: Device is not configured. Click on edit button. Disconnected: Device is not available or is disconnected from the M-Bus.
Speed	Shows the speed set in the M-Bus device
Manufacturer	Shows the manufacturer (max. 3 characters, e.g. ABB)
Medium	Shows which medium is measured by the M-Bus device
Version	Shows the firmware version in the M-Bus device
Place of installation	Enter the place the device is installed here. This action is recommended so that the device is easier to identify and assign on configuring the metering structure. Duplicate names are allowed.
Meter name	For ABB meters, the type designation is used by default as the device name after a scan. This can be overwritten. Enter a name for the device here. This action is recommended so that the device is easier to identify and assign on configuring the metering structure. Duplicate names are allowed.
Serial number	Shows the serial number (= secondary address) of the M-Bus device
Assignment	Shows the assignment of the M-Bus device based on the metering structure configured
Action	Used to edit and configure the M-Bus device (opens the window for configuring the meter or removes the M-Bus device from the system).


ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

An M-Bus device is considered configured (status OK) as soon as one of the data points for consumption has been configured

- Electricity meter:
 - Active energy (kWh)
 - Active power (W)
- Water meter:
 - Volume (m³)
- Gas meter:
 - Volume (m³)
- Heat meter:
 - Active energy (kWh)



The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a sub-menu bar contains 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. A table below displays meter configurations with columns: PRIMARY ADDRESS, STATUS, SPEED, MANUFACTURER, MEDIUM, and VERSION. A red arrow points to the STATUS column header, which contains a question mark icon. The table lists three meters: address 1 (Electricity, ABB, 9600), address 2 (Electricity, ABB, 9600), and address 11 (Gas, ACW, 2400).

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION
1	OK	9600	ABB	Electricity	32
2	OK	9600	ABB	Electricity	32
11	OK	2400	ACW	Gas	20

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus





ABB EQ A4x/B2x meters are automatically detected after scanning and do not need to be configured

Available data points, which depend on the meter type, are listed in the data points list

If a M-Bus device is shown as “Not Configured” or “Not detected” after scanning, you need to configure the device or its data points

Click the “Edit” icon in the device overview of the M-Bus device to be configured

- Meter name: For ABB meters, the type designation (e.g. A41 513-100) is used by default as the meter name
- Place of installation: To enter the physical place where the M-Bus device is installed

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	9600	ABB	Electricity	32	DB - 3rd floor	Lighting (B21 313-100)	00406880	Lighting 3rd floor	 
5	OK	9600	ABB	Electricity	32	DB - 3rd floor	Air conditioning (B23 313-100)	00433874	Air conditioning 3rd floor	 

Information

Manufacturer: ABB
Status: OK
Version: 32
Address: 1
Medium: Electricity
Serial number: 00406880

Configuration

Meter Name:

Place of installation:

Meter measures generated energy:



RECORD NUMBER	VALUE	UNIT	DESCRIPTION	ACTION
0	6260	Wh	Active Imported Energy Total	
1	6260	Wh	Active Imported Energy Tariff 0	
2	0	Wh	Active Imported Energy Tariff 1	
3	0	Wh	Active Imported Energy Tariff 2	
4	0	Wh	Active Imported Energy Tariff 3	
5	0	Wh	Active Exported Energy Total	
6	0	Wh	Active Exported Energy Tariff 0	
7	0	Wh	Active Exported Energy Tariff 1	
8	0	Wh	Active Exported Energy Tariff 2	
9	0	Wh	Active Exported Energy Tariff 3	

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

To add a manufacturer-specific data point, you need to configure it, e.g. gas meter

RECORD NUMBER	VALUE	UNIT	DESCRIPTION	ACTION
0	10010545		Serial	
1	0024464347		cust. ID	
2	18-9-3 9:59	time&date	Time point	
3	1287	hours	bat. time	
4	0	l	Volume Total	

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 3.xx.1 M-Bus

The required data point information must be entered in the configuration dialog

- Group (consumption, generation, ...)
- Presentation
- Unit
- Multiplier
- Description
- Tariff

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu shows 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area displays the configuration dialog for a data point, titled 'ACW_Unknown (#10010545) > Data point (#4)'. The dialog is split into two panels: 'Information' and 'Configuration'. The 'Information' panel shows details like Record number (4), Device unit (0), Function (Instantaneous), Tariff (none), DiF code (E0000100), and ViF code (E0010100). The 'Configuration' panel includes fields for Group (Consumption), Presentation (Volume Total), Unit (l), Multiplier (10 (deca)), Description (Volume), and Tariff (Select...). There are also buttons for 'Cancel' and 'Save'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

The *Meter Management* menu is used to make all the settings for the detection of Modbus devices connected

After the scan, all Modbus devices detected are listed in a table

This scan or scanned by commissioning wizard is absolutely essential during commissioning to be able to add, configure and manage devices

It is the basis for assigning devices to the metering structure later on

In the supplied state, the meter models and the register mapping are saved with data points for ABB EQ meters of type A4x, B2x and M2M

As an alternative to a scan, devices can also be added manually to the system

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu contains 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Configuration' and has three tabs: 'Meters', 'Meter models', and 'Register mappings'. The 'Meters' tab is active, showing a table of detected devices. A red arrow points to a 'Scanning' button and a '+ Add' button. The table has the following columns: PRIMARY ADDRESS, STATUS, SPEED, MANUFACTURER, MEDIUM, VERSION, PLACE OF INSTALLATION, METER NAME, SERIAL NUMBER, BUILDING NODE, and ACTION.

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
-----------------	--------	-------	--------------	--------	---------	-----------------------	------------	---------------	---------------	--------

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

To scan the bus for meters connected, first the speed range (speed), address range, parity, byte size and stop bits must be set

- The primary addresses must be set before-hand on the relevant devices (Modbus slaves)
- Each Modbus device must be assigned a unique primary address (1 ... 247)
- Duplicate addresses cause address conflicts!
- ABB meters are supplied from the factory with the primary address “1”, speed “19,200”, parity “even”, byte size “8” and stop bits “1”

Scanning can take several minutes depending on the scan settings and the number of Modbus devices

Limit the scan range as much as possible to reduce the scanning process time

The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below the navigation bar, the 'Meter Management' menu item is also highlighted with a red box. The main content area displays a 'Scanning' dialog box with the following settings: Speed range (baud rate) set to 1200 and 115200; Address range set to 1 and 247; Parity set to None, Odd, and Even; Byte size set to 7, 8, and 9; and Stop bits set to 1 and 2. Below the dialog, the 'Configuration' table is shown, with the 'PRIMARY ADDRESS' column highlighted by a red box. The table contains two rows of meter data.

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	19200	ABB	Electricity	-		B23 112-100	00608121	NOT ASSIGNED	✕
2	OK	19200	ABB	Electricity	-		B21 112-100	00408943	NOT ASSIGNED	✕

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

As an alternative to a scan, meters can also be added manually to the Energy Analyzer

For this purpose the device-specific information must be specified

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary navigation bar shows 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Meter configuration' and contains the following fields:

- Meter models: Select...
- * Address: Type meter address...
- Installation: Installation place...
- * Baudrate: Select...
- Meter Name: Meter name...
- * Bytesize: Select...
- Serial number: Type serial number...
- * Parity: Select...
- Meter measures generated energy:
- * Stop bits: Select...

At the bottom right of the form are 'Cancel' and 'Save' buttons.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

After a successful scan, all Modbus devices detected are shown along with the information they provided in the table below

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	19200	ABB	Electricity	768	DB - 7th floor	Electrical HEAT	00608121	NOT ASSIGNED	 
2	OK	19200	ABB	Electricity	768	DB - 7th floor	Socket outlets	00408943	NOT ASSIGNED	 

Primary address	Shows the primary address set in the device.
Status	OK: Meter detected, configured and connected. System ready for operation. NOT CONFIGURED: Device model is linked to register mapping, however at least 1 data point is not configured. Configure using . NOT IDENTIFIED: Register mapping defined but meter model unknown or register mapping defined but linked with wrong meter model. DISCONNECTED: - Device not connected to bus or has no power supply, data points incorrectly configured in register mapping or not available in device or collision (address conflict). Devices with same primary address and speed
Speed	Shows the speed set in the device
Manufacturer	Shows the manufacturer (max. 3 characters, e.g. ABB)
Medium	Shows the medium to be measured on the device
Version	Shows the firmware version in the device
Place of installation	Enter the place the device is installed here. This action is recommended so that the device is easier to identify and assign on configuring the metering structure. Duplicate names are allowed.
Meter name	For ABB meters, the type designation is used by default as the device name after a scan. This can be overwritten. Enter a name for the device here. This action is recommended so that the device is easier to identify and assign on configuring the metering structure. Duplicate names are allowed.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”


Meter Management: QA/S 4.xx.1 Modbus

After a successful scan, meter models configured as in the previous instructions are detected and marked in the table with the status OK

→ The system is now ready for operation

Should one of the following status messages appear in the table after the scan, the meter model or register mapping with data points must be configured, corrected or added

- Not configured
- Not identified
- Disconnected



The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this is a sub-menu with 'Meter Management' (highlighted with a red box), 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area displays a table with the following data:

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION
1	OK	19200	ABB	Electricity	768
2	OK	19200	ABB	Electricity	768

A red arrow points to the 'STATUS' column header, and a question mark icon is visible in the top right corner of the table area.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

For correct operation, as a minimum the data point for the product name and one of the following data points for consumption must be configured

- Electricity meter:
 - Active energy (kWh)
 - Active power (W)
- Water meter:
 - Volume (m³)
- Gas meter:
 - Volume (m³)
- Heat meter:
 - Active energy (kWh)

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION
1	OK	19200	ABB	Electricity	768
2	OK	19200	ABB	Electricity	768

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

ABB EQ A4x/B2x meters and M2M Modbus Network analyzer are automatically detected after scanning and do not need to be configured (e.g. data points)

The data points are visible if you open the Edit function for the required meter in the table of meters detected

The data points can be edited as required

1	RTU register address	Shows the register address for the related data point.
2	Value	Shows the currently measured value for the data point.
3	Unit	Shows the physical unit of the related data point. Some data points may not have a unit, e.g. number of power failures.
4	Description	Describes the related data point. If the data point is manufacturer-specific and needs to be configured, this situation will be shown here.
5	Action	Used to edit and configure a data point

PRIMARY ADDRESS	STATUS	SPEED	MANUFACTURER	MEDIUM	VERSION	PLACE OF INSTALLATION	METER NAME	SERIAL NUMBER	BUILDING NODE	ACTION
1	OK	19200	ABB	Electricity	768	DB - 7th floor	Electrical HEAT	00608121	NOT ASSIGN	 
2	OK	19200	ABB	Electricity	768	DB - 7th floor	Socket outlets	0040894	ASSIGN	 








Data points				
RTU REGISTER ADDRESS	VALUE	UNIT	DESCRIPTION	ACTION
0x5000	0	kWh	Active Imported Energy Total	
0x5460	0	kWh	Active Imported Energy L1	
0x5464	0	kWh	Active Imported Energy L2	
0x5468	0	kWh	Active Imported Energy L3	
0x5B00	234.2	V	Voltage L1	
0x5B02	21.7	V	Voltage L2	
0x5B04	21.9	V	Voltage L3	

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Meter Management: QA/S 4.xx.1 Modbus

To configure or add new Modbus devices, it is necessary to define the meter model as well as the register mapping and related data points

General procedure to add to the Energy Analyzer a new Modbus device that is not yet saved in the system:

1. Add meter model
2. Select register mapping or configure new mapping
3. Configure data points for register mapping
4. Start scan or add device manually

Here the register mapping and device model can be added in any order

PRODUCT NAME	MEDIUM	REGISTER MAPPING	VERSION	ACTION
A41 112-100	Electricity	ABB EQ-Meters	768	
A41 112-100	Electricity	ABB EQ-Meters	512	
A41 112-100	Electricity	ABB EQ-Meters	1024	

* Product name: Type value...

* Register mapping configuration: Select...

Minimum readout interval [s]: Type number...

Back Save

Register Mapping Data Points

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure

This function is used to specify the required metering structure for the building or infrastructure

This makes navigation easier when carrying out analyses later on

Data aggregation or totals settings are also made here

There are various options available

- Manual Structure
- Automatic Structure
This structure is additionally created when the M-Bus or Modbus is scanned for devices or slaves with the commissioning wizard

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu shows 'Meter Management', 'Metering Structure' (highlighted with a red box), 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Metering structure configuration' and features a search bar, a tree view under 'Main building' with items like 'Air conditioning 3rd floor', 'Lighting 3rd floor', 'Printer 3rd floor', and 'Water 3rd floor', and a legend on the right with entries for 'Virtual meter', 'Metering point', 'Medium', and 'Difference'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure

The “Automatic metering structure” created with the commissioning wizard or an existing metering structure can be removed by deleting the main node

A selection button for creating a manual or automatic metering structure is then displayed

An automatically created metering structure can be manually edited and changed as required at any time




The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary navigation bar shows 'Meter Management', 'Metering Structure' (highlighted with a red box), 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Metering structure configuration'. It features a search bar, a tree view of nodes (root, ABB B21 313-100, ABB B23 313-100), and a legend with 'Virtual meter' and 'Metering point'. A context menu is open over the 'root' node, showing options: 'Create sub node', 'Edit node', and 'Remove node'. Red arrows point to the search bar, the 'root' node, and the 'Remove node' option. Below this, a second screenshot shows the same interface with a '+ Manual' and '+ Automatic' button visible on the left side of the configuration area.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure

It can consist of the following sub-nodes:

-  **Virtual meter**
No meters can be assigned. It summarizes consumption and/or measured data from subordinate nodes (additional virtual meters or metering points) of the first level in the tree structure
-  **Metering point**
A metering point only ever consists of one meter assigned to it
-  **Difference**
It is automatically created and calculated and indicates the difference between the collected data of the superordinate node and the sum of the collected data of the sub-nodes







ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure

It can consist of the following sub-nodes:

-  **Virtual meter**
No meters can be assigned. It summarizes consumption and/or measured data from subordinate nodes (additional virtual meters or metering points) of the first level in the tree structure
-  **Metering point**
A metering point only ever consists of one meter assigned to it
-  **Difference**
It is automatically created and calculated and indicates the difference between the collected data of the superordinate node and the sum of the collected data of the sub-nodes




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure: Automatic Structure

With the Automatic Structure, a configuration window for the main node opens

Here, you need to enter the name of the building to which the meters are assigned, for example

Detected and configured devices are then automatically displayed in a flat (non-nested) list under the main node

The main node represents a virtual meter

This aggregates data points or values that can be physically added together (e.g. energy in kWh, power in W) in the main node

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu shows 'Meter Management', 'Metering Structure' (highlighted with a red box), 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Metering structure configuration'. A modal window titled 'Automatic structure' is open, containing a blue information box that reads: 'Here you can automatically configure metering structure. Please provide name for the root node. System will automatically create flat nodes structure, under the root node, based on all available and configured meters.' Below this, there is a text input field labeled '* Root node name' with the placeholder 'type root node name...'. A red arrow points to the 'Automatic' option in the left sidebar, and another red arrow points to the 'Save' button in the modal. Below the modal, the main configuration area shows a search bar, a 'Main building' header, and a list of detected devices: 'Air conditioning (B23 313-100)' and 'Lighting (B21 313-100)'. A 'Legend' section on the right lists 'Virtual meter' and 'Metering point'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure: Manual Structure

The Manual Structure allows you to set up a custom topology (main and sub-nodes)

With a Manual Structure, physical meters are assigned to a logical metering structure

The Manual Structure can be used, for example, to show consumers and costs for a cost center or an organization

The Metering Point and Virtual Meter structural elements are provided for this purpose

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary navigation bar shows 'Meter Management', 'Metering Structure' (highlighted with a red box), 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is titled 'Automatic structure' and contains a blue information box: 'Here you can automatically configure metering structure. Please provide name for the root node. System will automatically create flat nodes structure, under the root node, based on all available and configured meters.' Below this is a form for 'Root node name' with the text 'Main building' entered. A red arrow points to the 'Manual' option in the left sidebar. Below the form is a 'Metering structure configuration' section with a search bar and a tree view showing 'Main building' with a settings icon. A context menu is open over 'Main building' with options: 'Create sub node', 'Edit node', and 'Remove node'. To the right is a 'Legend' section with 'Virtual meter' and 'Metering point' entries.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure: Manual Structure

Clicking on the configuration icon opens the sub-menu:

- Create sub-node:
A sub-node is created for the current node
 - Virtual Meter
 - Metering Point
 - Difference
- Edit:
The dialog window for editing a node is displayed
- Delete:
The node is deleted from the system
- The user can click and drag sub-nodes to move them in the structure




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Metering Structure: Manual Structure

Dialog window for editing a node

- Node type: Metering Point
- Name: Used to name the node
- Meter: This parameter links the node to a physical meter. Meters are only displayed for selection if they have been added to the system via Meter Management and correctly configured
- Medium: Here, enter and set the medium that you wish the metering point to log
- Consumer group: This is used to select and assign a consumer group
- Meter data points: This is used to select and assign a data point

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu shows 'Meter Management', 'Metering Structure' (highlighted with a red box), 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is divided into two sections:

Create node

* Node type: Metering point
* Node name: 3rd floor lighting
Meter: Electricity, ABB, Lighting (B21 313-100), DB- 3rd floor, #00406880
* Medium: Electricity
Consumer group: Select...
Meter data points:

TARIFF	METER TARIFF DATA POINT	ASSIGNED TARIFF
0	Active Imported Energy Tariff 0	default tariff
1	Active Imported Energy Tariff 1	default tariff

Metering structure configuration

Search by name, consumer group, meter...

- Main building
 - 3rd floor marketing
 - 3rd floor lighting
 - 3rd floor air conditioning

Legend

- Virtual meter
- Metering point

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

User Management

In User Management you can add, configure and delete users

You can add as many users as you wish

Up to 10 users can access the system at any one time








The language can be set and different access rights assigned to the users

This function limits users to the areas they are authorized

The email address is required to send users automatically reports or a message about resetting the password if the "password is forgotten"

The screenshot displays the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below the navigation bar, a secondary menu shows 'Meter Management', 'Metering Structure', 'User Management' (highlighted with a red box), 'Tariffs and units', 'Consumer Groups', and 'Data sharing'. The main content area is divided into two sections: 'Users list' and 'User configuration'.

Users list

NAME	E-MAIL	ADMINISTRATOR	ACTION
admin		yes	 
Jue-ABB		yes	 
Heinz Becker		no	  

User configuration

User data Assign user rights

- Main building
 - 3rd floor marketing
 - 3rd floor lighting
 - 3rd floor air conditioning
 - 3rd floor product management
 - 3rd floor R&D

Buttons: Cancel, Save

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Tariffs and Units


The tariff settings are used to configure tariffs

This information is necessary for the subsequent calculation and display of costs

Refer to your latest bill, or your contract, for details of your current tariff

One tariff is pre-configured per medium from the factory; the costs per unit are set to "0."

You can add further tariffs



The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary navigation bar shows 'Meter Management', 'Metering Structure', 'User Management', 'Tariffs and units' (highlighted with a red box), 'Consumer Groups', and 'Data sharing'. The main content area displays 'Existing tariffs overview' with a '+ Add new' button. The table below lists the following data:







NAME	MEDIUM	COST PER UNIT	CO ₂ FACTOR	ACTION
Night tariff	Electricity	0.15 [EUR / 1 kWh]	0.527 [CO ₂ kg / kWh]	 
Default tariff	Electricity	0.25 [EUR / 1 kWh]	0.527 [CO ₂ kg / kWh]	
Default tariff	Water	3.9 [EUR / 1 m ³]	0 [CO ₂ kg / m ³]	
Default tariff	Gas	0.745 [EUR / 1 m ³]	2 [CO ₂ kg / m ³]	
Default tariff	Heat	0.265 [EUR / 1 kWh]	0.12 [CO ₂ kg / kWh]	

ABB EQmatic Energy Analyzer QA/S x.yy.1


Menu “Management”

Consumer Groups

Consumer groups are used to evaluate costs and consumption by application in the *Analytics* → *Usage* menu

For example, you can display electrical energy costs by consumer groups such as lighting, sockets and air conditioning

In order to be able to do this, a separate meter must be installed and assigned to a consumer group via the *Management* → *Metering Structure* menu



The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. Below this, a secondary menu shows 'Meter Management', 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups' (highlighted with a red box), and 'Data sharing'. The main content area is titled 'Existing consumer groups' and features a '+ Add new' button. A table lists the following consumer groups:









NAME	MEDIUM	ACTION
Air conditioning	Electricity	 
Heating	Gas	 
Lighting	Electricity	 
Warm water	Water	 

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Data sharing via Modbus TCP

The data sharing functions below are used to forward and utilize measured data in higher-level systems (e.g. building management systems, SCADA or web services).

- Modbus TCP
- REST API

Both communication interfaces can be used at once

Note:
Using Modbus TCP and REST API requires IT programming expertise




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”

Data sharing via Modbus TCP

The data transfer via Modbus TCP function is available for forwarding and using measured data in higher-level systems (e.g. building management systems, SCADA etc.)

A Client-server communication is established via Modbus TCP

This communication requires a TCP connection to be set up between a client (e.g. a PC) and the server (e.g. the Energy Analyzer QA/S x.yy.1)

The TCP port 502 reserved for Modbus is used for communication

If there is a firewall between the server and client, it must be ensured the TCP port configured is opened

The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted), and 'System'. Below this, a secondary navigation bar shows 'Meter Management', 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing' (highlighted). The main content area is titled 'Data sharing' and features a 'Modbus TCP' tab (highlighted) and a 'Rest API' tab. An 'Enable static register mapping' toggle is visible. Below the tabs is a table with the following data:

<input checked="" type="checkbox"/>	MODBUS TCP SLAVE ID	METER NUMBER	MANUFACTURER	SERIAL NUMBER	NAME	DATA POINTS
<input checked="" type="checkbox"/>	1	1	ABB		Meter Interface 1: B23-112-100	^
<input checked="" type="checkbox"/>	2	2	ABB		Meter Interface 1: B21-113-100	^
<input checked="" type="checkbox"/>	3	3	ABB		Energy Actuator 1: SE/S	^
<input checked="" type="checkbox"/>	4	4	ABB		Energy Module 1: EM/S	^
<input checked="" type="checkbox"/>	5	5	unknown		Energy Meter: Generic	^
<input checked="" type="checkbox"/>	6	6	unknown		Gas Meter: Generic	^
<input checked="" type="checkbox"/>	7	7	unknown		Water Meter: Generic	^
<input checked="" type="checkbox"/>	8	8	unknown		Heat Meter: Generic	^
<input checked="" type="checkbox"/>	9	9	unknown		Sensor: Measurement	^

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Management”


Data sharing via REST API

An API (Application Programming Interface) enables two programs to communicate with each other

REST (Representational State Transfer) is mainly used by web browsers and is a common programming style for web services

REST API provides easier access to lots of web services, e.g. If you need to set up your own cloud server or create a customer-specific application

Data can be accessed using HTTP commands such as GET, PUT, POST, DELETE



Commissioning

Main menu “System”

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

System

Basic settings are made in the System menu

- General
- Date and time
- Network settings
- Update
- SMTP configuration
- SSL certificate
- SSH access
- Erase data
- System log
- System diagnostics

Note:

Access only with “administrator” authorization




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

General

Device Name

- For assigning a device name
- The device name is displayed in the ABB i-bus® Tool
- QA/S 1.16.1 KNX: The device name is assigned in the ETS

Currency

- For setting the currency for cost calculation or display

The screenshot displays the ABB EQmatic web interface. The top navigation bar includes the ABB logo, 'EQmatic', and several menu items: 'Dashboard', 'Analytics', 'Management', and 'System'. The 'System' menu is highlighted with a red box. Below the navigation bar, a secondary menu contains 'General', 'Date and Time', 'Network', 'Update', 'SMTP Configuration', 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log', and 'System diagnostics'. The 'General' menu item is also highlighted with a red box. The main content area shows the 'General settings' configuration page. It features two input fields: 'Device name' with the value 'QA-S 3.16.1' and 'Currency' with a dropdown menu set to 'Euro (EUR)'. A blue 'Save' button is located at the bottom right of the settings area.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Date and Time

Automatic or manual date and time setting can be selected

Automatically Off:

- For manual setting of the time, date and time zone

Automatically On:

- The address/URL of the time server (e.g. pool.ntp.org) must be entered in the “Time synchronization server (NTP)” field
- The “Change the server” option must be used to change the server

QA/S 1.16.1 KNX: Date and time can also be received via KNX (3 byte and 8 byte)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Network

Automatic or manual addressing can be selected

Automatic network configuration On:

- The device’s network settings are assigned automatically by a DHCP server in the network or by a router with DHCP functionality
- If no automatic assignment of the network settings takes place via DHCP, then a standard network setting will be made in the Auto IP range: 169.254.1.0 – 169.254.254.255

Automatic network configuration Off:

- The device’s network settings must be entered manually

QA/S 1.16.1 KNX: All network configuration, except from proxy configuration, is only possible via ETS

The screenshot displays the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System' (highlighted with a red box). The date and time '2018-09-04 13:45' are shown on the right. Below the navigation bar, a secondary menu contains 'General', 'Date and Time', 'Network' (highlighted with a red box), 'Update', 'SMTP Configuration', 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log', and 'System diagnostics'. The main content area is titled 'System network settings' and features a toggle for 'Automatic network configuration' which is currently turned on. Below this, there are input fields for 'Proxy URL' (with a placeholder 'type proxy server address if any...'), 'IP Address' (192.168.0.111), '* Subnet' (24), '* Default Gateway' (192.168.0.1), and 'DNS Server' (192.168.0.1). A blue 'Save' button is located at the bottom right of the settings panel.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Update

Various options are available for updating the device or the firmware to the latest version

- Manual update
- Automatic update

The data and configuration in the device are retained during an update

The current version and other device-specific information can be retrieved via the menu item “Device information” in the main menu




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Update – Manual update

The update packages are available under the following download link

www.abb.com/knx

→ Products and Downloads

→ Energy Management

→ QA/S x.yy.1 Energy Analyzer

Save the latest firmware version to your PC/laptop

Click “Select update” and select the update file on the drive

Follow the instructions

The device will be rebooted after the update, and you will have to log in again




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Update – Automatic update

The automatic update must be activated

The address/URL of the update server must be entered

The “Notifications” icon in the menu bar will inform you when a new update becomes available

Click on the notification and follow the instructions

The device will be rebooted after the update, and you will have to log in again

The screenshot displays the ABB EQmatic web interface. At the top, the navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System' (highlighted with a red box). Below this, a secondary menu shows 'General', 'Date and Time', 'Network', 'Update' (highlighted with a red box), 'SMTP Configuration', 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log', and 'System diagnostics'. A notification bar below the menu shows the date '2017-08-17 16:19' and a notification icon with a blue circle and a red arrow pointing to it. The main content area is titled 'Update' and has two tabs: 'Manual update' and 'Automatic update settings' (selected). Under 'Automatic update settings', there is a toggle for 'Automatic updates enabled' which is currently turned on. Below this is a field for '* Updates server URL' containing the text 'http://www.knx-gebaeudesysteme.de/sto_g/MLC/MBUS'. At the bottom right of the settings area are 'Reset' and 'Save' buttons.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

SMTP Configuration

These settings configure the SMTP server

These settings are required so that the device can send messages, notifications (e.g. when the password is reset) and automatic reports via e-mail to users or recipients

You can configure the settings manually or by pre-selecting an e-mail service provider

Note: The required settings will be made available by the relevant provider

The screenshot displays the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System' (highlighted with a red box). The date '2018-09-04 13:45' and user icons are visible on the right. Below the navigation bar, a sub-menu contains 'General', 'Date and Time', 'Network', 'Update', 'SMTP Configuration' (highlighted with a red box), 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log', and 'System diagnostics'. The main content area shows the 'SMTP Configuration' form with the following fields:

- E-mail provider: Select E-Mail provider (dropdown menu)
- * "From" E-mail: Text input field
- Login: Text input field
- Password: Text input field
- * SMTP server address: Text input field
- * Security: NONE (dropdown menu)
- * Port: Text input field

A blue 'Save' button is located at the bottom right of the form.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Date and Time

Example: Gmail

- Email provider: Gmail (Google)
- “From” Email: xyz@gmail.com
(email of sender for all emails sent by QA/S)
- Password: *****

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System' (highlighted with a red box). The sub-navigation bar includes 'General', 'Date and Time', 'Network', 'Update', 'SMTP Configuration' (highlighted with a red box), 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log', and 'System diagnostics'. The main content area is titled 'SMTP Configuration' and contains the following fields:

- E-mail provider: Gmail
- * "From" E-mail: abb-qas@gmail.com
- * Password: *****

Buttons for 'Reset' and 'Save' are located at the bottom right of the form.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

SMTP Configuration

Depending on the provider special account settings must be made

Example: Gmail

- IMAP access: Enable
(access Gmail from other clients using IMAP)
→ Account setting → Forwarding &POP/IMAP
- Allow less secure apps: On
Some apps and devices use less secure login technologies. This will make your account more vulnerable. You can disable access to these apps (recommended) or enable access if you want to use the apps despite the risk.




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu "System"

SSL Certificate

SSL stands for "secure sockets layer"

Using an SSL certificate will encrypt the data transmitted to the computer on opening a website, for example

SSL certificates can be used to encrypt data for web pages or e-mails, for example

The following options are available for handling SSL certificates:

- Upload certificate
- Generate certificate
<https://ssl-trust.com/>
- Delete certificate




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

SSH Access

A secure network connection to the web server can be established using SSH (Secure Shell)

This access can then be used for servicing and maintenance purposes by the manufacturer

Authorization with time limit

- Access can be restricted to a certain number of hours with this parameter
- Duration for 1 ... 168 hour

Grant permission with no time constraint

- When this function is activated via the slide control, SSH access is permanently available




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

Erase data

This function allows you to delete all saved data and user-specific information from the system

This resets the system to its supplied state

The most recently installed system update is retained

The following data are reset to the factory settings or deleted:

- Devices and meters
- All meter data saved
- Meter configurations and metering structure configured
- Users and associated information (users and passwords are reset to the factory settings)
- All system settings
- SSL certificates (if any)
- QA/S 1.16.1 KNX: ETS parameter setting, group addresses and individual physical address




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

System Log

This function logs and timestamps all relevant information about the system and connected devices:

- IP network settings
- Date/time (Manual | Automatic)
- Reset to factory settings
- Device restart
- Firmware update
- Meter/device has been assigned to a new node
- Node has been deleted/added from/to metering structure
- User added/deleted
- User logged in/logged out

The System Log can also be restricted to a period using the calendar settings and exported as a file (e.g. xlsx).

The screenshot displays the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management', and 'System' (highlighted in red). Below this, a secondary menu contains 'General', 'Date and Time', 'Network', 'Update', 'SMTP Configuration', 'SSL Certificate', 'SSH Access', 'Erase data', 'System Log' (highlighted in red), and 'System diagnostics'. The main content area is titled 'System Log' and features an 'Export' dropdown, 'From date' and 'To date' input fields with calendar icons, and a 'Filter' button. The log table has two columns: 'TIMESTAMP' and 'ACTION'. The entries are as follows:

TIMESTAMP	ACTION
16/01/2020 12:40:23	The user admin (role Admin) logged in.
16/01/2020 08:25:15	The system was restarted.
15/01/2020 11:31:23	The system was restarted.
14/01/2020 15:48:31	The user admin (role Admin) logged in.
14/01/2020 14:44:42	The system was restarted.
14/01/2020 14:43:33	The system date/time settings were changed to manual with timezone Africa/Abidjan by .
14/01/2020 14:43:24	The user admin (role Admin) logged in.
14/01/2020 13:41:02	The system date/time settings were changed to manual with timezone Europe/Berlin by .
14/01/2020 11:55:57	The user admin (role Admin) logged in.
14/01/2020 11:08:41	The system was restarted.

A 'Load more...' button is located at the bottom of the table.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System”

System diagnostics

The System diagnostics function provides information on the device performance and the actual device status and is used for general diagnostics

The following information is available:

- Memory
- Database storage
- CPU utilization




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System

Troubleshooting: Device access

The Energy Analyzer QA/S x.yy.1 user interface cannot be accessed:

- Check the connections, cables and network connection, etc.
- Start the i-bus® Tool and scan the network for IP devices. Select the device in question and click “Open Website.” The Login page opens. Enter the access data.
- If the device is not listed in the i-bus® Tool after a network scan
 - Check the PC’s/laptop’s network settings; switch off the firewall if necessary
 - Restart and reset the network settings (see manual). A new IP address may be assigned via DHCP. Start the i-bus® Tool and scan the network.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System

Troubleshooting: M-Bus

No or several M-Bus devices do not respond:

- Short circuit on the M-Bus?
- Line not connected correctly or line severed?
- Energy Analyzer ready for operation, supply voltage available?
- The voltage at the M-Bus terminals is at least 24 V?
- Identical baud rates (300; 2,400; 9,600) set on the Energy Analyzer and the bus device(s)?

One M-Bus device does not respond:

- Bus address not assigned
- Bus address incorrect
- M-Bus device not connected
- M-Bus line severed
- Check M-Bus address of the device

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “System

Troubleshooting: Modbus (RS485)

To minimize potential sources of faults, a few basic aspects should be taken into account on the usage of RS485

Determine the communication characteristics of a device before the system design is completed

Pay attention to the following points here:

- Two-wire or four-wire system
 - RS485 systems can be either two-wire or four-wire systems
 - The two-wire configuration - with the additional earth wire - reduces the wiring costs, however it is limited to half duplex communication (cannot receive and transmit at the same time)
 - The majority of RS485 devices have two-wire configurations.
- How high is the response time of the device (processing time)?
- What is the address range of the device that can be programmed?
- Which speed is supported?

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

During commissioning ...

- A** ... the meters can be manually inserted from a catalog and configured offline. Addressing is performed later.
- B** ... the meters must be in operation, connected to the M-Bus/Modbus/KNX of the QA/S and configured (e.g. baud rate, primary address).
- C** ... the meters must not be recording any measured values. Switch off the circuit or shut off the water supply, for example.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 1

During commissioning ...

- A** ... the meters can be manually inserted from a catalog and configured offline. Addressing is performed later.
- B** ... the meters must be in operation, connected to the M-Bus/Modbus/KNX of the QA/S and configured (e.g. baud rate, primary address).
- C** ... the meters must not be recording any measured values. Switch off the circuit or shut off the water supply, for example.

The meters must be ready for operation and configured

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

The commissioning wizard can be used to ...

- A** ... perform all necessary steps and basic settings in the Energy Analyzer QA/S during initial commissioning.
- B** ... configure the connected M-Bus/Modbus/KNX devices (meters) (e.g. baud rate, primary address,...).
- C** ... search for known IP devices in the local network and thereby read the network address of the Energy Analyzer QA/S.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 2

The commissioning wizard can be used to ...

- A** ... perform all necessary steps and basic settings in the Energy Analyzer QA/S during initial commissioning.
- B** ... configure the connected M-Bus/Modbus/KNX devices (meters) (e.g. baud rate, primary address,...).
- C** ... search for known IP devices in the local network and thereby read the network address of the Energy Analyzer QA/S.

Perform all necessary steps and basic settings during initial commissioning

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

The metering structure ...

- A** ... is only optional. The M-Bus/Modbus/KNX devices can be managed in the topology view as well.
- B** ... must be created separately for each medium (electricity, gas, ...).
- C** ... is used for simple navigation and analysis. The physical meters are assigned to a logical metering structure.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Which answer is correct?

Question 3

The metering structure ...

- A** ... is only optional. The M-Bus/Modbus/KNX devices can be managed in the topology view as well.
- B** ... must be created separately for each medium (electricity, gas, ...).
- C** ... is used for simple navigation and analysis. The physical meters are assigned to a logical metering structure.

Navigation, analysis and assignment of the meters

Commissioning

Main menu “Dashboard”

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Dashboard

The dashboard provides a rapid overview of costs and consumption figures in the building

Users can configure customized views using widgets

A widget is a configurable graphic display element

Widgets are configured in edit mode

Each user creates his or her own dashboard with up to 24 widgets

Note:

Data for evaluation and analysis are not yet available after commissioning. This means that the dashboard is empty at that point. Make sure that connected devices are configured and that at least one meter is assigned to the metering structure.




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Widgets

1	Presets	Selects and displays current day, week, month, year, all. Presets are shown dynamically, depending on the measuring period.
2	Edit	Activates edit mode: <ul style="list-style-type: none">• Add widget• Place widget using drag & drop• Enlarge/reduce widget• Configure widget• Delete widget• Save
3	Add widget	Used to add and configure a widget. Only displayed in edit mode.




ABB EQmatic Energy Analyzer QA/S x.yy.1


Menu "Dashboard"

Widgets

Widgets are used to configure and lay out the dashboard.

The following widgets are available:

- Instantaneous Values **1**
- Usage Split **2**
- Historical Data **3**
- Consumer Ranking **4**
- Total values **5**
(performance indicators)

To add a widget to the dashboard, activate edit mode  and click the "Add widget" button




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Widget – Instantaneous Values

Used to display measured values, e.g. power, current, voltage etc. in real time.

The following options are available to configure the widget:

- Building node (used to select the meter and/or building section depending on the metering structure configured)
- Medium (electricity, water, gas, ...)
- Value to display (selection of data points)
- Chart type (Serial Chart, Gauge, Single value)
- Custom name

The screenshot displays the ABB EQmatic dashboard interface. The top navigation bar includes the ABB logo, 'EQmatic', and menu items for 'Dashboard', 'Analytics', 'Management', and 'System'. The 'Dashboard' menu item is highlighted with a red box. The main content area shows a 'Configure - Instantaneous values' dialog box with the following settings:

- Building node: Light room 229
- Medium: Electricity
- Value to display: Active Imported Energy Total
- Chart type: Serial chart
- Custom name: Energy: Light in room 229

Below the configuration dialog, three widget views are shown for 'Energy: Light in room 229' as of 2018/09/05 08:49:08:

- Serial Chart:** A line chart showing 'Active imported Energy Total' over time. The y-axis ranges from 260Wh to 280Wh. The x-axis shows time intervals from 08:45:00 to 08:48:00. The energy value is shown increasing from approximately 270Wh to 280Wh.
- Gauge:** A circular gauge showing the current value of 270 Wh. The scale ranges from 0Wh to 1.08kWh.
- Single Value:** A large text display showing the current value of 270 Wh.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Widget – Usage Split

Used to display the relative distribution of total cost, income or CO₂ emissions

The values are displayed according to the selected time interval (day, month, etc.) and available consumer groups

The following options are available to configure the widget:

- Building node (selection of the meter or building section depending on the metering structure configured)
- Value to display (costs, income, CO₂)
- Custom name

The screenshot shows the ABB EQmatic dashboard interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard' (highlighted with a red box), 'Analytics', 'Management', and 'System'. The date and time '2017-11-12 17:45' are displayed on the right. Below the navigation bar, the 'Configure - Usage Split' dialog is open. It contains the following fields:

- * Building node: Building
- * Value to display: Cost
- Custom name: Cost overview: Floor no. 03

Buttons for 'Cancel' and 'Save' are visible at the bottom right of the configuration dialog. Below the configuration dialog, the 'Usage Split - Main building' widget is displayed. The widget title is 'Usage Split - Main building' and the subtitle is 'Cost overview: Floor no. 03'. The widget shows a donut chart with the following data:

Consumer Group	Percentage
Without Consumer Group (Electricity)	70.13%
Air con	25.07%
Light	4.79%

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Widget – Historical Data

Used to display historical total cost/ consumption data for a selected node or meter, by medium

The values are displayed according to the selected time interval (day, month, etc.).

The following options are available to configure the widget:

- Building node (selection of the meter or building section depending on the metering structure configured)
- Value to display (costs, consumption, generation, income, CO2, load profile)
- Medium (electricity, water, gas, ...)
- Chart type (line, column, smoothed line, step)
- Custom name

The screenshot shows the ABB EQmatic dashboard interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard' (highlighted with a red box), 'Analytics', 'Management', and 'System'. The date and time are 2017-11-12 17:45. The main content area displays the 'Configure - Historical Data' widget configuration form. The form includes the following fields:

- Building node:** Light room 229
- Value to display:** Load profile
- Medium:** Select...
- Chart type:** Line
- Custom name:** Energy: Light in room 229

Buttons for 'Cancel' and 'Save' are visible at the bottom right of the configuration form. Below the configuration form is a line chart titled 'Cost - Offices Floor no. 04'. The chart shows historical cost data in EUR over a 24-hour period. The y-axis ranges from 0 to 1.5 EUR, and the x-axis shows time intervals from 03:00 to 21:00 on Nov 12. The chart displays a blue line with a shaded area underneath, representing the cost profile. A 'Zoom out' button is located in the top right corner of the chart area.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”


Widget – Total Values

Used to display typical total values for a medium

The values and the relative changes between the current and the previous time interval are displayed

The following options are available to configure the widget:

- Building node (selection of the meter or building section depending on the metering structure configured)
- Medium (electricity, water, gas, ...)
- Value to display (cost, consumption, generation, income, CO2 emission)
- Custom name



The screenshot shows the ABB EQmatic Dashboard interface. The 'Dashboard' menu is highlighted in red. The configuration window for the 'Total values' widget is open, showing the following settings:

- Building node: AirCon offices floor no. 04
- Medium: Electricity
- Custom name: Type custom widget name...
- Cost:
- Consumption:
- Generation:
- Income:
- CO₂ emission:

Below the configuration window, a table displays the 'Total values' for the selected medium and building node:

PRESENTATION	VALUE	CHANGE
Cost	25,02 [EUR]	-36% ↓
Consumption	0,04 [kWh]	-18% ↓
CO ₂	30,06 [kg]	29% ↑

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Widget – Consumer Ranking

Used to display the highest consumers in an installation, by medium

A maximum of 5 consumers are displayed in the widget

The following options are available to configure the widget:

- Value to display (costs, consumption, generation, income, CO₂)
- Medium (electricity, water, gas, ...)
- Custom name

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard' (highlighted with a red box), 'Analytics', 'Management', and 'System'. The date and time are 2017-11-12 17:45. The main content area displays the 'Configure - Consumer Ranking' dialog box. The dialog has the following fields:

- *Value to display: Consumption
- *Medium: Electricity
- Custom name: Type custom widget name...


Buttons for 'Cancel' and 'Save' are at the bottom right of the dialog. Below the dialog is a preview of the 'Consumer Ranking' widget. The widget shows a horizontal bar chart with the following data:

Consumer	Consumption (kWh)
Offices Floo...	~180
AirCon offic...	~20
Lighting off...	~10

ABB EQmatic Energy Analyzer QA/S x.yy.1


Menu “Dashboard”

Add a widget

To add a widget to the dashboard, activate the edit mode (click the  button) and click the “Add Widget” button

This opens a dialog window containing available widgets

- Instantaneous Values
- Usage Split
- Historical Data
- Total Values
- Consumer Ranking



The screenshot shows the ABB EQmatic dashboard interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard' (highlighted with a red box), 'Analytics', 'Management', and 'System'. The date and time '2017-11-12 17:45' are displayed on the right. The dashboard area shows a 'Today' tab selected, with a large plus sign in a dashed box indicating where to click to add a widget. A red arrow points to the gear icon in the top right corner of the dashboard area. Another red arrow points to the 'Add widget' button in the bottom right corner of the dashboard area. Below the dashboard, a dialog window titled 'Add new widget' is shown, displaying four widget options: 'Instantaneous values', 'Usage Split', 'Historical Data', and 'Consumer Ranking'. The 'Total values' section is also visible in the dialog.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Add a widget

- ...
- Make the settings in the selected widget
- Save the widget or the settings using the “Save” button
- The widget will now be displayed on the dashboard





ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Configure a widget

To configure widgets, activate edit mode using the  button

Options:

- Place widget using drag & drop
- Enlarge/reduce widget
- Configure widget (opens a configuration window)
- Delete widget







ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Dashboard”

Configure a widget

1	Medium	This symbol indicates the selected medium in the widget.
2	Cross-hair 	Used to arrange the widget on the dashboard via drag & drop.
3	Widget Name	Using <i>Edit</i> , you can give the widget a unique name.
4	Edit	Opens a window where you can configure the widget.
5	Delete	Deletes widgets from the dashboard page.
6	Date/Time	Indicates the date and time when the widget was last updated. You can show/hide this with <i>Edit</i> .
7	Alarm	Indicates whether there is an alarm configured for the widget or measured value; this is only possible with widgets for instantaneous values. Clicking the icon opens the alarm configuration window. → More details in menu “Analytics” – “Alarms”
8	Customize 	Used to enlarge/reduce the widget via drag & drop.
9	Value display	How the measured value appears in the display depends on how the widget is configured (as a gauge chart, serial chart or value).



Commissioning

Main menu “Analytics”

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Analytics

The analysis functions are used for the detailed examination and representation of costs, consumption figures and other measured values

The following analyses can be performed:

- Historical Data
- Usage Split
- Instantaneous Values
- Benchmark - Period
- Benchmark - Consumer
- Reports
- Alarms




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Historical Data

For analysis and display of historical data

- Measured data for evaluation are not yet available to the system after commissioning. The device saves data every 5 minutes, so measured data will be available after 5 minutes at the earliest
- The display of historical data also depends on the magnitude of the connected load and the meter’s transmission behavior/resolution
- The following prerequisites must be met to display measured data
- Devices are configured and ready for operation
- Metering structure is configured
- At the maximum system capacity, historical data can be stored for at least 3 years




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Analytics

For analysis and display of historical data

– The desired unit

- Cost
- Consumption
- Income
- CO₂
- Load profile (performance)

is displayed in

- one diagram (left Y-axis) or
- two diagrams (left and right Y-axes)

as

- Line
- Column
- Smoothed line
- Step




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Analytics

For analysis and display of data the desired unit can be displayed as

- Line
- Column
- Smoothed line
- Step




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Historical Data

1	Metering structure	Used to navigate and select a consumer or node. The metering structure must first be configured in Management > Metering Structure. Click the “<” icon to show or hide the metering structure.
2	Analysis functions	Menu for selecting the required analysis function. Options: <ul style="list-style-type: none"> • Historical Data • Usage Split • Instantaneous Values • Benchmark - Period • Benchmark - Consumer • Reports • Alarms
3	Media	Displays the media available in the system. Depending on the connected devices, the utilities electricity, water, gas and heat are displayed here. The devices must be assigned to a metering structure for this purpose. If devices have been assigned to consumer groups (e.g. lighting, electrical sockets, air conditioning, etc.), they can be recalled via the submenu
4	First axis settings	Used to select the required unit (e.g. costs, consumption, load profile, etc.) and to display it on the chart (e.g. column chart, line chart, load profile, etc.).
5	Second axis settings	Used to select the required unit (e.g. costs, consumption, etc.) and to display it on the chart (e.g. column chart, line chart, etc.).
6	Resolution	Resolution setting for the chart display; dependent on the time unit (day, week etc.) selected in Presets.
7	Actions	Used to select further data processing options (e.g. Save as image, Export to .xlsx, csv, Save as favorite, Print chart).
8	Chart area	Displays the data graphically. Click and drag or click a value on the chart to zoom.
9	Slider	Used to limit and move the required period.
10	Calendar function	Used to enter the required period (from/to).




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Usage Split

Used to analyze and display

- Cost
- Consumption
- Generation
- Income
- CO₂

per medium or consumer group

- Lighting
- Cooling
- Ventilation
- ...




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Usage Split

1	Metering structure	Used to navigate and select a consumer or node. The metering structure must first be configured in Management > Metering Structure. Click the icon to show or hide the metering structure.
2	Analysis functions	Menu for selecting the required analysis function. Options: <ul style="list-style-type: none"> • Historical Data • Usage Split • Instantaneous Values • Benchmark - Period • Benchmark - Consumer • Reports • Alarms
3	Media	Displays the media available in the system. Depending on the connected devices, the utilities electricity, water, gas and heat are displayed here. If devices have been assigned to consumer groups (e.g. lighting, electrical sockets, air conditioning, etc.), they can be recalled via the submenu.
4	Data Type	Used to select the required data type (e.g. costs, consumption etc.).
5	Resolution	Resolution setting for the chart display; dependent on the time unit (day, week etc.) selected in Presets.
6	Actions	Used to select further data processing options (e.g. Save as image, Export to .xlsx, csv, Save as favorite, Print chart).
7	Chart area	Displays the data graphically. Click and drag or click a value on the chart to zoom.
8	Slider	Used to limit and move the required period.
9	Calendar function	Used to enter the required period (from/to).
10	Presets	Selects and displays current day, week, month, year, all. Presets are shown dynamically, depending on the measuring period: Day: always visible; Week: after 2 days; Month: after 7 days; Year: after 6 months; All: Always visible




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Instantaneous Values

This function displays the instantaneous value for a single data point in real time

The value is displayed on a serial chart

You must first select the required metering point or meter in the metering structure

Depending on the meter's functionality, various data points are available for display

The values in the diagram are updated depending on:

- Baud rate of the devices
- Number of devices in the system
- Data resolution and transmission behavior of the M-Bus/Modbus/KNX meter
- The minimum update time is 5 seconds




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Instantaneous Values

1	Metering structure	Used to navigate and select a consumer or node. Click the “<” icon to show or hide the metering structure.
2	Analysis functions	Menu for selecting the required analysis function.
3	Media	Displays the media available in the system. Depending on the connected devices, the utilities electricity, water, gas and heat are displayed here.
4	Edit	Opens the window for selecting and adding available data points to the table for subsequent display.
5	Chart area	Graphically displays the data point selected on a serial chart.
6	Table	The meter data points are listed in the table depending on the functionality and the available meter data points selected.
7	Display	Clicking the icon displays the data point or measured value in the serial chart. If a data point is accompanied by the alarm icon, an alarm has been configured for it. Clicking the icon opens the alarm configuration window.




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Benchmark – Period

To compare a consumer or node over two time intervals (e.g. current month, previous month)

– The desired data type

- Cost
- Consumption
- Generation
- Income
- CO₂
- Load profile

is displayed as

- Line
- Column
- Smoothed line
- Step




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Benchmark – Period

1	Metering structure	Used to navigate and select a consumer or node. The metering structure must first be configured in Management > Metering Structure. Click the “<” icon to show or hide the metering structure.
2	Analysis functions	Menu for selecting the required analysis function. Options: <ul style="list-style-type: none"> • Historical Data • Usage Split • Instantaneous Values • Benchmark - Period • Benchmark - Consumer • Reports • Alarms
3	Media	Displays the media available in the system. Depending on the connected devices, the utilities electricity, water, gas and heat are displayed here. If devices have been assigned to consumer groups (e.g. lighting, electrical sockets, air conditioning, etc.), they can be recalled via the submenu .
4	Data type	Used to select the required data type (e.g. costs, consumption etc.).
5	Resolution	Resolution setting for the chart display; dependent on the time unit (day, week etc.) selected in Presets.
6	Actions	Used to select further data processing options (e.g. Save as image, Export to .xlsx, csv, Save as favorite, Print chart).
7	Chart area	Displays the data graphically. Click and drag or click a value on the chart to zoom.
8	Slider	Used to limit and move the required period.
9	Calendar function	Used to enter the required period (from/to).
10	Presets	Selects and displays current day, week, month, year, all. Presets are shown dynamically, depending on the measuring period




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Benchmark – Consumer

Used to compare up to 5 consumers or nodes over an time interval

– The desired data type

- Cost
- Consumption
- Generation
- Income
- CO₂
- Load profile

is displayed as

- Line
- Column
- Smoothed line
- Step




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Benchmark – Consumer

1	Metering structure	Used to navigate and select a consumer or node. The metering structure must first be configured in Management > Metering Structure. Click the “<” icon to show or hide the metering structure.
2	Analysis functions	Menu for selecting the required analysis function. Options: <ul style="list-style-type: none"> • Historical Data • Usage Split • Instantaneous Values • Benchmark - Period • Benchmark - Consumer • Reports • Alarms
3	Media	Displays the media available in the system. Depending on the connected devices, the utilities electricity, water, gas and heat are displayed here. If devices have been assigned to consumer groups (e.g. lighting, electrical sockets, air conditioning, etc.), they can be recalled via the submenu .
4	Data type	Used to select the required data type (e.g. costs, consumption etc.).
5	Resolution	Resolution setting for the chart display; dependent on the time unit (day, week etc.) selected in Presets.
6	Actions	Used to select further data processing options (e.g. Save as image, Export to .xlsx, csv, Save as favorite, Print chart).
7	Chart area	Displays the data graphically. Click and drag or click a value on the chart to zoom.
8	Slider	Used to limit and move the required period.
9	Calendar function	Used to enter the required period (from/to).
10	Presets	Selects and displays current day, week, month, year, all. Presets are shown dynamically, depending on the measuring period




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

This function allows to send analyses and evaluations to various recipients automatically

The data can be sent data either by e-mail and/or to an FTP server


Example: Send saved consumption figures or costs for a meter once a month to a recipient by e-mail in the file format “.xlsx” for further evaluation and archiving

Reports configured are displayed and managed in an overview table

To send emails, the settings for the SMTP server must have been made in the *System* menu

Note:

Available for QA/S 3.xx.1 M-Bus from version 2.0.0 and QA/S 1.16.1 KNX



The screenshot displays the ABB EQmatic web interface. The top navigation bar includes 'Dashboard', 'Analytics' (highlighted with a red box), 'Management', and 'System'. The right side of the bar shows the date '2018-09-05 12:21' and a star icon. Below the navigation bar, a secondary menu contains 'Historical Data', 'Usage Split', 'Instantaneous Values', 'Benchmark - Period', 'Benchmark - Consumer', 'Reports' (highlighted with a red box), and 'Alarms'. The main content area is titled 'Configuration' and features a 'Report recipients' section. This section includes a search bar, a 'Refresh' button, and an 'Add' button. Below these elements is a table with the following columns: RECIPIENTS, TYPE, STATUS, NEXT REPORT ON, LAST REPORT ON, PERIOD, RESOLUTION, MEDIUM, FORMAT, and ACTION. The table currently displays 'No items to show'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

Configuration of a report:

- There are various parameters available to help you configure reports
- Enter the required values and parameters in the window and save the report

1	Name	Enter report name.
2	Recipients	Configure report recipients (email or FTP).
3	Values	Select the values to be sent in the report (e.g. consumption, costs). Multiple selection possible.
4	Nodes	Select the required node or meter. Multiple selection possible.
5	Medium	Select the medium (e.g. electricity, gas, water, heat). Multiple selection possible.
6	Resolution	Select the data resolution for the report (e.g. hourly, daily).
7	Format	Select the file format for the report (e.g. XLSX, CSV).
8	Filename	Enter the filename.
9	Period	Select the sending interval or period for the report (e.g. 1 x / week).
10	Send on	Set when the report is to be sent for the first time.
11	End on	Set when the report is to be sent for the last time.

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics' (highlighted with a red box), 'Management', and 'System'. Below this, a sub-navigation bar contains 'Historical Data', 'Usage Split', 'Instantaneous Values', 'Benchmark - Period', 'Benchmark - Consumer', and 'Reports' (highlighted with a red box). The main content area displays a 'Report' configuration window with 11 numbered fields: 1. Name (text input), 2. Recipients (select dropdown), 3. Values (select dropdown), 4. Nodes (select dropdown), 5. Medium (select dropdown), 6. Resolution (select dropdown), 7. Format (select dropdown, currently XLSX), 8. Filename (text input), 9. Period (select dropdown, currently type), 10. Send on (calendar icon), 11. End on (calendar icon). At the bottom right of the window are 'Cancel' and 'Save' buttons.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

Recipient of the report: Email

The screenshot shows a 'Report edit' dialog box with a 'Report recipients' section. The 'Type' dropdown is set to 'EMAIL'. The 'Address' field contains 'juergen.schilder@de.abb.com'. The 'Name' field contains 'QA/S: Daily report of load profile "Main Building"'. At the bottom right of the dialog are three buttons: 'Cancel', 'Ping', and 'Save'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

Recipient of the report: FTP server

Report recipients

* Type
FTP

* Address
192.168.1.12

Name
test

Login
ABB

Password

Directory
/home/QAS/

Success. Destination is available.

Cancel Ping Save

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

The report “Daily load profile: Main building” will be sent daily via email and FTP with the values “Load profile” of the nodes “main building” and “Sockets outlets”

The screenshot shows the 'Report' configuration window with the following fields and values:

- Name:** Daily load profile: Main building
- Recipients:** QA/S: Daily report of load profile "Main Building" (EMAIL: juergen.schilder@de.abb.com) | FTP storage (FTP: 192.168.1.12)
- E-mail subject:** Daily load profile: Main building
- E-mail body:** Hello ...
- Values:** Load profile
- Nodes:** Main building | Socket outlets, ...
- Medium:** Electricity
- Resolution:** 5 minutes
- Period:** 1 Day
- Send on:** 2018/09/06
- End on:** (empty)
- Format:** XLSX
- Filename:** Main Building - daily report of load profile
- Example filename:** Main Building - daily report of load profile-electricity-2018-09-06.xlsx


Buttons: Cancel, Save

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

Overview of all reports incl. recipients



The screenshot shows the ABB EQmatic Analytics interface. The top navigation bar includes 'Dashboard', 'Analytics' (highlighted with a red box), 'Management', and 'System'. The date is 2018-09-05 12:21. Below the navigation bar, there are tabs for 'Historical Data', 'Usage Split', 'Instantaneous Values', 'Benchmark - Period', 'Benchmark - Consumer', 'Reports' (highlighted with a red box), and 'Alarms'. The main content area is titled 'Configuration' and contains a section for 'Reports' with a sub-tab 'Report recipients'. There is a search bar and a '+ Add' button. A table lists report recipients with columns for RECIPIENTS, TYPE, STATUS, NEXT REPORT ON, LAST REPORT ON, PERIOD, RESOLUTION, MEDIUM, FORMAT, and ACTION. The table shows two entries for 'Daily load profile: Main building'.

RECIPIENTS	TYPE	STATUS	NEXT REPORT ON	LAST REPORT ON	PERIOD	RESOLUTION	MEDIUM	FORMAT	ACTION
Daily load profile: Main building									
192.168.1.12	FTP	OK	2018-09-06	-	a day	5 minutes	Electricity	XLSX	X
juergen.schilder@de.abb.com	EMAIL	OK	2018-09-06	-	a day	5 minutes	Electricity	XLSX	X


ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Reports

Received email with the values “Load profile” of the nodes “main building” and “Sockets outlets”

Resolution 5 min.



	A	B	C	D
1	Timestamp	Main building Load Profile (kW)	Socket outlets, ... Load Profile (kW)	Sum (kW)
2	2018-09-05 00:00	0,41547	0,35611	0,77158
3	2018-09-05 00:05	0,42000	0,36019	0,78019
4	2018-09-05 00:10	0,45489	0,39668	0,85157
5	2018-09-05 00:15	0,44738	0,38955	0,83693
6	2018-09-05 00:20	0,47773	0,42043	0,89816
7
286	2018-09-05 23:40	0,48005	0,41979	0,89984
287	2018-09-05 23:45	0,48005	0,41607	0,89612
288	2018-09-05 23:50	0,48000	0,41835	0,89835
289	2018-09-05 23:55	0,43486	0,37183	0,80669

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Alarms

This function can be used to configure one or more limit values for each measured value

If the limit is exceeded, an alarm function can be configured and a choice can be made between different actions (notification in the dashboard and/or sending an email)

If an alarm occurs, the configured action is carried out and the occurrence of the alarm is written to the event log

Configured alarms are displayed and managed in an *Alarms* overview table

Any number of alarms can be configured

The occurrence of an alarm is managed in the event memory in the *Alarm Events* table







ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu "Load control"

Dashboard



Notification when the value is "<" or ">" than the alarm limit



Alarm category

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Alarms – Configuring via the analytics function

The Actions button provides the following options:

- Create: Opens the alarm configuration window
- Remove: Deletes the alarms selected using the check boxes in the overview table, removing them from the overview and the system
- Activate: Primes the alarms selected using the check boxes in the overview table
- Enable UI Notifications: Switches on UI pop-up notifications for the alarms selected using the check boxes in the overview table.
- Disable UI Notifications: Switches off UI pop-up notifications for the alarms selected using the check boxes in the overview table.




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Alarms – Configuring via the dashboard

Activate the edit mode in the dashboard and click on the “Configure Widget” button

Go to “Alarm” and click the “Add” button

The alarm configuration window opens
(as for configuring via the analytics function)




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Alarms – Configuring window

1	Name	Enter a name for the alarm.
2	Building node	Select the building node or associated meter/device.
3	Value Type	Select the data point (e.g. active power) for the alarm configuration.
4	Alarm enabled	Prime the alarm using the slider.
5	Schedule	Configure a period (start and stop dates) during which you want the alarm to be active. Leaving the stop date empty leaves the alarm enabled indefinitely.
6	Active days	Select the weekdays when you want the alarm to be active.
7	Auto Scale	Where there are several threshold values configured, clicking this distributes them evenly along the threshold line.
8	Alarm limits	<p>Clicking a point (threshold value) on the line provides additional parameters for entering the threshold value and reaction times.</p> <p>A threshold can be moved along the line using drag & drop. You can add as many thresholds as necessary by mousing over the line. A new point (threshold) appears; click to configure it.</p> <p>Each threshold value or range must be assigned an alarm category by clicking :</p> <ul style="list-style-type: none"> • Error (red) • Warning (orange) • Note (blue) <p>The alarm category color codes are carried over to the widget display and Alarm Events table.</p> <p>If you choose a serial chart as a widget, the configured alarm thresholds are displayed as broken lines in the chart.</p>
...		




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”


Alarms – Configuring window

...		
9	Severity	Alarm priority specification. Options: <ul style="list-style-type: none">• High• Medium• Low
10	Send UI notifications Send E-mail notifications	To activate the relevant notification(s), select the check boxes. If an alarm occurs, the pop-up notification appears in the Information icon. To receive email notifications you need to enter SMTP settings. You can enter a custom message for each notification. Aside from this, the email will contain details about the alarm: <ul style="list-style-type: none">• Date/Time• Building node• Value Type• Threshold exceeded• Alarm category and severity
11	Save	Saves the current configurations. The configured alarm appears in the Alarms overview table.


ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”


Alarms – Dashboard values and UI notifications



Alarm category “Note” (blue)



Alarm category “Warning” (orange)



Alarm category “Error” (red)

Alarm limits:




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”


Alarm events

Alarm events are managed and displayed in an overview table showing when each alarm occurred and when it was cleared

The alarms overview can be exported in various formats

- XLSX
- CSV
- JSON

for further processing



The screenshot shows the ABB EQmatic Analytics interface. The 'Analytics' menu is highlighted in the top navigation bar. Below it, the 'Alarms' section is active, and the 'Alarm Events' sub-menu is selected. A table displays a list of alarm events with columns for Category, Severity, Alarm Name, Value Type, Value, Node, and Created On. The table contains seven rows of data, including errors for voltage low and warnings for power blower room power total.

	CATEGORY	SEVERITY	ALARM NAME	VALUE TYPE	VALUE	NODE	CREATED ON
<input type="checkbox"/>	Error	High	Voltage low	Voltage L1	230.60000610351562 V	Meter Interface 1: B21-113-100	17/01/2020 10:34:12
<input type="checkbox"/>	Warning	High	Power Blower room 3-001	Active Imported Power Total	14.90999984741211 W	Meter Interface 1: B23-112-100	17/01/2020 10:34:11
<input type="checkbox"/>	Warning	High	Power Blower room 3-001	Active Imported Power Total	14.90999984741211 W	Meter Interface 1: B23-112-100	17/01/2020 10:34:01
<input type="checkbox"/>	Error	High	Voltage low	Voltage L1	230.60000610351562 V	Meter Interface 1: B21-113-100	17/01/2020 10:34:00
<input type="checkbox"/>	Error	High	Voltage low	Voltage L1	230.60000610351562 V	Meter Interface 1: B21-113-100	17/01/2020 09:08:38
<input type="checkbox"/>	Ok	High	SE/S Leistung	Active Imported Power Total	38.99700164794922 W	Energy Actuator 1: SE/S	14/01/2020 12:09:19

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Actions

Available in the menu:

- Historical Data
- Usage Split
- Benchmark - Period
- Benchmark - Consumer

Used to select further data processing options

- Save as image
- Export to file
- Save as favorite
- Print
- Create report




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Actions – Save as image

The diagram of the consumer or node selected in the metering structure is saved as a graphic file in the format

- PNG
- JPG

over the selected time interval




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Actions – Export to file

The historical data of the consumer or node selected in the metering structure are exported over the selected time interval as

- PDF
- XLSX
- CSV
- JSON

The screenshot displays the ABB EQmatic Analytics interface. The 'Analytics' menu is highlighted in the top navigation bar. The 'Actions' dropdown menu is open, showing options: 'Save as image', 'Export to file', 'Save as favourite', 'Print', and 'Create Report'. The 'Export to file' option is selected, opening a sub-menu with options: 'PDF', 'XLSX', 'CSV', and 'JSON'. A red box highlights the 'Export to file' sub-menu. The main interface shows a line graph of 'Average Power: 1 [kW]' over time, with a table of data below it.

Date	Electricity [W]
2017-08-26 00:00	550,38
2017-08-26 00:05	515,30
2017-08-26 00:10	522,57
2017-08-26 00:15	600,13
2017-08-26 00:20	519,15
2017-08-26 00:25	564,46
2017-08-26 00:30	558,90
2017-08-26 00:35	512,73
2017-08-26 00:40	482,11
2017-08-26 00:45	440,94
2017-08-26 00:50	424,90
2017-08-26 00:55	415,44
2017-08-26 01:00	401,03
2017-08-26 01:05	438,66
2017-08-26 01:10	400,65
2017-08-26 01:15	390,95

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Actions – Save as favorite

The consumer or node selected in the metering structure is saved in the *Favorites* bar with the time interval




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”

Actions – Print

The diagram of the consumer or node selected in the metering structure is printed over the selected time interval




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Analytics”


Actions – Report

This function allows to send analyses and evaluations to various recipients automatically

The data can be sent data either by e-mail and/or to an FTP server

- There are various parameters available to help you configure reports
- Enter the required values and parameters in the window and save the report

More information in the “*Analytics* → *Reports*” menu



Commissioning

Main menu “Load control”

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu "Load control" (only for QA/S 1.16.1 KNX)

Load control

With the Load Control Management function, load shedding sequences can be prioritized based on the electrical power values received from electricity meters

In order to be able to display and operate the load control via the user interface, it must first be activated in the ETS using the "Enable laser control" parameter




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

Load control is a function that enables an Energy Analyzer QA/S 1.16.1 KNX to manage an electrical installation energy-efficiently based on an adjustable load limit, by sending switching commands to KNX

The Energy Analyzer (master) ① receives power values from up to 16 energy meters ② ③ (slaves, e.g. SE/S, EM/S, ZS/S and third party)

The values are then internally added to the total power value




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

Load control is a function that enables an Energy Analyzer QA/S 1.16.1 KNX to manage an electrical installation energy-efficiently based on an adjustable load limit, by sending switching commands to KNX

The Energy Analyzer (master) ① receives power values from up to 16 energy meters ② ③ (slaves, e.g. SE/S, EM/S, ZS/S and third party)

The values are then internally added to the total power value

If the sum of the power values exceeds the user-defined load limit setting, the device sends shedding stages ④ to KNX

All ABB devices (e.g. Energy Actuator SE/S 3.16.1) featuring the “Receive shedding stages” group object (DPT 236.001) are suitable for use with the load shedding function




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

The Energy Actuator ③ features power measurement and a switch actuator function

As a result, it can send power values to the load control function and at the same time, receive shedding stages to switch connected consumers on and off

This means that a shedding stage can be set in the Energy Actuator for each output

The slave receives the shedding stage and switches all outputs set with this stage




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

The Energy Actuator **3** features power measurement and a switch actuator function

As a result, it can send power values to the load control function and at the same time, receive shedding stages to switch connected consumers on and off

This means that a shedding stage can be set in the Energy Actuator for each output

The slave receives the shedding stage and switches all outputs set with this stage

Devices **6** (e.g. switch actuators) without the “*Receive shedding stages*” group object can still be integrated in load control using the 1-bit group objects “*Send load shedding stage 1...8*” **5**

The master increases the shedding stage until “Send sum power values” falls back below the load limit




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

How load control works

The number of shedding stages that load control (the master) can send is defined based on the number of priority stages to be switched on the meters (slaves)

For instance, if a system has only two priority stages (where priority 1 is always on and priority 2 can be switched off as necessary), one load shedding stage is enough

In the master, you can set a load limit that must not be exceeded

Alternatively there is a load limit that can be changed via KNX

As a rule, the power values received from the slaves should be sent with a change

When the master then receives a new power value, the sum of the values is recalculated and if applicable, a shedding stage sent to KNX

The cyclic monitoring time can be enabled

The screenshot shows the configuration page for '1.1.21 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Load Control'. The 'Load Control' tab is selected and highlighted with a red box. The configuration is organized into a table with columns for meter identification and specific settings.

Meter	Parameter	Value
General	Enable load control	<input type="radio"/> No <input checked="" type="radio"/> Yes
	Note: At least one electricity meter must send power values to load control. Set parameter "Send power values to load control" in corresponding electricity meter(s).	
+ Meter 1	Number of load shedding stages	2
+ Meter 2	Load limit	150 W
+ Meter 3	Change load limit via Group object	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 4	Reaction time when exceeding load limit	2 s
+ Meter 5	Reaction time when falling below load limit	30 s
+ Meter 6	Hysteresis at restart attempt in % of load limit	0 %
+ Meter 7	Change load limit, hysteresis and reaction times via user interface	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 8	Overwrite load limit, hysteresis and reaction times with download	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 9	Value Group object "Deactivate load control" at restart	<input type="radio"/> 0 = load control activated <input checked="" type="radio"/> 1 = load control deactivated

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

How load control works

Set the over/underlimit reaction times according to how quickly you wish the system to react

If the load limit is exceeded, shedding stage 1 is sent to KNX after the overlimit reaction time

If the load then exceeds the limit again, the next shedding stage up is sent after the reaction time, and so on, until the load falls back below the limit

Once the reaction time has run after the load falls below the limit, the master reduces the shedding stage (attempted restart)

Take account of relay lifetime when setting reaction times

Set up the system so that load control is only active at peak times, or set long enough over/underlimit reaction times to prevent excessive switching

1.1.21 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Load Control

General	Enable load control	<input type="radio"/> No <input checked="" type="radio"/> Yes
Load Control	Note: At least one electricity meter must send power values to load control. Set parameter "Send power values to load control" in corresponding electricity meter(s).	
+ Meter 1	Number of load shedding stages	2
+ Meter 2	Load limit	150 W
+ Meter 3	Change load limit via Group object	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 4	Reaction time when exceeding load limit	2 s
+ Meter 5	Reaction time when falling below load limit	30 s
+ Meter 6	Hysteresis at restart attempt in % of load limit	0 %
+ Meter 7	Change load limit, hysteresis and reaction times via user interface	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 8	Overwrite load limit, hysteresis and reaction times with download	<input type="radio"/> No <input checked="" type="radio"/> Yes
+ Meter 9	Value Group object "Deactivate load control" at restart	<input type="radio"/> 0 = load control activated <input checked="" type="radio"/> 1 = load control deactivated

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

How load control works – QA/S Meter settings

The meters must be set which power values should be sent internally to the load control and taken into account in the calculation

For example:

- Meter Interface ZS/S1.1: 4-wire meter (B23-112-100):
 - No, Sum of all phases, Phase 1, Phase 2, Phase 3; Phase 1&2, Phase 1&3 and Phase 2&3
- Meter Interface ZS/S1.1 : 2-wire meter (B21-113-100)
 - Yes or No
- Energy Actuator SE/S3.16.1:
 - No, Total, Channel A, Channel B, Channel C; Channel A&B, Channel A&C and Channel B&C
- Energy Module EM/S3.16.1:
 - No, Total, Channel A, Channel B, Channel C; Channel A&B, Channel A&C and Channel B&C




ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

How load control works – Settings Energy Actuator

The following parameters must be set in the Energy Actuator SE/S for each output

- Load shedding stage: Options: 1...8
(at which shedding stage the output is switched off)
- Shedding stage can be changed via object: No or Yes
- Slave is controlled via “external object” (send by QA/S)
- Behaviour at recovery of bus voltage

1.1.34 SE/S3.16.1 Energy Actuator,3-fold,16/20A,MDRC > A: Load control slave

A: Load control slave	Load shedding stage output [1...8]	1
B: General	Load shedding stage can be changed via object	<input checked="" type="radio"/> no <input type="radio"/> yes
B: Function	Slave is controlled via	<input checked="" type="radio"/> external object <input type="radio"/> receives load shedding stage internally
B: Metering (Wh)	Enable object "Receive load shedding stage" on "Function"	<--- NOTE
B: Instrument and power values	Object "Deactivate load control" (slave) at recovery of bus voltage	unchanged

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX) – Assignment of group addresses: Power values

Energy Analyze QA/S1.16.1	Meter 1: ZS/S – Active Power Total	←	Power value – Active power total	Meter Interface ZS/S 1.1 4-wire EQmeter “B22 113 100”
	Meter 1: ZS/S – Active Power L1	←	Power value – Active power L1	
	Meter 1: ZS/S – Active Power L2	←	Power value – Active power L2	
	Meter 1: ZS/S – Active Power L3	←	Power value – Active power L3	
	Meter 1: ZS/S – ...			
	Meter 2: ZS/S – Active Power	←	Power value – Active power	Meter Interface ZS/S 1.1 2-wire EQmeter “B21 113 100”
	Meter 2: ZS/S – ...			
	Meter 3: SE/S – Active Power	←	Active power total	Energy Actuator SE/S3.16.1
	Meter 3: SE/S – A: Active Power	←	A: Active Power	
	Meter 3: ZS/S – B: Active Power	←	B: Active Power	
	Meter 3: ZS/S – C: Active Power	←	C: Active Power	
	Meter 3: SE/S – ...			
	Meter 4: ES/S – Active Power	←	Active power total	Energy Module EM/S3.16.1
	Meter 4: ES/S – A: Active Power	←	A: Active Power	
	Meter 4: ES/S – B: Active Power	←	B: Active Power	
	Meter 4: ES/S – C: Active Power	←	C: Active Power	
Meter 4: ES/S – ...				
Meter 5: Gen.EL– Active Power Total	←	Power value – Active power total	Energy Meter: Generic 4-wire meter	
Meter 5: Gen.EL– Active Power L1	←	Power value – Active power L1		
Meter 5: Gen.EL– Active Power L2	←	Power value – Active power L2		
Meter 5: Gen.EL– Active Power L3	←	Power value – Active power L3		
Meter 5: Gen.EL– ...				

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX) – Assignment of group addresses





ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

1	Load control status overview	<p>Displays the load control status options and present measured values or settings</p> <ul style="list-style-type: none">• Status<ul style="list-style-type: none">• Disabled: Load control is not enabled via ETS• Stopped: Load control has been stopped (via ETS or the UI)• Ideal: Total power is within the load limit and no shedding stage is active• Over Limit: Total power is above the load limit• Under Limit: Total power is within the load limit and at least one shedding stage is active• Between: Total power is above the load limit minus the hysteresis and at least one shedding stage is active• Total power: Displays the total power (in kW) of the meters/slaves sending their values to load control• Shedding Stage: Displays the present shedding stage (0–8)
2	Start/Stop	Slider for activating load control
3	Chart of current power	<p>Blue line: current power</p> <p>Red line: load limit</p> <p>Broken gray line: hysteresis</p>
4	Edit	The values for <i>Load limit</i> , <i>Hysteresis</i> and <i>Overlimit/Underlimit time</i> can be changed with the <i>Edit</i> function. The load limit and hysteresis in the chart can be changed using drag & drop.
5	Meter/slave overview	<p>The meters listed here are sending their power values for inclusion in the total power calculation and are taken into account in load control.</p> <p>Click the “>” icon to show or hide the table.</p>
...		



Load control is enabled

ABB EQmatic Energy Analyzer QA/S x.yy.1

Menu “Load control” (only for QA/S 1.16.1 KNX)

Load control

...		
6	Load limit	Enter the desired load limit here
7	Hysteresis	If the system is often overloaded during operation, the hysteresis can prevent a shedding stage from repeatedly switching on and off. The hysteresis is subtracted from the load limit. The shedding stage is not reduced again until the system falls below the load limit minus the hysteresis.
8	Overlimit time	If the sum of the power values exceeds the set load limit, load control sends shedding stages to the bus based on the time set here. The shedding stage increases until the power falls below the load limit. The reaction time restarts before each stage increase.
9	Underlimit time	If the power falls back below the limit (i.e. if enough slaves were switched off), the master waits for the length of time set here and then starts reducing the shedding stages in reverse order until it reaches stage 0 (i.e. all slaves are enabled) or the load limit is exceeded again.
	Save	<p>Saves the settings after you edit the following parameters:</p> <ul style="list-style-type: none"> • Load limit • Hysteresis • Overlimit time • Underlimit time

Edit mode (load control is disabled)

Commissioning

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Commissioning

To display and process the QA/S values of KNX meters, both the QA/S and the KNX meters must first be configured and parametrized in ETS

- Add the QA/S and KNX meters to the project
- Set the parameters of the QA/S and KNX meters, e.g.
 - Date and time source (KNX, User Interface or time server)
 - Meter settings: Meter Interface Module ZS/S, Energy Actuator SE/S, Energy Module EM/S, Electricity (generic), Gas (generic), Water (generic), Heat (generic)
 - Load control
- Assign group addresses
- Download individual address and application programs




ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: General

1	<u>Device name</u> In this field, you can enter a unique name for the device. It is used for identification purposes, for example, if there are several identical energy analyzers in a single installation. The name entered here appears in the i-bus® Tool and UI under System Information
2	<u>Send delay after bus voltage recovery</u> <ul style="list-style-type: none">• 2...255 s
3	<u>Enable group object "In operation"</u> <ul style="list-style-type: none">• No• Yes – send with value 0 or 1 This parameter enables the In operation group object. This group object signals the presence of the device on KNX and can be monitored by an external device.
4	<u>Cycle time</u> <ul style="list-style-type: none">• 1 ... 65535 s This parameter determines the interval at which the In operation group object sends a telegram.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > General

General

1 Device name: Energy Analyzer Room 224 JueSch

2 Send delay after bus voltage recovery: 2 s

3 Enable Group object "In operation": Yes - send with value 0

4 Cycle time: 60 s

Limit number of telegrams: No Yes

Date and time source: KNX User Interface

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: General

5	<u>Limit number of telegrams</u> <ul style="list-style-type: none">NoYes and max. number of sent telegrams This parameter determines whether the number of telegrams the device sends to the bus is limited (telegram rate limitation)
6	<u>Date and time source</u> <ul style="list-style-type: none">KNXUser Interface This parameter determines how the device's system time is received <ul style="list-style-type: none">KNX: The system time is received via a clock in the KNX installation.User Interface: The system time has to be set via the UI in System > Date and Time

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > General

General

Device name: Energy Analyzer Room 224 JueSch

Send delay after bus voltage recovery: 2 s

Enable Group object "In operation": Yes - send with value 0

Cycle time: 60 s

Limit number of telegrams: No Yes

Date and time source: KNX User Interface

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Load control

1	<p><u>Enable load control</u></p> <p>This parameter enables the Load Control function. Enabling the function shows the parameters and associated group objects.</p> <ul style="list-style-type: none">No: The Load Control function is not enabled.Yes: The Load Control function is enabled in ETS and in the UI
2	<p><u>Number of load shedding stages</u></p> <ul style="list-style-type: none">1...2...8 <p>This parameter determines how many load shedding stages are used. Each slave assigned to load control is assigned, according to priority, to a shedding stage. If the load limit is exceeded, load control sends shedding stages to the bus. Starting with stage 1, the shedding stage is increased until the load is back within the limit. If the load drops below the limit, the shedding stage is reduced again.</p>
3	<p><u>Load limit</u></p> <ul style="list-style-type: none">1....200000.000 W <p>This parameter defines the load limit for the overall system</p>
4	<p><u>Change load limit via Group object</u></p> <p>This parameter enables the Send/receive load limit group object, which changes the load limit parametrized in ETS.</p> <ul style="list-style-type: none">No: The load limit can only be changed in ETS.Yes: The Send/receive load limit group object is enabled.

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Load control

5	<p><u>Reaction time when exceeding load limit</u></p> <ul style="list-style-type: none">Options: 2...60 s <p>This parameter determines at what point load control starts sending load shedding stages if the load limit is exceeded. If the sum of the power values exceeds the set load limit, load control sends shedding stages to the bus based on the time set here. The shedding stage increases until the power falls below the load limit. The reaction time restarts before each stage increase</p>
6	<p><u>Reaction time when falling below load limit</u></p> <ul style="list-style-type: none">30...65535 s <p>This parameter determines at what point load control starts reducing the shedding stages if the power falls below the load limit. If the power falls back below the limit (i.e. if enough slaves were switched off), load control waits for the length of time set here and then starts reducing the shedding stages in reverse order until it reaches stage 0 (i.e. all slaves are enabled) or the load limit is exceeded again.</p>
7	<p><u>Hysteresis at restart attempt in % of load limit</u></p> <ul style="list-style-type: none">Options: 0...100 % <p>This parameter determines the hysteresis for an attempted restart. If the system is often overloaded during operation, the hysteresis can prevent a shedding stage from repeatedly switching on and off. The hysteresis is subtracted from the load limit. The shedding stage is not reduced again until the system falls below the load limit minus the hysteresis</p>

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Load Control

General	Enable load control	<input type="radio"/> No <input checked="" type="radio"/> Yes
Load Control	Note: At least one electricity meter must send power values to load control. Set parameter "Send power values to load control" in corresponding electricity meter(s).	
Meter 1	Number of load shedding stages	8
ZS/S	Load limit	150 W
Meter 2	Change load limit via Group object	<input type="radio"/> No <input checked="" type="radio"/> Yes
ZS/S	5 Reaction time when exceeding load limit	2 s
ZS/S	6 Reaction time when falling below load limit	30 s
Meter 3	7 Hysteresis at restart attempt in % of load limit	0 %
SE/S	Change load limit, hysteresis and reaction times via user interface	<input type="radio"/> No <input checked="" type="radio"/> Yes
Meter 4	Overwrite load limit, hysteresis and reaction times with download	<input type="radio"/> No <input checked="" type="radio"/> Yes
EM/S	Value Group object "Deactivate load control" at restart	<input type="radio"/> 0 = load control activated <input checked="" type="radio"/> 1 = load control deactivated

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Load control

8	<p>Change load limit, hysteresis and reaction times via user interface</p> <ul style="list-style-type: none">• No• Yes <p>This parameter determines whether the load limit, hysteresis and reaction times can be changed via the UI</p>
9	<p>Overwrite load limit, hysteresis and reaction times with download</p> <ul style="list-style-type: none">• No• Yes <p>This parameter determines whether the values entered in the UI for load limit, hysteresis and reaction times are applied in ETS when there is a download.</p>
10	<p>Value Group object "Deactivate load control" at restart</p> <ul style="list-style-type: none">• 0 = Load control activated• 1 = Load control deactivated <p>This parameter determines the value written to the "Deactivate load control" group object after a device restart.</p>

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Load Control

General

Enable load control No Yes

Load Control

Note: At least one electricity meter must send power values to load control.
Set parameter "Send power values to load control" in corresponding electricity meter(s).

Meter 1

Number of load shedding stages 8

ZS/S

Load limit 150 W

Change load limit via Group object No Yes

Meter 2

Reaction time when exceeding load limit 2 s

ZS/S

Reaction time when falling below load limit 30 s

Meter 3

Hysteresis at restart attempt in % of load limit 0 %

SE/S

8 Change load limit, hysteresis and reaction times via user interface No Yes

Meter 4

9 Overwrite load limit, hysteresis and reaction times with download No Yes

EM/S

10 Value Group object "Deactivate load control" at restart 0 = load control activated 1 = load control deactivated

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Meter “ZS/S Meter Interface Module”

1	<p><u>Device selection</u></p> <ul style="list-style-type: none">• None• ABB: ZS/S Meter Interface Module• ABB: SE/S Energy Actuator• ABB: EM/S Energy Module• Electricity (generic)• Gas (generic)• Water (generic)• Heat (generic)• Measurement <p>This parameter determines which type of meter is read. It shows meter-specific parameter windows according to the option selected. These are explained in the sections that follow.</p>
2	<p><u>Name</u></p> <p>This field lets you enter a unique name for the meter interface module or the meter you wish to read. It is used for identification purposes, for example, if there are several identical meter interface modules in a single installation. The name you enter will appear in the UI in Management > Meter Management</p>
3	<p><u>Location</u></p> <p>Here you can enter the installation location for the meter interface module. It is used for location purposes, for example, if there are several identical meter interface modules in a single installation. The installation location you enter will appear in the UI in Management > Meter Management</p>

1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 1 > ZS/S

General	1 Device selection	ABB: ZS/S Meter Interface Module
Load Control	2 Name	Meter Interface 1: B23-112-100
Meter 1	3 Location	Training Board (1)
Meter 2	Serial number	85674123
ZS/S	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
Meter 3	Monitor "In Operation" Group object	Yes, value 0
SE/S	Cycle time	60 s
Meter 4	Meter type	A4x (A-Series), B2x (B-Series)
EM/S	Version	Active energy meter (direct connected)
Meter 5	Voltage network	4-Wire (L1, L2, L3, N)
	Tariffs	<input checked="" type="radio"/> No tariffs <input type="radio"/> 4 tariffs
	Register for exported energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
	Send power values to load control	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Meter “ZS/S Meter Interface Module”

4	<p><u>Serial number</u></p> <p>This field lets you enter a serial number or ID number for the meter interface module. This is another way to identify it if there are several identical meter interface modules in a single installation. The serial number you enter will appear in the UI in Management > Meter Management</p>
5	<p><u>Enable Group object "Request meter/sensor reading"</u></p> <p>This parameter determines whether meter readings are received via a separate group object.</p> <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.
6	<p><u>Monitor "In Operation" Group object</u></p> <p>This parameter determines whether the In operation group object monitors the presence of the ZS/S on the bus.</p> <ul style="list-style-type: none">• No: No monitoring• Yes, value 0: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 telegram from the ZS/S within the cycle time.• Yes, value 1: Shows the In operation group object and the Cycle time parameter. The group object expects a value 1 telegram from the ZS/S within the cycle time.• Yes, both values: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 or 1 telegram from the ZS/S within the cycle time.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 1 > ZS/S

General	Device selection	ABB: ZS/S Meter Interface Module
Load Control	Name	Meter Interface 1: B23-112-100
	Location	Training Board (1)
Meter 1	Serial number	85674123
ZS/S	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
Meter 2	Monitor "In Operation" Group object	Yes, value 0
ZS/S	Cycle time	60 s
Meter 3	Meter type	A4x (A-Series), B2x (B-Series)
SE/S	Version	Active energy meter (direct connected)
Meter 4	Voltage network	4-Wire (L1, L2, L3, N)
Meter 4	Tariffs	<input checked="" type="radio"/> No tariffs <input type="radio"/> 4 tariffs
EM/S	Register for exported energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
Meter 5	Send power values to load control	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Meter “ZS/S Meter Interface Module”

7	<u>Meter type</u> A4x (A-series), B2x (B-series) The Energy Analyzer QA/S can only be used in conjunction with type A4x (A-Series) and B2x (B-Series) meters. The meters must be parametrized in the ZS/S.
8	<u>Version</u> <ul style="list-style-type: none">• Active energy meter (direct connected)• Active energy meter (transformer rated)• Combination meter (direct connected)• Combination meter (transformer rated)
9	<u>Voltage network</u> <ul style="list-style-type: none">• 2-Wire (L, N)• 3-Wire (L1, L2, L3)• 4-Wire (L1, L2, L3, N)

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 1 > ZS/S

General	Device selection	ABB: ZS/S Meter Interface Module
Load Control	Name	Meter Interface 1: B23-112-100
	Location	Training Board (1)
	Serial number	85674123
	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
	Monitor "In Operation" Group object	Yes, value 0
	Cycle time	60 s
	Meter type	A4x (A-Series), B2x (B-Series)
	Version	Active energy meter (direct connected)
	Voltage network	4-Wire (L1, L2, L3, N)
	Tariffs	<input checked="" type="radio"/> No tariffs <input type="radio"/> 4 tariffs
	Register for exported energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
	Send power values to load control	No

Note: The parameter settings here must match those in the ZS/S.

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Meter “ZS/S Meter Interface Module”

10	<u>Tariffs</u> <ul style="list-style-type: none">No tariffs4 tariffs
11	<u>Register for exported energy</u> <ul style="list-style-type: none">NoYes
12	<u>Send power values to load control</u> <p>This parameter determines which power value from the connected meter is sent to load control and taken into account in the calculation.</p> <ul style="list-style-type: none">NoSum of all phasesPhase 1Phase 2Phase 3Phase 1, 2Phase 1, 3Phase 2, 3


1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 1 > ZS/S

General	Device selection	ABB: ZS/S Meter Interface Module
Load Control	Name	Meter Interface 1: B23-112-100
	Location	Training Board (1)
Meter 1	Serial number	85674123
	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
Meter 2	Monitor "In Operation" Group object	Yes, value 0
ZS/S	Cycle time	60 s
Meter 3	Meter type	A4x (A-Series), B2x (B-Series)
	Version	Active energy meter (direct connected)
SE/S	Voltage network	4-Wire (L1, L2, L3, N)
Meter 4	10 Tariffs	<input checked="" type="radio"/> No tariffs <input type="radio"/> 4 tariffs
EM/S	11 Register for exported energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
Meter 5	12 Send power values to load control	No

Note: The parameter settings here must match those in the ZS/S.

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX – Assignment of group addresses



Meter Interface ZS/S 1.1

Example of a ZS/S parameterization:
 EQmeter "B21 113 100"
 Meter type "A/B-series"
 Active energy meter (direct)
 Voltage network 2-wire (N,L), No tariffs
 Send object "In operation" cyclically
 Send values (meter, power and instrument)
 on request

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: SE/S Energy Act. – EM/S Energy Mod.

1	<p><u>Name</u> This field lets you enter a unique name for the SE/S Energy Actuator or EM/S Energy Module. It is used for identification purposes, for example, if there are several identical energy actuators or modules in a single installation. The name you enter will appear in the UI in Management > Meter Management</p>
2	<p><u>Location</u> Here you can enter the installation location for the SE/S Energy Actuator or EM/S Energy Module. It is used for location purposes, for example, if there are several identical energy actuators or modules in a single installation. The installation location you enter will appear in the UI in Management > Meter Management</p>
3	<p><u>Serial number</u> This field lets you enter a serial or ID number for the SE/S Energy Actuator or EM/S Energy Module. This is another way to identify it if there are several identical energy actuators or modules in a single installation. The serial number you enter will appear in the UI in Management > Meter Management</p>
4	<p><u>Enable Group object "Request meter/sensor reading"</u> This parameter determines whether meter readings are received via a separate group object.</p> <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.

The screenshot shows the configuration interface for a 16-fold MDRC Energy Analyzer. The title bar reads "1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 3 > SE/S". The interface is divided into a left sidebar and a main configuration area. The sidebar lists meters from Meter 3 to Meter 6, with Meter 3 selected and highlighted in red. The main area shows configuration options for the selected meter:

- General**: Device selection is set to "ABB: SE/S Energy Actuator".
- Load Control**:
 - 1 Name: "Energy Actuator 1: SE/S"
 - 2 Location: "Training Board (3)"
 - 3 Serial number: "1978563"
 - 4 Enable Group object "Request meter/sensor reading": Radio buttons for "No" and "Yes" (selected).
- Meter 4**: Monitor "In Operation" Group object: "Yes, value 0"
- EM/S**: Cycle time: "60" s
- Meter 5**: Send power values to load control: "Total"
- Electricity**: (empty)
- Meter 6**: (empty)

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: SE/S Energy Act. – EM/S Energy Mod.

5

Monitor "In Operation" Group object

This parameter determines whether the In operation group object monitors the presence of the SE/S or EM/S on the bus.

- No: No monitoring
- Yes, value 0: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 telegram from the SE/S or EM/S within the cycle time.
- Yes, value 1: Shows the In operation group object and the Cycle time parameter. The group object expects a value 1 telegram from the SE/S or EM/S within the cycle time.
- Yes, both values: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 or 1 telegram from the SE/S or EM/S within the cycle time.

6

Send power values to load control

This parameter determines which power value from the connected meter is sent to load control and taken into account in the calculation.

- No: No power value is sent; the meter is not taken into account in the load control
- Total: Sends the total power/sum of all channels
- Channel A: Sends the channel A power value
- Channel B: Sends the channel B power value
- Channel C: Sends the channel C power value
- Channel A, B: Sends the (sum of the) channel A and B power values
- Channel A, C: Sends the (sum of the) channel A and C power values
- Channel B, C: Sends the (sum of the) channel B and C power values

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 3 > SE/S

General	Device selection	ABB: SE/S Energy Actuator
Load Control	Name	Energy Actuator 1: SE/S
Meter 3	Location	Training Board (3)
SE/S	Serial number	1978563
Meter 4	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
EM/S	Monitor "In Operation" Group object	Yes, value 0
Meter 5	Cycle time	60 s
Electricity	Send power values to load control	Total
Meter 6		

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX – Assignment of group addresses

Energy Analyzer QA/S1.16.1	Meter x: SE/S – In operation	←	System – In operation	Energy Actuator SE/S3.16.1
	Meter x: SE/S – Request meter reading	→	General – Request status values	
	Meter x: SE/S – Request status values	←	General – Request meter readings	
	Meter x: SE/S – Measurement circuit active	←	Diagnostics – Measurement circuit active	
	Meter x: SE/S – Meter reading	←	Meter total – Meter reading	
	Meter x: SE/S – Active power	←	Active power total – Active power	
	Meter x: SE/S – Frequency	←	Frequency – Frequency	
	Meter x: SE/S – A: Meter reading	←	A: Meter – Meter reading	
	Meter x: SE/S – A: Active power	←	A: Active power – Active power	
	Meter x: SE/S – A: Current	←	A: Current – Current value	
	Meter x: SE/S – A: Voltage	←	A: Voltage – Voltage	
	Meter x: SE/S – A: Apparent power	←	A: Apparent power – Apparent power	
	Meter x: SE/S – A: Power factor	←	A: Power factor – Power factor	
	Meter x: SE/S – B: Meter reading	←	B: Meter – Meter reading	
	Meter x: SE/S – B: Active power	←	B: Active power – Active power	
	Meter x: SE/S – B: Current	←	B: Current – Current value	
	Meter x: SE/S – B: Voltage	←	B: Voltage – Voltage	
	Meter x: SE/S – B: Apparent power	←	B: Apparent power – Apparent power	
	Meter x: SE/S – B: Power factor	←	B: Power factor – Power factor	
	Meter x: SE/S – C: Meter reading	←	C: Meter – Meter reading	
Meter x: SE/S – C: Active power	←	C: Active power – Active power		
Meter x: SE/S – C: Current	←	C: Current – Current value		
Meter x: SE/S – C: Voltage	←	C: Voltage – Voltage		
Meter x: SE/S – C: Apparent power	←	C: Apparent power – Apparent power		
Meter x: SE/S – C: Power factor	←	C: Power factor – Power factor		

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Electricity (generic)

1	Name In this field, you can enter a unique name for the meter. It is used for identification purposes, for example, if there are several identical meters in a single installation. The name you enter will appear in the UI in Management > Meter Management
2	Location Here you can enter the installation location for the meter. It is used for location purposes, for example, if there are several identical meters in a single installation. The installation location you enter will appear in the UI in Management > Meter Management
3	Serial number This field lets you enter a serial number or ID number for the meter. This is another way to identify it if there are several identical meters in a single installation. The serial number you enter will appear in the UI in Management > Meter Management
4	Enable Group object "Request meter/sensor reading" This parameter determines whether meter readings are received via a separate group object. <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 5 > Electricity

General	Device selection	Electricity (generic)
Load Control	1 Name	Energy Meter: Generic
	2 Location	Training Board (5)
	3 Serial number	4419782
	4 Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
	Note: Connected device must support this function	
	Communication monitoring	No
	Voltage network	4-Wire (L1, L2, L3, N)
	Tariffs	No tariffs
	Register for exported Energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
	Data point type for active energy	13.010 Active Energy (Wh) 4 Byte
	Data point type for reactive energy	13.012 Reactive Energy (varh) 4 Byte
	Data point type for apparent energy	13.011 Apparent Energy (VAh) 4 Byte
	Send power values to load control	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Electricity (generic)

5

Communication monitoring

This parameter determines whether the In operation group object monitors the presence of the meter on the bus.

- No: No monitoring
- Yes, value 0: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 telegram from the meter within the cycle time.
- Yes, value 1: Shows the In operation group object and the Cycle time parameter. The group object expects a value 1 telegram from the meter within the cycle time.
- Yes, both values: Shows the In operation group object and the Cycle time parameter. The group object expects a value 0 or 1 telegram from the meter within the cycle time.
- General monitoring: If any telegram fails to reach an Energy Analyzer group object within the set cycle time, the meter will be flagged as "disconnected" in the meter management overview.
- Therefore the meter's group object must be linked with the corresponding KNX Energy Analyzer group object.

6

Voltage network

This parameter determines whether the meter has a 2-, 3- or 4-wire connection and provides a corresponding tab. To use the tab, select the relevant option.

- 2-Wire (L, N): The meter is a 2-wire. The group objects for a 2-wire meter appear.
- 3-Wire (L1, L2, L3): The meter is a 3-wire. The group objects for a 3-wire meter appear.
- 4-Wire (L1, L2, L3, N): The meter is a 4-wire. The group objects for a 4-wire meter appear.

The screenshot shows the configuration window for '1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 5 > Electricity'. The interface is divided into two main sections: a left sidebar with a tree view and a main configuration area on the right. The tree view on the left includes 'Meter 5' (highlighted with a red box), 'Electricity' (highlighted with a blue box), 'Meter 6', 'Gas', 'Meter 7', 'Water', 'Meter 8', 'Heat', 'Meter 9', and 'Sensor'. The main configuration area is titled '1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 5 > Electricity' and contains several tabs: 'General', 'Load Control', 'Meter 5', 'Gas', 'Meter 7', 'Water', 'Meter 8', 'Heat', 'Meter 9', and 'Sensor'. The 'Meter 5' tab is active, showing the following configuration:

- Device selection: Electricity (generic)
- Name: Energy Meter: Generic
- Location: Training Board (5)
- Serial number: 4419782
- Enable Group object "Request meter/sensor reading": No Yes
- Note: Connected device must support this function
- Communication monitoring: No
- Voltage network: 4-Wire (L1, L2, L3, N)
- Tariffs: No tariffs
- Register for exported Energy: No Yes
- Data point type for active energy: 13.010 Active Energy (Wh) 4 Byte
- Data point type for reactive energy: 13.012 Reactive Energy (varh) 4 Byte
- Data point type for apparent energy: 13.011 Apparent Energy (VAh) 4 Byte
- Send power values to load control: No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Electricity (generic)

7	<p><u>Tariffs</u> This parameter determines whether the meter has a tariff tab. To use the tab, select the relevant option.</p> <ul style="list-style-type: none">• No tariffs: The meter has no tariffs.• 2 tariffs: The meter has 2 tariffs. The group objects for 2 tariffs appear.• 4 tariffs: The meter has 4 tariffs. The group objects for 4 tariffs appear.
8	<p><u>Register for exported energy</u> This parameter determines whether the meter has an exported energy tab. To use the tab, select Yes.</p> <ul style="list-style-type: none">• No• Yes: The group objects for exported energy appear.
9	<p><u>Data point type for active energy</u> This parameter determines the data type used to receive active energy. The corresponding group object appears when you make a selection.</p> <ul style="list-style-type: none">• 13.010 Active Energy (Wh) 4 Byte• 13.013 Active Energy (kWh) 4 Byte• 29.010 Active Energy (Wh) 8 Byte

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 5 > Electricity

General	Device selection	Electricity (generic) ▼
Load Control	Name	Energy Meter: Generic
	Location	Training Board (5)
Meter 5	Serial number	4419782
Electricity	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
Meter 6	Note: Connected device must support this function	
Gas	Communication monitoring	No ▼
	Voltage network	4-Wire (L1, L2, L3, N) ▼
Meter 7	7 Tariffs	No tariffs ▼
Water	8 Register for exported Energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
Meter 8	9 Data point type for active energy	13.010 Active Energy (Wh) 4 Byte ▼
Heat	Data point type for reactive energy	13.012 Reactive Energy (varh) 4 Byte ▼
	Data point type for apparent energy	13.011 Apparent Energy (VAh) 4 Byte ▼
Meter 9		
Sensor	Send power values to load control	No ▼

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Electricity (generic)

10	<p><u>Data point type for reactive energy</u> This parameter determines the data type used to receive reactive energy. The corresponding group object appears when you make a selection.</p> <ul style="list-style-type: none">• None• 13.012 Reactive Energy (varh) 4 Byte• 13.015 Reactive Energy (kvarh) 4 Byte• 29.012 Reactive Energy (varh) 8 Byte
11	<p><u>Data point type for apparent energy</u> This parameter determines the data type used to receive apparent energy. The corresponding group object appears when you make a selection.</p> <ul style="list-style-type: none">• None• 13.011 Apparent Energy (VAh) 4 Byte• 13.014 Apparent Energy (kVAh) 4 Byte• 29.011 Apparent Energy (VAh) 8 Byte
12	<p><u>Send power values to load control</u> This parameter determines which power value from the connected meter is sent to load control and taken into account in the calculation.</p> <ul style="list-style-type: none">• No: No power value is sent; the meter is not taken into account in the load control.• Sum of all phases: Sends the total power/sum of all phases• Phase 1: Sends the phase L1 power value• Phase 2: Sends the phase L2 power value• Phase 3: Sends the phase L3 power value• ...

The screenshot shows the configuration window for '1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 5 > Electricity'. The interface is divided into a left sidebar and a main configuration area. The sidebar lists various meters and sensors, with 'Meter 5' and 'Electricity' highlighted. The main area contains the following settings:

- General:** Device selection: Electricity (generic)
- Load Control:** Name: Energy Meter: Generic; Location: Training Board (5); Serial number: 4419782
- Enable Group object "Request meter/sensor reading":** No Yes
- Note:** Connected device must support this function
- Communication monitoring:** No
- Voltage network:** 4-Wire (L1, L2, L3, N)
- Tariffs:** No tariffs
- Register for exported Energy:** No Yes
- Data point type for active energy:** 13.010 Active Energy (Wh) 4 Byte
- 10 Data point type for reactive energy:** 13.012 Reactive Energy (varh) 4 Byte
- 11 Data point type for apparent energy:** 13.011 Apparent Energy (VAh) 4 Byte
- 12 Send power values to load control:** No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Gas (generic)

1	<u>Name</u> In this field, you can enter a unique name for the meter. It is used for identification purposes, for example, if there are several identical meters in a single installation. The name you enter will appear in the UI in Management > Meter Management
2	<u>Location</u> Here you can enter the installation location for the meter. It is used for location purposes, for example, if there are several identical meters in a single installation. The installation location you enter will appear in the UI in Management > Meter Management
3	<u>Serial number</u> This field lets you enter a serial number or ID number for the meter. This is another way to identify it if there are several identical meters in a single installation. The serial number you enter will appear in the UI in Management > Meter Management
4	<u>Enable Group object "Request meter/sensor reading"</u> This parameter determines whether meter readings are received via a separate group object. <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 6 > Gas

General	Device selection	Gas (generic)
Load Control	1 Name	Gas Meter: Generic
Meter 6	2 Location	Training Board (6)
Gas	3 Serial number	10978314
Meter 7	4 Enable Group object "Request meter/sensor reading"	<input checked="" type="radio"/> No <input type="radio"/> Yes
Water	Communication monitoring	No
Meter 8	Receive consumption	14.076 (F32) Volume (m ³)
	Receive flow rate	13.002 (S32) Flow rate (m ³ /h)

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Gas (generic)

5	<u>Communication monitoring</u> See parameter window "Electricity (generic)"
6	<u>Receive consumption</u> This parameter determines the data type used to receive gas consumption. The corresponding group object appears when you make a selection. <ul style="list-style-type: none">• No• 14.076 (F32) Volume (m³)• 12.xxx (U32) Volume (m³)• 12.xxx (U32) Volume (l)
7	<u>Receive flow rate</u> This parameter determines the data type used to receive flow rate. The corresponding group object appears when you make a selection. <ul style="list-style-type: none">• No• 14.077 (F32) Flow rate (m³/s)• 12.xxx (U32) Flow rate (m³/h)• 12.xxx (U32) Flow rate (l/h)• 13.002 (S32) Flow rate (m³/h)

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 6 > Gas

General	Device selection	Gas (generic)
Load Control	Name	Gas Meter: Generic
	Location	Training Board (6)
	Serial number	10978314
	Enable Group object "Request meter/sensor reading"	<input checked="" type="radio"/> No <input type="radio"/> Yes
Meter 6		
	5 Communication monitoring	No
	6 Receive consumption	14.076 (F32) Volume (m ³)
	7 Receive flow rate	13.002 (S32) Flow rate (m ³ /h)
Meter 7		
Water		
Meter 8		

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Water (generic)

1	<p><u>Name</u> In this field, you can enter a unique name for the meter. It is used for identification purposes, for example, if there are several identical meters in a single installation. The name you enter will appear in the UI in Management > Meter Management</p>
2	<p><u>Location</u> Here you can enter the installation location for the meter. It is used for location purposes, for example, if there are several identical meters in a single installation. The installation location you enter will appear in the UI in Management > Meter Management</p>
3	<p><u>Serial number</u> This field lets you enter a serial number or ID number for the meter. This is another way to identify it if there are several identical meters in a single installation. The serial number you enter will appear in the UI in Management > Meter Management</p>
4	<p><u>Enable Group object "Request meter/sensor reading"</u> This parameter determines whether meter readings are received via a separate group object.</p> <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 7 > Water

General	Device selection	Water (generic)
Load Control	1 Name	Water Meter: Generic
Meter 7	2 Location	Training Board (7)
Water	3 Serial number	90294256
Meter 8	4 Enable Group object "Request meter/sensor reading"	<input checked="" type="radio"/> No <input type="radio"/> Yes
Heat	Communication monitoring	No
Meter 9	Receive consumption	14.076 (F32) Volume (m³)
	Receive flow rate	13.002 (S32) Flow rate (m³/h)

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Water (generic)

5	<u>Communication monitoring</u> See parameter window "Electricity (generic)"
6	<u>Receive consumption</u> This parameter determines the data type used to receive water consumption. The corresponding group object appears when you make a selection. <ul style="list-style-type: none">• No• 14.076 (F32) Volume (m3)• 12.xxx (U32) Volume (m3)• 12.xxx (U32) Volume (l)
7	<u>Receive flow rate</u> This parameter determines the data type used to receive flow rate. The corresponding group object appears when you make a selection. <ul style="list-style-type: none">• No• 14.077 (F32) Flow rate (m³/s)• 12.xxx (U32) Flow rate (m³/h)• 12.xxx (U32) Flow rate (l/h)• 13.002 (S32) Flow rate (m³/h)

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 7 > Water

General	Device selection	Water (generic)
Load Control	Name	Water Meter: Generic
Meter 7	Location	Training Board (7)
	Serial number	90294256
	Enable Group object "Request meter/sensor reading"	<input checked="" type="radio"/> No <input type="radio"/> Yes
- Meter 8	5 Communication monitoring	No
Heat	6 Receive consumption	14.076 (F32) Volume (m ³)
- Meter 9	7 Receive flow rate	13.002 (S32) Flow rate (m ³ /h)

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Heat (generic)

1	<p><u>Name</u> In this field, you can enter a unique name for the meter. It is used for identification purposes, for example, if there are several identical meters in a single installation. The name you enter will appear in the UI in Management > Meter Management</p>
2	<p><u>Location</u> Here you can enter the installation location for the meter. It is used for location purposes, for example, if there are several identical meters in a single installation. The installation location you enter will appear in the UI in Management > Meter Management</p>
3	<p><u>Serial number</u> This field lets you enter a serial number or ID number for the meter. This is another way to identify it if there are several identical meters in a single installation. The serial number you enter will appear in the UI in Management > Meter Management</p>
4	<p><u>Enable Group object "Request meter/sensor reading"</u> This parameter determines whether meter readings are received via a separate group object.</p> <ul style="list-style-type: none">• No• Yes: Shows the Request meter reading group object, which enables active reading of the present meter readings. Readings from connected meters are requested one after the other roughly every 60 seconds.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 8 > Heat

General	Device selection	Heat (generic)
Load Control	1 Name	Heat Meter: Generic
	2 Location	Training Board (8)
	3 Serial number	1178965
	4 Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
- Meter 9	Note: Connected device must support this function	
ZS/S	Communication monitoring	No
- Meter 3	Data point type for heating energy	13.010 (V32) Active Energy (Wh)
	Data point type for cooling energy	No
SE/S	Receive volume consumption	14.076 (F32) Volume (m³)
- Meter 4	Receive active energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
EM/S	Receive flow rate	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Heat (generic)

5	<u>Communication monitoring</u> See parameter window "Electricity (generic)"
6	<u>Data point type for heating energy</u> This parameter determines the data type used to receive heating energy meter readings. The corresponding group object appears when you make a selection. <ul style="list-style-type: none">• 13.010 (V32) Active Energy (Wh)• 13.013 (V32) Active Energy (kWh)• 112.xxx (U32) Active Energy (kWh)• 12.xxx (U32) Active Energy (MWh)
7	<u>Data point type for cooling energy</u> This parameter determines the data type used to receive cooling energy meter readings. The corresponding group object appears when you make a selection. No <ul style="list-style-type: none">• 13.010 (V32) Active Energy (Wh)• 13.013 (V32) Active Energy (kWh)• 12.xxx (U32) Active Energy (kWh)• 12.xxx (U32) Active Energy (MWh)

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 8 > Heat

General	Device selection	Heat (generic)
Load Control	Name	Heat Meter: Generic
Meter 1	Location	Training Board (8)
Heat	Serial number	1178965
Meter 9	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
ZS/S	Note: Connected device must support this function	
Meter 3	5 Communication monitoring	No
SE/S	6 Data point type for heating energy	13.010 (V32) Active Energy (Wh)
Meter 4	7 Data point type for cooling energy	No
EM/S	Receive volume consumption	14.076 (F32) Volume (m³)
	Receive active energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
	Receive flow rate	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Heat (generic)

8	<p><u>Receive volume consumption</u> This parameter determines the data type used to receive accumulated volume. The corresponding group object appears when you make a selection</p> <ul style="list-style-type: none">No14.076 (F32) Volume (m³)12.xxx (U32) Volume (m³)12.xxx (U32) Volume (l)
9	<p><u>Receive active energy</u> This parameter determines the data type used to receive active energy. The corresponding group object appears when you make a selection.</p> <ul style="list-style-type: none">No: No actionYes: The group object for receiving heating energy appears.
10	<p><u>Receive flow rate</u> This parameter determines the data type used to receive flow rate. The corresponding group object appears when you make a selection.</p> <ul style="list-style-type: none">No14.077 (F32) Flow rate (m³/s)12.xxx (U32) Flow rate (m³/h)12.xxx (U32) Flow rate (l/h)13.002 (S32) Flow rate (m³/h)

The screenshot shows the configuration window for '1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 8 > Heat'. The interface is divided into a left sidebar and a main configuration area. The sidebar lists various meters and their associated parameters, with 'Heat' selected and highlighted by a red box. The main area displays the configuration for 'Heat (generic)', including fields for Name, Location, Serial number, and data point types for heating and cooling energy. The 'Receive volume consumption' parameter is set to '14.076 (F32) Volume (m³)', 'Receive active energy' is set to 'No', and 'Receive flow rate' is set to 'No'. The 'Enable Group object "Request meter/sensor reading"' is set to 'Yes'.

Category	Parameter	Value
General	Device selection	Heat (generic)
Load Control	Name	Heat Meter: Generic
	Location	Training Board (8)
	Serial number	1178965
	Enable Group object "Request meter/sensor reading"	<input type="radio"/> No <input checked="" type="radio"/> Yes
	Note: Connected device must support this function	
	Communication monitoring	No
	Data point type for heating energy	13.010 (V32) Active Energy (Wh)
	Data point type for cooling energy	No
SE/S	8 Receive volume consumption	14.076 (F32) Volume (m ³)
Meter 4	9 Receive active energy	<input checked="" type="radio"/> No <input type="radio"/> Yes
EM/S	10 Receive flow rate	No

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX – Assignment of group addresses

Energy Analyzer QA/S1.16.1	...	
	Meter x: Gen. El. – In operation	←
	Meter x: Gen. El. – Request meter reading	→
	Meter x: Gen. El. – Active energy	←
	Meter x: Gen. El. – Reactive energy	←
	Meter x: Gen. El. – Apparent energy	←
	Meter x: Gen. El. – Active power	←
	Meter x: Gen. El. – Reactive power	←
	Meter x: Gen. El. – Apparent power	←
	Meter x: Gen. El. – Phase angle power	←
	Meter x: Gen. El. – Power factor	←
	Meter x: Gen. El. – Current	←
	Meter x: Gen. El. – Voltage	←
	Meter x: Gen. El. – Frequency	←
	Meter x: Gen. El. – Phase angle current	←
	Meter x: Gen. El. – Phase angle voltage	←
Meter x: Gen. El. – Quadrant	←	

Example of a QA/S parameterization:

Meter type “Electricity” (generic)

- Voltage network 2-wire (N,L)
- No tariffs
- Communication monitoring via object “In operation” cyclically

Energy Analyzer QA/S1.16.1	...	
	Meter x: Water – In operation	←
	Meter x: Water – Request meter reading	→
	Meter x: Water – Volume (m3)	←
	Meter x: Water – Flow rate (m3/s)	←
	...	

Example of a QA/S parameterization:

Meter type “Water” (generic)

- Receive consumption m³ (DPT 14.076)
- Receive flow rate m³/s (DPT 14.077)
- Communication monitoring via object “In operation” cyclically

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX – Assignment of group addresses

Energy Analyzer QA/S1.16.1	...	
	Meter x: Heat – In operation	←
	Meter x: Heat – Request meter reading	→
	Meter x: Heat – Consumption heat (Wh)	←
	Meter x: Heat – Volume (m3)	←
	Meter x: Heat – Power	←
	Meter x: Heat – Flow rate (m3/s)	←
	Meter x: Heat – Flow temperature	←
	Meter x: Heat – Return temperature	←
	Meter x: Heat – Temperature difference	←
	...	

Example of a QA/S parameterization:

Meter type “Heat” (generic)

- Receive energy consumption heating “Active energy” (DPT 13.010)
- Receive volume consumption “Volume” m³ (DPT 14.076)
- Receive volume flow rate “Flow rate” m³/s (DPT 14.0767)
- Communication monitoring via object “In operation” cyclically

Energy Analyzer QA/S1.16.1	...	
	Meter x: Gas – In operation	←
	Meter x: Gas – Request meter reading	→
	Meter x: Gas – Volume (m ³)	←
	Meter x: Gas – Flow rate (m ³ /s)	←
	...	

Example of a QA/S parameterization:

Meter type “Gas” (generic)

- Receive consumption “Volume” m³ (DPT 14.076)
- Receive flow rate m³/s (DPT 14.077)
- Communication monitoring via object “In operation” cyclically

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Measurement

As an additional function, the Energy Analyzer offers the possibility to record further measured values in addition to the energy values

Up to ten different measured values or environmental parameters can be recorded for each configured sensor and displayed in the user interface

In combination with the alarm function, a notification can be sent by email if a limit value is exceeded

- Temperature (°C/°F)
- Rel. Humidity % (1-byte/2-bytes-value)
- CO₂/Air Quality ppm
- PM2.5: particulate matter
- PM10: particulate matter
- Wind Speed m/s
- Brightness lux




ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Measurement

1	<p><u>Name</u></p> <p>In this field, you can enter a unique name for the sensor. It is used for identification purposes, for example, if there are several identical sensors in a single installation. The name you enter will appear in the UI in Management > Meter Management</p>
2	<p><u>Location</u></p> <p>Here you can enter the installation location for the sensor. It is used for location purposes, for example, if there are several identical sensors in a single installation. The installation location you enter will appear in the UI in Management > Meter Management</p>
3	<p><u>Serial number</u></p> <p>This field lets you enter a serial number or ID number for the sensor. This is another way to identify it if there are several identical sensors in a single installation. The serial number you enter will appear in the UI in Management > Meter Management</p>
4	<p><u>Enable Group object "Request meter/sensor reading"</u></p> <p>This parameter determines whether meter readings/measured values are received via a separate group object.</p> <ul style="list-style-type: none">• No• Yes: Shows the Request meter/sensor reading group object. This group object enables active reading of the present meter readings/measured values. Readings/measured values from connected meters/sensors are requested one after the other roughly every 60 seconds.

1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 9 > Sensor

General

1 Device selection Measurement

2 Name Sensor: Measurement

3 Location Training Board (9)

3 Serial number

4 Enable Group object "Request meter/sensor reading" No Yes

Note: Connected device must support this function

Load Control

Communication monitoring No

Value 1 9.001 (F16) Temperature (°C)

Value 2 5.001 (U8) Rel. Humidity

Value 3 9.005 (F16) Wind Speed

Value 4 Not used

Value 5 Not used

Value 6 Not used

Value 7 Not used

Value 8 Not used

Value 9 Not used

Value 10 Not used

ABB EQmatic Energy Analyzer QA/S x.yy.1

ETS Parameter Energy Analyzer QA/S 1.16.1 KNX

Parameter window: Measurement

5	Communication monitoring See parameter window “Electricity (generic)” <u>Value 1...Value 10</u> This parameter defines which measured value is received. The corresponding group object appears based on your selection.
6	<ul style="list-style-type: none">• Not used: No measured values are received.• 9.001 (F16) Temperature (°C): The group object for receiving temperature in °C appears.• 9.027 (F16) Temperature (°F): The group object for receiving temperature in °F appears.• 5.001 (U8) Rel. Humidity: The group object for receiving relative humidity in % (1-byte-value) appears.• 9.007 (U8) Rel. Humidity: The group object for receiving relative humidity in % (2-bytes-value) appears.• 9.008 (F16) C CO2/Air Quality: The group object for receiving air quality in ppm appears.• 7.001 (U16) PM2.5: The group object for receiving PM2.5 particulate matter appears.• 7.001 (U16) PM10: The group object for receiving PM10 particulate matter appears.• 9.005 (F16) Wind Speed: The group object for receiving wind speed in m/s appears.• 9.004 (F16) Brightness: The group object for receiving brightness in lux appears.

The screenshot shows the configuration interface for the Energy Analyzer. The title bar reads "1.1.20 QA/S1.16.1 Energy Analyzer, 16-fold, MDRC > Meter 9 > Sensor". The interface is divided into two main sections: a left sidebar and a main configuration area.

Left Sidebar: Lists various meters and their associated sensors. "Meter 9" is selected and highlighted with a red box. Below it, "Sensor" is also highlighted with a red box. Other meters listed include Meter 2, Meter 3, Meter 4, Meter 5, Meter 6, and Gas. A "5" is circled next to "Communication monitoring" and a "6" is circled next to "Value 1".

Main Configuration Area: Contains the following fields and options:

- General:** Device selection: Measurement (dropdown)
- Load Control:** Name: Sensor: Measurement (text field)
- Location:** Training Board (9) (text field)
- Serial number:** (empty text field)
- Enable Group object "Request meter/sensor reading":** Radio buttons for No and Yes (Yes is selected)
- Note:** Connected device must support this function
- Communication monitoring:** No (dropdown)
- Value 1:** 9.001 (F16) Temperature (°C) (dropdown)
- Value 2:** 5.001 (U8) Rel. Humidity (dropdown)
- Value 3:** 9.005 (F16) Wind Speed (dropdown)
- Value 4:** Not used (dropdown)
- Value 5:** Not used (dropdown)
- Value 6:** Not used (dropdown)
- Value 7:** Not used (dropdown)
- Value 8:** Not used (dropdown)
- Value 9:** Not used (dropdown)
- Value 10:** Not used (dropdown)

Provide measured values

Data sharing via Modbus TCP and REST API

ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via Modbus TCP




ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via Modbus TCP

The data transfer via Modbus TCP function is available for forwarding and using measured data in higher-level systems (e.g. building management systems, SCADA etc.)

A Client-server communication is established via Modbus TCP

This communication requires a TCP connection to be set up between a client (e.g. a PC) and the server (e.g. the Energy Analyzer QA/S x.yy.1)

The TCP port 502 reserved for Modbus is used for communication

If there is a firewall between the server and client, it must be ensured the TCP port configured is opened

Note:

Available for

- Energy Analyzer QA/S 3.xx.1 M-Bus from version 2.0.0
- Energy Analyzer QA/S 1.16.1 KNX

The screenshot shows the ABB EQmatic Management interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. The secondary navigation bar includes 'Meter Management', 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing' (highlighted with a red box). The main content area is titled 'Data sharing' and features a 'Modbus TCP' tab (highlighted with a red box) and a 'Rest API' tab. There is a toggle for 'Enable static register mapping' and a search bar. Below the search bar is a table with the following data:

<input checked="" type="checkbox"/>	TCP ENABLED	MODBUS TCP SLAVE ID	PHYSICAL ADDRESS	MANUFACTURER	SERIAL NUMBER	NAME	DATA POINTS
<input checked="" type="checkbox"/>		1	1	ABB	00486522	Floor 03 - open office - lighting	^
<input checked="" type="checkbox"/>		2	2	ABB	00398010	Floor 03 - open office - cooling	^

ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via Modbus TCP – data points: Register address (dec.), size, coding, unit, multiplier and name

The screenshot shows the ABB EQmatic Management interface. The 'Management' tab is active, and the 'Data sharing' sub-tab is selected. Under 'Data sharing', 'Modbus TCP' is chosen. A table lists two Modbus TCP slaves. The 'TCP ENABLED' checkbox is checked for both. The 'Actions' menu is open, showing options like 'Export JSON', 'Export XML', 'Export XML (BMS)', and 'Export XLSX'.

TCP ENABLED	MODBUS TCP SLAVE ID	PHYSICAL ADDRESS	MANUFACTURER	SERIAL NUMBER	NAME
<input checked="" type="checkbox"/>	1	1	ABB	00486522	Floor 03 - open office - lighting
<input checked="" type="checkbox"/>	2	2	ABB	00398010	Floor 03 - open office - cooling

tcpRegAddress	size	coding	unit	multiplier	name
0	1	Unsigned 16-bit (UINT16)	-	-	Start of meter data registers
1	1	Unsigned 16-bit (UINT16)	-	-	Number of meter registers
2	2	Unsigned 32-bit (UINT32)	Wh	10	Active Imported Energy Total
4	2	Signed 32-bit (INT32)	-	1	NOT AVAILABLE (Current Transformer (CT) ratio prima
6	2	Signed 32-bit (INT32)	-	1	NOT AVAILABLE (Voltage Transformer (VT) ratio prima
8	2	Signed 32-bit (INT32)	-	1	NOT AVAILABLE (Current Transformer (CT) ratio secon
10	2	Signed 32-bit (INT32)	-	1	NOT AVAILABLE (Voltage Transformer (VT) ratio secon
12	4	Signed 64-bit (INT64)	-	1	Error flags
16	4	Signed 64-bit (INT64)	-	1	Warning flags
20	4	Signed 64-bit (INT64)	-	1	Information flags
24	4	Signed 64-bit (INT64)	-	1	Alarm flags
28	4	ASCII string	-	1	Firmware Version
32	6	ASCII string	-	1	Product name
38	2	Signed 32-bit (INT32)	W	0,01	Active Imported Power Total
40	2	Signed 32-bit (INT32)	V	0,1	Voltage L1
42	2	Signed 32-bit (INT32)	A	0,001	Current L1
44	1	Unsigned 8-bit (UINT8)	Hz	0,01	Frequency
45	1	Signed 16-bit (INT16)	-	0,001	Power Factor Total
46	1	Signed 8-bit (INT8)	-	1	Number of elements
47	1	Signed 8-bit (INT8)	-	1	Binary 1

Voltage L1:

Register address 40dec → 28hex; 2 byte signed 32-bit (INT32), unit “V”, multiplier 0.1

ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via Modbus TCP – data points: TCP register address (hex), size, coding, unit, multiplier and name

Data sharing

Modbus TCP Test API

Enable static register mapping

Search...

TCP ENABLED	MODBUS TCP SLAVE ID	PHYSICAL ADDRESS	MANUFACTURER	SERIAL NUMBER	NAME	DATA POINTS
<input checked="" type="checkbox"/>	1	1	ABB	00486522	Floor 03 - open office - lighting	^
<input checked="" type="checkbox"/>	2	2	ABB	00398010	Floor 03 - open office - cooling	^

TCP REGISTER ADDRESS	SIZE	CODING	UNIT	MULTIPLIER	NAME
0x0	1	Unsigned 16-bit (UINT16)	-	-	Start of meter data registers
0x1	1	Unsigned 16-bit (UINT16)	-	-	Number of meter registers
0x2	2	Unsigned 32-bit (UINT32)	Wh	10	Active Imported Energy Total
0xC	4	Signed 64-bit (INT64)	-	1	Error flags
0x10	4	Signed 64-bit (INT64)	-	1	Warning flags
0x14	4	Signed 64-bit (INT64)	-	1	Information flags
0x18	4	Signed 64-bit (INT64)	-	1	Alarm flags
0x1C	4	ASCII string	-	1	Firmware Version
0x20	6	ASCII string	-	1	Product name
0x26	2	Signed 32-bit (INT32)	W	0.01	Active Imported Power Total
0x28	2	Signed 32-bit (INT32)	V	0.1	Voltage L1
0x2A	2	Signed 32-bit (INT32)	A	0.001	Current L1
0x2C	1	Unsigned 8-bit (UINT8)	Hz	0.01	Frequency

Voltage L1:

Register address 28hex → 40dec, 2 byte signed 32-bit (INT32), unit “V”, multiplier 0.1

ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via REST API




ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via REST API

Representational state transfer (REST) is a software architectural style that defines a set of constraints to be used for creating Web services

→ provide interoperability between computer systems on the Internet

An application programming interface (API) is an interface or communication protocol between a client and a server intended to simplify the building of client-side software

Software information:

- Description of the “REST API”
- Documentation “ABB EQmatic REST API”




ABB EQmatic Energy Analyzer QA/S x.yy.1

Provide measured values

Data sharing via REST API

Authentication tokens allow usage of EQmatic API

Click “Action” dropdown to generate an API authentication token

The screenshot shows the ABB EQmatic web interface. The top navigation bar includes 'ABB EQmatic', 'Dashboard', 'Analytics', 'Management' (highlighted with a red box), and 'System'. The 'Management' menu is expanded, showing 'Meter Management', 'Metering Structure', 'User Management', 'Tariffs and units', 'Consumer Groups', and 'Data sharing' (highlighted with a red box). The 'Data sharing' page has a 'Modbus TCP' and 'Rest API' (highlighted with a red box) tab. The 'Allow API token authentication' toggle is turned on. Below the toggle, there is a text block: 'Below is the list of Auth tokens that has been generated by you. You can generate multiple tokens and invalidate them at any time. To revoke the token remove it from the list.' A table lists the generated tokens:

	NAME	TOKEN	CREATED ON
<input type="checkbox"/>	EIMo2904	2:b9a5eb0e5ab8b0a327c51e2a0d162b1c33b5f96f909f5891e	21/01/2020 09:59:35

The 'Actions' dropdown for the first token is open, showing 'Create auth token' and 'Remove' options. A red arrow points to the 'Create auth token' button.

Collection, management and storage of meter data from QA/S via Modbus TCP in a BMS, BAC/S, Visualisation, ...

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Visualisation or building management software




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Building management software “NETxAutomation”

Building management software for medium-sized and enterprise building automation projects

Servers and clients based on open standards

KNX, BACnet, Modbus, OPC, interfaces to hotel management systems, access control etc.

Through the connection of hotel management software like MICROS Fidelio/Opera or Protel with the building management system, data of the guest can be integrated

<https://www.netxautomation.com>




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Building management software




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Visualisation software “EisBaer SCADA”

EisBaer SCADA is an innovative and cost-efficient software for the visualisation and automation of building and machine intelligence

EisBaer SCADA offers a large range of potential applications, from the control of single rooms or machines, apartments or houses through to largescale buildings or whole building complexes

An intuitive graphical editor with flexible menus, convenient layout tools and customizable function templates facilitates the creation of user interfaces for your applications

The software provides interfaces for a wide variety of control and IT systems and is therefore a universal platform

Multiple interfaces to KNX, OPC, BACNet, Modbus, MBus, DMX, CAN Bus, ESPA 4.4.4, Sonos, Fidelio, Z-Wave, Tesla, Siemens Logo!, Profibus, BOSE, Revox Voxnet, ekey, Philips Hue, WAGO PFC, ZigBee, SNMP, ABB CMS, RAPIX, IRTrans, and many more

<https://www.busbaer.de/en>




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Visualisation software “EisBaer SCADA”

- Free editor incl. simulation mode
- Server is running as a Windows service
- Unlimited number of clients – no cost
- Free software updates
- Free Smart Clients for iOS, Android, Windows Phone and Windows RT
- Alarm Manager for unlimited messages according to DIN 19235 and data logging in SQL-based database
- Drivers and interfaces to KNX, OPC DA / UA / XML, DMX, MODBUS TCP / RTU / UDP, SONOS, IrTrans, ABB CMS, ABB M2M, Rapix, C-Bus, BACnet (server and / or client)
- Generation of templates with complete Modbus registers



ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Visualisation software “EisBaer SCADA”

Available MODBUS interfaces:

- Generic MODBUS RTU
- Generic MODBUS TCP
- Generic MODBUS UDP
- ABB CMS 600
- ABB M2M
- Templates for A4x payer, XT 4 ACB and Emax2MCB
- Templates for QA/S x.64.1
- ABB EV AC-charger
- ... and more



ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Visualisation software “EisBaer SCADA”: Editor

The screenshot shows the EisBaer SCADA Editor interface. The main window displays a table of data for 'Floor 03 - open office' connected via Modbus TCP. The table includes metrics for Active Imported Energy Total, Active Imported Power Total, Voltage L1, and Current L1 for both Lighting and Cooling systems. A 3D model of the ABB EQmatic Energy Analyzer is shown next to the table. The interface also features a search bar, a diagram view, and a communication table at the bottom.

	Lighting	Cooling
Active Imported Energy Total	2.210kWh	.610kWh
Active Imported Power Total	44.4 W	14.7 W
Voltage L1	230.8 V	230.9 V
Current L1	0.193 A	0.065 A

Run time

Data sharing via Modbus TCP

	Lighting	Cooling
Active Imported Energy Total	2,200kWh	0,610kWh
Active Imported Power Total	44,7 W	14,8 W
Voltage L1	231,2 V	230,9 V
Current L1	0,194 A	0,065 A

The 3D model shows the physical ABB EQmatic Energy Analyzer device, a white rectangular unit with various ports and labels.

Live Database Options

Chart

Suche

- ✓ Cooling: Active Imp...
- ✓ Lighting: Active Im...

The chart displays power consumption in Watts over time. The Y-axis ranges from 0 to 40 Watts. The X-axis shows time from 10:45:00 to 10:50:00. The chart shows two data series: Cooling (blue area) and Lighting (yellow area). The Cooling power fluctuates between approximately 15W and 40W, while the Lighting power is consistently around 15W.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Settings of “Modbus TCP driver”

Properties

Component

Name: Modbus TCP 1

Alignment: Top

Width [pixel]: 125

Height [pixel]: 107

X: 10115

Y: 59

Z: 0

Look: Front

Rights: Admin

Settings

Channels: 8

IP Address: 10.49.121.115

Port: 502

Timeout [ms]: 5000

Cyclic ping-check:

Cyclic ping-check interval [s]: 30

Mode: TCP

Temporary close connection:

Cyclic request - Delay [s]: 1

Cyclic request - Autostart:

Cyclic sending - Delay [s]: 1

Cyclic sending - Autostart:

Driver On/Off:

Component/Datapoint

Work

Energy Analyzer QA/S

Modbus TCP

Modbus TCP 1

Dynamic

Devices

Active Imported Energy Total (Meter 1): DataPoint... Net2

Active Imported Energy Total (Meter 2): DataPoint... Net6

Active Imported Power Total (Meter 1): DataPoint... Net3

Active Imported Power Total (Meter 2): DataPoint... Net7

Current L1 (Meter 1): DataPoint... Net4

Current L1 (Meter 2): DataPoint... Net8

Voltage L1 (Meter 1): DataPoint... Net1

Voltage L1 (Meter 2): DataPoint... Net5

Cyclic request: On/Off...

Cyclic request - Delay [s]: UInt16

Cyclic send: On/Off...

Cyclic sending - Delay [s]: UInt16

Diagnosis: String

Modbus TCP driver: Modbus Channel Editor

Modbus Channel Editor

Import Export

Name	Device ID [0 - 2...	Function	Register Address...	Number o...	Datatype
Active Imported Energy Total (Meter 1)	1	Read holding register(s) (3)	2	1	UInt32 CD AB
Active Imported Energy Total (Meter 2)	2	Read holding register(s) (3)	2	1	UInt32 CD AB
Active Imported Power Total (Meter 1)	1	Read holding register(s) (3)	38	1	Int32 CD AB
Active Imported Power Total (Meter 2)	2	Read holding register(s) (3)	38	1	Int32 CD AB
Current L1 (Meter 1)	1	Read holding register(s) (3)	42	1	Int32 CD AB
Current L1 (Meter 2)	2	Read holding register(s) (3)	42	1	Int32 CD AB
Voltage L1 (Meter 1)	1	Read holding register(s) (3)	40	1	Int32 CD AB
Voltage L1 (Meter 2)	2	Read holding register(s) (3)	40	1	Int32 CD AB

OK Cancel

tcpRegAddress	size	coding	unit	multiplier	name
...
2	2	Unsigned 32-bit (UINT32)	Wh	10	Active Imported Energy Total
32	6	ASCII string	-	1	Product name
38	2	Signed 32-bit (INT32)	W	0,01	Active Imported Power Total
40	2	Signed 32-bit (INT32)	V	0,1	Voltage L1
42	2	Signed 32-bit (INT32)	A	0,001	Current L1
44	1	Unsigned 8-bit (UINT8)	Hz	0,01	Frequency
45	1	Signed 16-bit (INT16)	-	0,001	Power Factor Total
...

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Settings of component “Value driven text”: Energy

The screenshot shows the software interface for configuring a 'Value driven text' component. The main display area shows a grid with the following data points: Active Imported Energy Total (2.210kWh), Active Imported Power Total (44.4 W), and Voltage I1 (230.8 V). A red box highlights the 'Active Imported Energy Total' value. The Properties panel on the right shows the component name 'Active Imported Energy Total (Meter 1)' and the text format 'ABBvoiceOffice;18;Bold;...'. The 'Value display' property is set to 'Float 64...' and the 'Undefined text' is set to '###,000kWh'. The 'Factor' is set to '0' and the 'Text List' is set to '0'. The 'Show string from list' checkbox is unchecked.

Settings of component “Value driven text”: Power

The screenshot shows the software interface for configuring a 'Value driven text' component. The main display area shows the same data points as the previous screenshot. A red box highlights the 'Active Imported Power Total' value. The Properties panel on the right shows the component name 'Active Imported Power Total (Meter 1)' and the text format 'ABBvoiceOffice;18;Bold;...'. The 'Value display' property is set to 'Float 64...' and the 'Undefined text' is set to '###,0 W'. The 'Factor' is set to '0' and the 'Text List' is set to '0'. The 'Show string from list' checkbox is unchecked.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Settings of component “Value driven text”: Voltage

Active Imported Power Total: 44.4 W, 14.7 W

Voltage L1: 230.8 V, 230.8 V

Current L1: 0.193 A, 0.065 A

Properties

Component	Value
Name	Voltage L1 (Meter 1)
Alignment	
Width [pixel]	200
Height [pixel]	50
X	330
Y	250
Z	1
Rotation Angle	0
Look	
Text format	ABBvoiceOffice;18;Bold;...
Effects	Reflection Off;Shadow Off;Glow Off;
Background	
Corner radius	
Border	
Border thickness	
Visible	<input checked="" type="checkbox"/>
Transparency	
ToolTip	Voltage L1 (Meter 1)
Text color status on	
Text color status off	
Text color status undefined	
On text	On #0
Off text	Off #0
Undefined text	##,0 V
Rights	Full Access
Settings	
Factor	0.1
Text List	0
Show string from list	<input type="checkbox"/>

Settings of component “Value driven text”: Current

Active Imported Power Total: 44.4 W, 14.7 W

Voltage L1: 230.8 V, 230.8 V

Current L1: 0.193 A, 0.065 A

Properties

Component	Value
Name	Current L1 (Meter 1)
Alignment	
Width [pixel]	200
Height [pixel]	50
X	330
Y	300
Z	1
Rotation Angle	0
Look	
Text format	ABBvoiceOffice;18;Bold;...
Effects	Reflection Off;Shadow Off;Glow Off;
Background	
Corner radius	
Border	
Border thickness	
Visible	<input checked="" type="checkbox"/>
Transparency	
ToolTip	Current L1 (Meter 1)
Text color status on	
Text color status off	
Text color status undefined	
On text	On #0
Off text	Off #0
Undefined text	##,0,000 A
Rights	Full Access
Settings	
Factor	0.001
Text List	0
Show string from list	<input type="checkbox"/>

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Visualisation or building management software and send on KNX




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Settings of component “Graphical Logic”: Multiplier

The screenshot shows the 'Graphical Logic' component settings in the software. The 'Properties' panel on the right shows the component name 'Graphical Logic1' and various settings like 'Cyclical calculation interval [ms]' set to 499. The main workspace displays a logic diagram with a 'Multiplier' component (represented by a green box with a '1' and a multiplier symbol) connected to a 'Voltage (Meter 1)' component. The logic diagram also includes inputs for 'CURRENT IN', 'CURRENT OUT', 'ENERGY IN', 'ENERGY OUT', 'POWER IN', 'POWER OUT', 'VOLTAGE IN', and 'VOLTAGE OUT'. The 'Communication' panel at the bottom shows a list of components and their associated data points and networks.

Component/Datapoint	Type	GA	GA Name	Network
Modbus TCP				
Graphical Logic1				
Dynamic				
CURRENT IN	DataPoint4OctetSignedValue			Net4
CURRENT IN - constant value	DataPoint4OctetSignedValue			
CURRENT OUT	DataPoint2OctetFloatValue	05/4/004	Energy.Modbus TC...	Net12
ENERGY IN	DataPoint4OctetSignedValue			Net2
ENERGY IN - constant value	DataPoint4OctetSignedValue			
ENERGY OUT	DataPoint4OctetSignedValue	05/4/002	Energy.Modbus TC...	Net10
POWER IN	DataPoint4OctetSignedValue			Net3
POWER IN - constant value	DataPoint4OctetSignedValue			
POWER OUT	DataPoint2OctetFloatValue	05/4/003	Energy.Modbus TC...	Net11
VOLTAGE IN	DataPoint4OctetSignedValue			Net1
VOLTAGE IN - constant value	DataPoint4OctetSignedValue			
VOLTAGE OUT	DataPoint2OctetFloatValue	05/4/001	Energy.Modbus TC...	Net9

Divide by multiplier and convert integer to floating point

- The QA/S sends the values with a factor (multiplier)
- These values must be multiplied by the multiplier and converted from integer to KNX data types (float value)

The screenshot shows the logic diagram for 'Voltage' with several configuration windows open. The logic diagram includes a 'VOLTAGE IN' input (4B), a 'Converter' component (4B -> 4B(f)), a 'Voltage (Meter 1)' component (A: 4B(f), B: A * B), and a 'VOLTAGE OUT' output (4B(f)). The configuration windows show the following settings:

- Edit Input parameters... (VOLTAGE IN):** Name: VOLTAGE IN, Number: 0, Datatype: 4 bytes (signed), Initialization: Read value, Initial value: 0.
- Edit converter parameters... (Converter):** Name: Converter, Number: 3, Datatype in: 4 bytes (signed), Datatype out: 4 bytes floating, Out value true: [], Out value false: [], Invert overflow output: [].
- Edit arithmetic operator parameters... (Voltage (Meter 1)):** Name: Voltage (Meter 1), Number: 2, Datatype: [], Functiontype: Multiplication, Invert error out: [], Use value on input 2 only if value on input 1 is new: [].
- Edit Input parameters... (VOLTAGE IN - constant value):** Name: VOLTAGE IN - constant value, Number: 1, Datatype: 4 bytes floating, Initialization: Initial value with trigger, Initial value: 0.1.
- Edit Output parameters... (VOLTAGE OUT):** Name: VOLTAGE OUT, Number: 4, Datatype: 4 bytes floating, Send: After each calculation, Send initial value on startup: [], Send value: true and false.

Example "Voltage":

- Multiplier 0.1 → Multiply by 0.1
- Signed 32-bit (INT32) → 4 byte float value

CODING	UNIT	MULTIPLIER	NAME
Signed 32-bit (INT32)	V	0.1	Voltage L1

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Settings of “KNX driver”

The screenshot displays the ETS software interface for configuring a KNX driver. On the left, a 3D model of the ABB EQmatic Energy Analyzer QA/S is shown. The Properties panel on the right indicates the component name is 'KNX1' and provides dimensions: Width [pixel] 108, Height [pixel] 107, X 1017, Y 190, and Z 19. The Communication panel shows a tree view with the following structure:

- Work
 - Energy Analyzer QA/S
 - Modbus TCP
 - KNX1
 - Dynamic
 - 01.01.001.002 DataPoint4OctetSignedValue, Numb... 05/4/002 Open office: Lighting -
 - 01.01.001.003 DataPoint4OctetFloatValue, Float 32... 05/4/003 Open office: Lighting -
 - 01.01.001.004 DataPoint4OctetFloatValue, Float 32... 05/4/004 Open office: Lighting -
 - 01.01.001.001 DataPoint4OctetFloatValue, Float 32... 05/4/001 Open office: Lighting -
 - Driver On/Off On/Off
 - Driver status On/Off
 - ETS4 Logging (On/Off) On/Off, DataPointBooleanValue
 - Initialize KNX data during act... On/Off
 - Monitor Strings
 - Read values from KNX in prog... On/Off
 - Send active On/Off
 - Start/Stop reading values fro... On/Off
 - Status table EISState

The Settings panel on the right shows the following configuration:

- Data points from ETS (4 data points)
- Read values from KNX
- Send active
- Telegram delay [ms] 50
- Driver settings KNXnet/IP-Routing: 224.0.23.12;3671...
- ETS-Monitor logging
- Log save interval [min.] 5
- Driver On/Off

ETS: Group monitor

The screenshot shows the ETS Group Monitor window. The interface includes a toolbar with buttons for Start, Stop, Clear, Open, Save, Print, Replay Telegrams, Options, and Group Functions. The Group Address field is empty, and the Data point type is set to '1.001 switch'. The Last received value is 'Off'. The Send cyclically checkbox is unchecked. The table below displays the monitored data points:

#	Time	Service	Fla	Prio	Sourc	Source Name	Destinat	Destination Name	Ro	Type	DPT	Info
1	03.06...	from bus	Low	2.2.1	Energy Analy...	5/4/1		Open office: Lighting - Voltage L1 (Meter 1)	5	GroupValueWrite	14.027 electric potential (V)	43 65 EB 85 229.92 V
2	03.06...	from bus	Low	2.2.1	Energy Analy...	5/4/2		Open office: Lighting - Active Imported Energy Total (Meter 1)	5	GroupValueWrite	13.010 active energy (Wh)	00 00 09 4C 2380 Wh
3	03.06...	from bus	Low	2.2.1	Energy Analy...	5/4/3		Open office: Lighting - Active Imported Power Total (Meter 1)	5	GroupValueWrite	14.056 power (W)	42 2E 66 66 43.6 W
4	03.06...	from bus	Low	2.2.1	Energy Analy...	5/4/4		Open office: Lighting - Current L1 (Meter 1)	5	GroupValueWrite	14.019 electric current (A)	3E 42 8F 5C 0.19 A

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1





ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1



The screenshot displays the ABB Automation Builder interface. The left-hand pane shows a project tree for 'Projekt1' with a sub-project 'PLC_AC500_V3 (PM5630-2ETH - TB5620-2ETH)'. Under 'Application', the 'IO_Bus' is expanded to show 'DX571 (DX571)'. The right-hand pane shows the 'I/O Mapping' configuration for the DX571 device, which is currently set to 'Digital inputs 10 - 17'. Below this, a table lists the I/O objects and their mappings.

Object Name	Variable	Channel	Address	Type	Description	Terminal
DX571		Digital inputs 10 - 17	%I0	BYTE		
DX571	DigIn0	Digital input 10	%IX0.0	BOOL		2
DX571	DigIn1	Digital input 11	%IX0.1	BOOL		3
DX571	DigIn2	Digital input 12	%IX0.2	BOOL		4
DX571		Digital input 13	%IX0.3	BOOL		5
DX571		Digital input 14	%IX0.4	BOOL		6
DX571		Digital input 15	%IX0.5	BOOL		7
DX571		Digital input 16	%IX0.6	BOOL		8
DX571		Digital input 17	%IX0.7	BOOL		9
DX571		Relay outputs NO0 - NO7	%QB0	BYTE		
DX571	RelOut0	Relay output NO0	%QX0.0	BOOL		10
DX571	RelOut1	Relay output NO1	%QX0.1	BOOL		11
DX571	RelOu2	Relay output NO2	%QX0.2	BOOL		12
DX571		Relay output NO3	%QX0.3	BOOL		13
DX571		Relay output NO4	%QX0.4	BOOL		15
DX571		Relay output NO5	%QX0.5	BOOL		16
DX571		Relay output NO6	%QX0.6	BOOL		17
DX571		Relay output NO7	%QX0.7	BOOL		18

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1

The screenshot displays the ABB Automation Builder interface for a project named 'Projekt1'. The left sidebar shows a tree view of the project structure, including 'PLC_AC500_V3 (PM5630-2ETH - TB5620-2ETH)', 'IO_Bus', 'Interfaces', 'COM_1 (COM 1)', 'CAN (<Empty>)', 'Ethernet', 'ETH1 (IP Settings)', 'NetConfig (NetConfig)', 'Web_Server (Web Server)', 'ETH2 (IP Settings)', 'Protocols (Client Protocols)', 'Extension_Bus', 'Slot 1 (<Empty>)', and 'Slot 2 (<Empty>)'. The main window is titled 'KNX_1' and shows the 'I/O mapping list' configuration. The table below lists the mapping of variables to channels and addresses.

Variable	Mapping	Channel	Address	Type	Default Value
KNX I/O Mapping		Program LED Status	%IX4.0	BOOL	
		1 - Switch 1 on/off - BOOL	%IB5	BYTE	
		Statusbyte	%IB5	BYTE	
	KNXIN001	Value	%IX6.0	BOOL	
		Control of 1 - Switch 1 on/off - BOOL	%QB4	BYTE	
		2 - Switch 2 on/off - BOOL	%IB7	BYTE	
		Control of 2 - Switch 2 on/off - BOOL	%QB5	BYTE	
		3 - Switch 3 on/off - BOOL	%IB9	BYTE	
		Control of 3 - Switch 3 on/off - BOOL	%QB6	BYTE	
		4 - Switch 4 on/off - BOOL	%IB11	BYTE	
		Control of 4 - Switch 4 on/off - BOOL	%QB7	BYTE	
		5 - Status Logic 1 - BOOL	%QB8	BYTE	
		6 - Status Logic 1 - BOOL	%QB10	BYTE	
		7 - Room temperature - REAL	%ID4	REAL	
		Control of 7 - Room temperature - REAL	%QB12	BYTE	
		8 - 4-Octet vorzeichenloser Wert - Ausgang (SPS zu KNX) - DPT 12.*	%QD4	REAL	
		9 - Control value room 3-001 - Eingang (KNX zu SPS) - DPT 5.001	%IB24	REAL	
		Control of 9 - Control value room 3-001 - Eingang (KNX zu SPS) - DPT 5.001	%QB24	BYTE	
		10 - Bookxyz - Ausgang (SPS zu KNX) - DPT 1.*	%QB25	REAL	

At the bottom of the window, there are options for 'Reset mapping', 'Always update variables: Enabled 1 (use bus cycle task if not used in any task)', and 'Bus cycle options' set to 'Use parent bus cycle setting'.

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1

The screenshot displays the ABB Automation Builder software interface. The left sidebar shows a project tree with the following structure:

- Projekt1
 - PLC_AC500_V3 (PM5630-2ETH - TB5620-2ETH)
 - PLC Logic
 - IO_Bus
 - Interfaces
 - COM_1 (COM 1)
 - CAN (<Empty>)
 - Ethernet
 - ETH1 (IP Settings)
 - NetConfig (NetConfig)
 - Web_Server (Web Server)
 - KNX_1 (KNX)**
 - ETH2 (IP Settings)
 - Protocols (Client Protocols)
 - Extension_Bus
 - Slot 1 (<Empty>)
 - Slot 2 (<Empty>)

The main configuration area is currently on the 'General' tab, showing a table of KNX I/O objects. The table has the following columns: Object Name, Variable, Channel, Address, Type, Description, and Terminal.

Object Name	Variable	Channel	Address	Type	Description	Terminal
KNX_1		1 - Switch 1 on/off - BOOL -	%I85	BYTE		
KNX_1		1 - Switch 1 on/off - BOOL -	%IX5.3	BOOL		
KNX_1		1 - Switch 1 on/off - BOOL -	%IX5.4	BOOL		
KNX_1		1 - Switch 1 on/off - BOOL -	%IX5.5	BOOL		
KNX_1	KNXIN001	1 - Switch 1 on/off - BOOL -	%IX6.0	BOOL		
KNX_1		Control of 1 - Switch 1 on/off%QB4		BYTE		
KNX_1		Control of 1 - Switch 1 on/off%QX4.0		BOOL		
KNX_1		Control of 1 - Switch 1 on/off%QX4.1		BOOL		
KNX_1		2 - Switch 2 on/off - BOOL -	%IB7	BYTE		
KNX_1		2 - Switch 2 on/off - BOOL -	%IX7.3	BOOL		
KNX_1		2 - Switch 2 on/off - BOOL -	%IX7.4	BOOL		
KNX_1		2 - Switch 2 on/off - BOOL -	%IX7.5	BOOL		
KNX_1	KNXIN002	2 - Switch 2 on/off - BOOL -	%IX8.0	BOOL		
KNX_1		Control of 2 - Switch 2 on/off%QB5		BYTE		
KNX_1		Control of 2 - Switch 2 on/off%QX5.0		BOOL		
KNX_1		Control of 2 - Switch 2 on/off%QX5.1		BOOL		
KNX_1		3 - Switch 3 on/off - BOOL -	%IB9	BYTE		
KNX_1		3 - Switch 3 on/off - BOOL -	%IX9.3	BOOL		
KNX_1		3 - Switch 3 on/off - BOOL -	%IX9.4	BOOL		
KNX_1		3 - Switch 3 on/off - BOOL -	%IX9.5	BOOL		
KNX_1	KNXIN003	3 - Switch 3 on/off - BOOL -	%IX10.0	BOOL		
KNX_1		Control of 3 - Switch 3 on/off%QB6		BYTE		
KNX_1		Control of 3 - Switch 3 on/off%QX6.0		BOOL		
KNX_1		Control of 3 - Switch 3 on/off%QX6.1		BOOL		
KNX_1		4 - Switch 4 on/off - BOOL -	%IB11	BYTE		
KNX_1		4 - Switch 4 on/off - BOOL -	%IX11.3	BOOL		
KNX_1		4 - Switch 4 on/off - BOOL -	%IX11.4	BOOL		
KNX_1		4 - Switch 4 on/off - BOOL -	%IX11.5	BOOL		

ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1




ABB EQmatic Energy Analyzer QA/S x.yy.1

Collection, management and storage of meter data from QA/S via Modbus TCP

Data sharing via Modbus TCP to KNX: Building Automation Controller BAC/S 1.5.1

The screenshot shows the ETS5 software interface for configuring a Building Automation Controller (BAC/S). The main window displays a table of objects with the following columns: Numb, Group Address, Name, Object Function, Description, Length, C, R, W, T, U, Data Type, and Priority.

Numb	Group Address	Name	Object Function	Description	Length	C	R	W	T	U	Data Type	Priority
1	7/1/21	Switch 1 on/off	BOOL	Switch 1 on/off	1 bit	C	-	W	T	U	1-bit	Low
2	7/1/22	Switch 2 on/off	BOOL	Switch 2 on/off	1 bit	C	-	W	T	U	1-bit	Low
3	7/1/23	Switch 3 on/off	BOOL	Switch 3 on/off	1 bit	C	-	W	T	U	1-bit	Low
4	7/1/24	Switch 4 on/off	BOOL	Switch 4 on/off	1 bit	C	-	W	T	U	1-bit	Low
5	7/1/31	Status Logic 1	BOOL	Status Logic 1	1 bit	C	R	-	T	-	1-bit	Low
6	7/1/32	Status Logic 2	BOOL	Status Logic 2	1 bit	C	R	-	T	-	1-bit	Low
7	7/1/41	Room temperature	REAL	Room temperature	2 bytes	C	-	W	T	U	2-byte float value	Low
8	7/1/102	4-Octet vorzeichenloser Wert	Ausgang (SPS zu KNX) - DPT 12.*	Active Import...	4 bytes	C	R	-	T	-	4-byte unsigned value	Low

The interface also shows a 'Group Addresses' list at the bottom, which includes entries like '7/1/17 BAC/S - Digital Output/Relais 7', '7/1/21 Switch 1 on/off', and '7/1/102 Active Imported Energy Meter 1'. The 'Properties' panel on the right shows details for the selected object, including its name, individual address, and description.

Disclaimer

Technical data in this presentation are only approximate figures. The information in this presentation is subject to change without notice and should not be construed as a commitment by ABB. ABB assumes no responsibility for any errors that may appear in this presentation.

ABB shall in no case be liable under, or in connection with the presentation towards any person or entity, to which the presentation has been made available, in view of any damages or losses – irrespective of the legal grounds. In particular ABB shall in no event be liable for any indirect, consequential or special damages, such as - but not limited to – loss of profit, loss of revenue, loss of earnings, cost of capital or cost connected with an interruption of business.

© Copyright [2021] ABB. All rights reserved.

ABB